



Drew Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004594	3/17/2021	3/17/2022	1	Cooler	In cafeteria	WF-03172021-004594	1/27/2022	FT-FY22-01042022-004594-A	<1	FT-FY22-01042022-004594-B	<1	
WS- 004599	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 104	WF-09062021-004599	1/27/2022	FT-FY22-01042022-004599-A	<1	FT-FY22-01042022-004599-B	<1	
WS- 004600	3/17/2021	3/17/2022	1	Combo Fountain	In classroom 104	WF-03172021-004600	1/27/2022	FT-FY22-01042022-004600-A	<1	FT-FY22-01042022-004600-B	<1	
WS- 004602	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 108	High Left	WF-09062021-004602	1/27/2022	FT-FY22-01042022-004602-A	<1	FT-FY22-01042022-004602-B	<1
WS- 004603	3/17/2021	3/17/2022	1	Combo Fountain	In classroom 108	Low Right	WF-03172021-004603	1/27/2022	FT-FY22-01042022-004603-A	<1	FT-FY22-01042022-004603-B	<1
WS- 004604	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 105	WF-09062021-004604	1/27/2022	FT-FY22-01042022-004604-A	<1	FT-FY22-01042022-004604-B	<1	
WS- 004605	3/17/2021	3/17/2022	1	Combo Fountain	In classroom 105	WF-03172021-004605	1/27/2022	FT-FY22-01042022-004605-A	<1	FT-FY22-01042022-004605-B	<1	
WS- 004606	3/17/2021	3/17/2022	1	Cooler	In hallway adjacent to room 107	High Left	WF-03172021-004606	1/27/2022	FT-FY22-01042022-004606-A	<1	FT-FY22-01042022-004606-B	<1
WS- 004607	3/17/2021	3/17/2022	1	Cooler	In hallway adjacent to room 107	Low Right	WF-03172021-004607	1/27/2022	FT-FY22-01042022-004607-A	<1	FT-FY22-01042022-004607-B	<1
WS- 004608	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 107	High Left	WF-09062021-004608	1/27/2022	FT-FY22-01042022-004608-A	<1	FT-FY22-01042022-004608-B	<1
WS- 004609	3/17/2021	3/17/2022	1	Combo Fountain	In classroom 107	Low Right	WF-03172021-004609	1/27/2022	FT-FY22-01042022-004609-A	<1	FT-FY22-01042022-004609-B	<1
WS- 004610	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 106	WF-09062021-004610	1/27/2022	FT-FY22-01042022-004610-A	<1	FT-FY22-01042022-004610-B	<1	
WS- 004611	3/17/2021	3/17/2022	1	Combo Fountain	In classroom 106	WF-03172021-004611	1/27/2022	FT-FY22-01042022-004611-A	<1	FT-FY22-01042022-004611-B	<1	
WS- 004612	9/6/2021	9/6/2022	2	Combo Faucet	In classroom 205	High Left	WF-09062021-004612	1/27/2022	FT-FY22-01042022-004612-A	<1	FT-FY22-01042022-004612-B	<1
WS- 004613	3/17/2021	3/17/2022	2	Combo Fountain	In classroom 205	Low Right	WF-03172021-004613	1/27/2022	FT-FY22-01042022-004613-A	<1	FT-FY22-01042022-004613-B	<1
WS- 004614	9/6/2021	9/6/2022	2	Combo Faucet	In classroom 207	High Left	WF-09062021-004614	1/27/2022	FT-FY22-01042022-004614-A	<1	FT-FY22-01042022-004614-B	<1
WS- 004615	3/17/2021	3/17/2022	2	Combo Fountain	In classroom 207	Low Right	WF-03172021-004615	1/27/2022	FT-FY22-01042022-004615-A	<1	FT-FY22-01042022-004615-B	<1
WS- 004619	9/6/2021	9/6/2022	2	Combo Faucet	In classroom 209	High Left	WF-09062021-004619	1/27/2022	FT-FY22-01042022-004619-A	<1	FT-FY22-01042022-004619-B	<1
WS- 004620	3/17/2021	3/17/2022	2	Combo Fountain	In classroom 209	Low Right	WF-03172021-004620	1/27/2022	FT-FY22-01042022-004620-A	1.7	FT-FY22-01042022-004620-B	<1
WS- 004622	9/6/2021	9/6/2022	2	Combo Faucet	In classroom 200	Left	WF-09062021-004622	1/27/2022	FT-FY22-01042022-004622-A	<1	FT-FY22-01042022-004622-B	<1
WS- 004623	3/17/2021	3/17/2022	2	Combo Fountain	In classroom 200	Right	WF-03172021-004623	1/27/2022	FT-FY22-01042022-004623-A	<1	FT-FY22-01042022-004623-B	<1
WS- 004624	3/17/2021	3/17/2022	2	Cooler	In hallway adjacent to room 212	High Left	WF-03172021-004624	1/27/2022	FT-FY22-01042022-004624-A	<1	FT-FY22-01042022-004624-B	<1
WS- 004625	3/17/2021	3/17/2022	2	Cooler	In hallway adjacent to room 212	Low Right	WF-03172021-004625	1/27/2022	FT-FY22-01042022-004625-A	<1	FT-FY22-01042022-004625-B	<1
WS- 004626	3/17/2021	3/17/2022	2	Break Room	In staff lounge 213	WF-03172021-004626	1/27/2022	FT-FY22-01042022-004626-A	<1	FT-FY22-01042022-004626-B	<1	
WS- 004627	3/17/2021	3/17/2022	2	Cooler	In staff lounge 213	WF-03172021-004627	1/27/2022	FT-FY22-01042022-004627-A	<1	FT-FY22-01042022-004627-B	<1	
WS- 004629	9/6/2021	9/6/2022	3	Combo Faucet	In classroom 312	WF-09062021-004629	1/27/2022	FT-FY22-01042022-004629-A	4.2	FT-FY22-01042022-004629-B	<1	
WS- 004630	3/17/2021	3/17/2022	3	Combo Fountain	In classroom 312	WF-03172021-004630	1/27/2022	FT-FY22-01042022-004630-A	<1	FT-FY22-01042022-004630-B	<1	
WS- 004631	3/17/2021	3/17/2022	3	Cooler	In hallway adjacent to room 300	High Left	WF-03172021-004631	1/27/2022	FT-FY22-01042022-004631-A	<1	FT-FY22-01042022-004631-B	<1
WS- 004641	3/17/2021	3/17/2022	4	Break Room	In staff lounge	WF-03172021-004641	1/27/2022	FT-FY22-01042022-004641-A	<1	FT-FY22-01042022-004641-B	<1	
WS- 004642	3/17/2021	3/17/2022	4	Cooler	In hallway adjacent to arts studio	High Left	WF-03172021-004642	1/27/2022	FT-FY22-01042022-004642-A	<1	FT-FY22-01042022-004642-B	<1
WS- 004643	3/17/2021	3/17/2022	4	Cooler	In hallway adjacent to arts studio	Low Right	WF-03172021-004643	1/27/2022	FT-FY22-01042022-004643-A	<1	FT-FY22-01042022-004643-B	<1
WS- 004644	3/17/2021	3/17/2022	4	Cooler	In hallway adjacent to room 407	High Left	WF-03172021-004644	1/27/2022	FT-FY22-01042022-004644-A	<1	FT-FY22-01042022-004644-B	<1
WS- 004645	3/17/2021	3/17/2022	4	Cooler	In hallway adjacent to room 407	Low Right	WF-03172021-004645	1/27/2022	FT-FY22-01042022-004645-A	<1	FT-FY22-01042022-004645-B	<1
WS- 004646	3/17/2021	3/17/2022	3	Break Room	In staff lounge	WF-03172021-004646	1/27/2022	FT-FY22-01042022-004646-A	<1	FT-FY22-01042022-004646-B	<1	
WS- 004649	3/17/2021	3/17/2022	4	Bottle Filler	In hallway adjacent to arts studio	WF-03172021-004649	1/27/2022	FT-FY22-01042022-004649-A	<1	FT-FY22-01042022-004649-B	<1	

WS-009118	9/6/2021	9/6/2022	2	Combo Faucet	In classroom 212	WF-09062021-009118	1/27/2022	FT-FY22-01042022-009118-A	<1	FT-FY22-01042022-009118-B	<1
WS-009119	3/17/2021	3/17/2022	2	Combo Fountain	In classroom 212	WF-03172021-009119	1/27/2022	FT-FY22-01042022-009119-A	<1	FT-FY22-01042022-009119-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004601	1/21/2021	1/21/2022	1	Food Prep Sink	In kitchen	WF-01212021-004601	1/27/2022	FT-FY22-01042022-004601-A	<1	FT-FY22-01042022-004601-B	<1