



# Drew Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004590	2/28/2023	2/28/2024	1	Bottle Filler	In hallway across from health suite	WF-02282023-004590	12/21/2023	FT-FY24-11272023-004590-A	<1	FT-FY24-11272023-004590-B	<1
WS- 004592	5/31/2023	5/31/2024	1	Cooler	In auditorium High Left	WF-05312023-004592	12/21/2023	FT-FY24-11272023-004592-A	<1	FT-FY24-11272023-004592-B	<1
WS- 004593	5/31/2023	5/31/2024	1	Cooler	In auditorium Low Right	WF-05312023-004593	12/21/2023	FT-FY24-11272023-004593-A	<1	FT-FY24-11272023-004593-B	<1
WS- 004594	2/28/2023	2/28/2024	1	Cooler	In cafeteria	WF-02282023-004594	12/21/2023	FT-FY24-11272023-004594-A	<1	FT-FY24-11272023-004594-B	<1
WS- 004596	2/28/2023	2/28/2024	1	Cooler	In hallway across from health suite Low Right	WF-02282023-004596	12/21/2023	FT-FY24-11272023-004596-A	<1	FT-FY24-11272023-004596-B	<1
WS- 004599	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 104	WF-08222023-004599	12/21/2023	FT-FY24-11272023-004599-A	<1	FT-FY24-11272023-004599-B	<1
WS- 004602	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 108 High Left	WF-08222023-004602	12/21/2023	FT-FY24-11272023-004602-A	<1	FT-FY24-11272023-004602-B	<1
WS- 004603	7/12/2023	7/12/2024	1	Combo Fountain	In classroom 108 Low Right	WF-07122023-004603	12/21/2023	FT-FY24-11272023-004603-A	<1	FT-FY24-11272023-004603-B	<1
WS- 004604	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 105	WF-08222023-004604	12/21/2023	FT-FY24-11272023-004604-A	<1	FT-FY24-11272023-004604-B	<1
WS- 004605	7/12/2023	7/12/2024	1	Combo Fountain	In classroom 105	WF-07122023-004605	12/21/2023	FT-FY24-11272023-004605-A	<1	FT-FY24-11272023-004605-B	<1
WS- 004608	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 107 High Left	WF-08222023-004608	12/21/2023	FT-FY24-11272023-004608-A	<1	FT-FY24-11272023-004608-B	<1
WS- 004609	7/12/2023	7/12/2024	1	Combo Fountain	In classroom 107 Low Right	WF-07122023-004609	12/21/2023	FT-FY24-11272023-004609-A	<1	FT-FY24-11272023-004609-B	<1
WS- 004610	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 106	WF-08222023-004610	12/21/2023	FT-FY24-11272023-004610-A	<1	FT-FY24-11272023-004610-B	<1
WS- 004611	7/12/2023	7/12/2024	1	Combo Fountain	In classroom 106	WF-07122023-004611	12/21/2023	FT-FY24-11272023-004611-A	<1	FT-FY24-11272023-004611-B	<1
WS- 004612	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 205 High Left	WF-08222023-004612	12/21/2023	FT-FY24-11272023-004612-A	<1	FT-FY24-11272023-004612-B	<1
WS- 004613	2/28/2023	2/28/2024	2	Combo Fountain	In classroom 205 Low Right	WF-02282023-004613	12/21/2023	FT-FY24-11272023-004613-A	<1	FT-FY24-11272023-004613-B	<1
WS- 004614	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 207 High Left	WF-08222023-004614	12/21/2023	FT-FY24-11272023-004614-A	<1	FT-FY24-11272023-004614-B	<1
WS- 004615	7/12/2023	7/12/2024	2	Combo Fountain	In classroom 207 Low Right	WF-07122023-004615	12/21/2023	FT-FY24-11272023-004615-A	<1	FT-FY24-11272023-004615-B	<1
WS- 004619	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 209 High Left	WF-08222023-004619	12/21/2023	FT-FY24-11272023-004619-A	<1	FT-FY24-11272023-004619-B	<1
WS- 004620	7/12/2023	7/12/2024	2	Combo Fountain	In classroom 209 Low Right	WF-07122023-004620	12/21/2023	FT-FY24-11272023-004620-A	<1	FT-FY24-11272023-004620-B	<1
WS- 004623	7/12/2023	7/12/2024	2	Combo Fountain	In classroom 200 Right	WF-07122023-004623	12/21/2023	FT-FY24-11272023-004623-A	<1	FT-FY24-11272023-004623-B	<1
WS- 004624	5/31/2023	5/31/2024	2	Cooler	In hallway adjacent to room 212 High Left	WF-05312023-004624	12/21/2023	FT-FY24-11272023-004624-A	<1	FT-FY24-11272023-004624-B	<1
WS- 004625	5/31/2023	5/31/2024	2	Cooler	In hallway adjacent to room 212 Low Right	WF-05312023-004625	12/21/2023	FT-FY24-11272023-004625-A	<1	FT-FY24-11272023-004625-B	<1
WS- 004626	7/12/2023	7/12/2024	2	Break Room	In staff lounge 213	WF-07122023-004626	12/21/2023	FT-FY24-11272023-004626-A	<1	FT-FY24-11272023-004626-B	<1
WS- 004627	7/12/2023	7/12/2024	2	Cooler	In staff lounge 213	WF-07122023-004627	12/21/2023	FT-FY24-11272023-004627-A	<1	FT-FY24-11272023-004627-B	<1
WS- 004629	8/22/2023	8/22/2024	3	Combo Faucet	In classroom 312	WF-08222023-004629	12/21/2023	FT-FY24-11272023-004629-A	<1	FT-FY24-11272023-004629-B	<1
WS- 004631	5/31/2023	5/31/2024	3	Cooler	In hallway adjacent to room 300 High Left	WF-05312023-004631	12/21/2023	FT-FY24-11272023-004631-A	<1	FT-FY24-11272023-004631-B	<1
WS- 004632	5/31/2023	5/31/2024	3	Cooler	In hallway adjacent to room 300 Low Right	WF-05312023-004632	12/21/2023	FT-FY24-11272023-004632-A	<1	FT-FY24-11272023-004632-B	<1
WS- 004641	7/12/2023	7/12/2024	4	Break Room	In staff lounge	WF-07122023-004641	12/21/2023	FT-FY24-11272023-004641-A	<1	FT-FY24-11272023-004641-B	<1
WS- 004642	5/31/2023	5/31/2024	4	Cooler	In hallway adjacent to arts studio High Left	WF-05312023-004642	12/21/2023	FT-FY24-11272023-004642-A	<1	FT-FY24-11272023-004642-B	<1
WS- 004643	5/31/2023	5/31/2024	4	Cooler	In hallway adjacent to arts studio Low Right	WF-05312023-004643	12/21/2023	FT-FY24-11272023-004643-A	<1	FT-FY24-11272023-004643-B	<1
WS- 004649	5/31/2023	5/31/2024	4	Bottle Filler	In hallway adjacent to arts studio	WF-05312023-004649	12/21/2023	FT-FY24-11272023-004649-A	<1	FT-FY24-11272023-004649-B	<1
WS- 009118	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 212	WF-08222023-009118	12/21/2023	FT-FY24-11272023-009118-A	<1	FT-FY24-11272023-009118-B	<1
WS- 009119	7/12/2023	7/12/2024	2	Combo Fountain	In classroom 212	WF-07122023-009119	12/21/2023	FT-FY24-11272023-009119-A	<1	FT-FY24-11272023-009119-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004601	12/21/2022	12/21/2023	1	Food Prep Sink	In kitchen	WF-12212022-004601	12/21/2023	FT-FY24-11272023-004601-A	<1	FT-FY24-11272023-004601-B	<1