



Drew ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004592	4/1/2019	4/1/2020	1	Cooler	In auditorium High Left	WF-04012019-004592	11/27/2019	FT-FY20-112019-004592-A	<1	FT-FY20-112019-004592-B	<1
WS-004593	4/1/2019	4/1/2020	1	Cooler	In auditorium Low Right	WF-04012019-004593	11/27/2019	FT-FY20-112019-004593-A	<1	FT-FY20-112019-004593-B	<1
WS-004594	4/1/2019	4/1/2020	1	Cooler	In cafeteria	WF-04012019-004594	11/27/2019	FT-FY20-112019-004594-A	<1	FT-FY20-112019-004594-B	<1
WS-004595	4/1/2019	4/1/2020	1	Cooler	In hallway across from health suite High Left	WF-04012019-004595	11/27/2019	FT-FY20-112019-004595-A	<1	FT-FY20-112019-004595-B	<1
WS-004596	4/1/2019	4/1/2020	1	Cooler	In hallway across from health suite Low Right	WF-04012019-004596	11/27/2019	FT-FY20-112019-004596-A	<1	FT-FY20-112019-004596-B	<1
WS-004597	4/1/2019	4/1/2020	1	Cooler	In health suite	WF-04012019-004597	11/27/2019	FT-FY20-112019-004597-A	<1	FT-FY20-112019-004597-B	<1
WS-004599	9/23/2019	9/23/2020	1	Combo Faucet	In classroom 104	WF-09232019-004599	11/27/2019	FT-FY20-112019-004599-A	<1	FT-FY20-112019-004599-B	<1
WS-004600	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 104	WF-04012019-004600	11/27/2019	FT-FY20-112019-004600-A	<1	FT-FY20-112019-004600-B	<1
WS-004602	9/23/2019	9/23/2020	1	Combo Faucet	In classroom 108 High Left	WF-09232019-004602	11/27/2019	FT-FY20-112019-004602-A	<1	FT-FY20-112019-004602-B	<1
WS-004603	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 108 Low Right	WF-04012019-004603	11/27/2019	FT-FY20-112019-004603-A	<1	FT-FY20-112019-004603-B	<1
WS-004604	9/23/2019	9/23/2020	1	Combo Faucet	In classroom 105	WF-09232019-004604	11/27/2019	FT-FY20-112019-004604-A	1.1	FT-FY20-112019-004604-B	<1
WS-004605	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 105	WF-04012019-004605	11/27/2019	FT-FY20-112019-004605-A	<1	FT-FY20-112019-004605-B	<1
WS-004606	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room 107 High Left	WF-04012019-004606	11/27/2019	FT-FY20-112019-004606-A	<1	FT-FY20-112019-004606-B	<1
WS-004607	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room 107 Low Right	WF-04012019-004607	11/27/2019	FT-FY20-112019-004607-A	<1	FT-FY20-112019-004607-B	<1
WS-004608	9/23/2019	9/23/2020	1	Combo Faucet	In classroom 107 High Left	WF-09232019-004608	11/27/2019	FT-FY20-112019-004608-A	<1	FT-FY20-112019-004608-B	<1
WS-004609	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 107 Low Right	WF-04012019-004609	11/27/2019	FT-FY20-112019-004609-A	<1	FT-FY20-112019-004609-B	<1
WS-004610	9/23/2019	9/23/2020	1	Combo Faucet	In classroom 106	WF-09232019-004610	11/27/2019	FT-FY20-112019-004610-A	<1	FT-FY20-112019-004610-B	<1
WS-004611	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 106	WF-04012019-004611	11/27/2019	FT-FY20-112019-004611-A	<1	FT-FY20-112019-004611-B	<1
WS-004612	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 205 High Left	WF-09232019-004612	11/27/2019	FT-FY20-112019-004612-A	<1	FT-FY20-112019-004612-B	<1
WS-004613	4/1/2019	4/1/2020	2	Combo Fountain	In classroom 205 Low Right	WF-04012019-004613	11/27/2019	FT-FY20-112019-004613-A	<1	FT-FY20-112019-004613-B	<1
WS-004614	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 207 High Left	WF-09232019-004614	11/27/2019	FT-FY20-112019-004614-A	<1	FT-FY20-112019-004614-B	<1
WS-004615	4/1/2019	4/1/2020	2	Combo Fountain	In classroom 207 Low Right	WF-04012019-004615	11/27/2019	FT-FY20-112019-004615-A	<1	FT-FY20-112019-004615-B	<1
WS-004616	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to room 207 High Left	WF-04012019-004616	11/27/2019	FT-FY20-112019-004616-A	<1	FT-FY20-112019-004616-B	<1
WS-004617	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to room 207 Low Right	WF-04012019-004617	11/27/2019	FT-FY20-112019-004617-A	<1	FT-FY20-112019-004617-B	<1
WS-004619	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 209 High Left	WF-09232019-004619	11/27/2019	FT-FY20-112019-004619-A	<1	FT-FY20-112019-004619-B	<1
WS-004620	4/1/2019	4/1/2020	2	Combo Fountain	In classroom 209 Low Right	WF-04012019-004620	11/27/2019	FT-FY20-112019-004620-A	<1	FT-FY20-112019-004620-B	<1
WS-004622	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 200 Left	WF-09232019-004622	11/27/2019	FT-FY20-112019-004622-A	<1	FT-FY20-112019-004622-B	<1
WS-004623	4/1/2019	4/1/2020	2	Combo Fountain	In classroom 200 Right	WF-04012019-004623	11/27/2019	FT-FY20-112019-004623-A	<1	FT-FY20-112019-004623-B	<1
WS-004624	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to room 212 High Left	WF-04012019-004624	11/27/2019	FT-FY20-112019-004624-A	<1	FT-FY20-112019-004624-B	<1
WS-004625	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to room 212 Low Right	WF-04012019-004625	11/27/2019	FT-FY20-112019-004625-A	<1	FT-FY20-112019-004625-B	<1
WS-004626	4/1/2019	4/1/2020	2	Break Room	In staff lounge 213	WF-04012019-004626	11/27/2019	FT-FY20-112019-004626-A	<1	FT-FY20-112019-004626-B	<1
WS-004627	4/1/2019	4/1/2020	2	Cooler	In staff lounge 213	WF-04012019-004627	11/27/2019	FT-FY20-112019-004627-A	<1	FT-FY20-112019-004627-B	<1
WS-004629	9/23/2019	9/23/2020	3	Combo Faucet	In classroom 312	WF-09232019-004629	11/27/2019	FT-FY20-112019-004629-A	1	FT-FY20-112019-004629-B	<1

WS- 004630	4/1/2019	4/1/2020	3	Combo Fountain	In classroom 312			WF-04012019-004630	11/27/2019	FT-FY20-112019-004630-A	<1	FT-FY20-112019-004630-B	<1
WS- 004631	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to room 300	High	Left	WF-04012019-004631	11/27/2019	FT-FY20-112019-004631-A	<1	FT-FY20-112019-004631-B	<1
WS- 004632	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to room 300	Low	Right	WF-04012019-004632	11/27/2019	FT-FY20-112019-004632-A	<1	FT-FY20-112019-004632-B	<1
WS- 004639	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to room 307	Low	Right	WF-04012019-004639	11/27/2019	FT-FY20-112019-004639-A	<1	FT-FY20-112019-004639-B	<1
WS- 004641	4/1/2019	4/1/2020	4	Break Room	In staff lounge			WF-04012019-004641	11/27/2019	FT-FY20-112019-004641-A	<1	FT-FY20-112019-004641-B	<1
WS- 004642	4/1/2019	4/1/2020	4	Cooler	In hallway adjacent to arts studio	High	Left	WF-04012019-004642	11/27/2019	FT-FY20-112019-004642-A	<1	FT-FY20-112019-004642-B	<1
WS- 004643	4/1/2019	4/1/2020	4	Cooler	In hallway adjacent to arts studio	Low	Right	WF-04012019-004643	11/27/2019	FT-FY20-112019-004643-A	<1	FT-FY20-112019-004643-B	<1
WS- 004644	4/1/2019	4/1/2020	4	Cooler	In hallway adjacent to room 407	High	Left	WF-04012019-004644	11/27/2019	FT-FY20-112019-004644-A	<1	FT-FY20-112019-004644-B	<1
WS- 004645	4/1/2019	4/1/2020	4	Cooler	In hallway adjacent to room 407	Low	Right	WF-04012019-004645	11/27/2019	FT-FY20-112019-004645-A	<1	FT-FY20-112019-004645-B	<1
WS- 004646	4/1/2019	4/1/2020	3	Break Room	In staff lounge			WF-04012019-004646	11/27/2019	FT-FY20-112019-004646-A	<1	FT-FY20-112019-004646-B	<1
WS- 004649	4/1/2019	4/1/2020	4	Bottle Filler	In hallway adjacent to arts studio			WF-04012019-004649	11/27/2019	FT-FY20-112019-004649-A	<1	FT-FY20-112019-004649-B	<1
WS- 009118	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 212			WF-09232019-009118	11/27/2019	FT-FY20-112019-009118-A	<1	FT-FY20-112019-009118-B	<1
WS- 009119	4/1/2019	4/1/2020	2	Combo Fountain	In classroom 212			WF-04012019-009119	11/27/2019	FT-FY20-112019-009119-A	<1	FT-FY20-112019-009119-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004601	7/1/2019	7/1/2020	1	Food Prep Sink	In kitchen	WF-07012019-004601	11/27/2019	FT-FY20-112019-004601-A	<1	FT-FY20-112019-004601-B	<1	