



# Drew Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004592	3/9/2022	3/9/2023	1	Cooler	In auditorium High Left	WF-03092022-004592	11/10/2022	FT-FY23-10102022-004592-A	<1	FT-FY23-10102022-004592-B	<1
WS-004593	3/9/2022	3/9/2023	1	Cooler	In auditorium Low Right	WF-03092022-004593	11/10/2022	FT-FY23-10102022-004593-A	<1	FT-FY23-10102022-004593-B	<1
WS-004594	3/9/2022	3/9/2023	1	Cooler	In cafeteria	WF-03092022-004594	11/10/2022	FT-FY23-10102022-004594-A	<1	FT-FY23-10102022-004594-B	<1
WS-004599	8/29/2022	8/29/2023	1	Combo Faucet	In classroom 104	WF-08292022-004599	11/10/2022	FT-FY23-10102022-004599-A	<1	FT-FY23-10102022-004599-B	<1
WS-004600	3/9/2022	3/9/2023	1	Combo Fountain	In classroom 104	WF-03092022-004600	11/10/2022	FT-FY23-10102022-004600-A	<1	FT-FY23-10102022-004600-B	<1
WS-004602	8/29/2022	8/29/2023	1	Combo Faucet	In classroom 108 High Left	WF-08292022-004602	11/10/2022	FT-FY23-10102022-004602-A	<1	FT-FY23-10102022-004602-B	<1
WS-004603	3/9/2022	3/9/2023	1	Combo Fountain	In classroom 108 Low Right	WF-03092022-004603	11/10/2022	FT-FY23-10102022-004603-A	<1	FT-FY23-10102022-004603-B	<1
WS-004604	8/29/2022	8/29/2023	1	Combo Faucet	In classroom 105	WF-08292022-004604	11/10/2022	FT-FY23-10102022-004604-A	1.8	FT-FY23-10102022-004604-B	<1
WS-004606	3/9/2022	3/9/2023	1	Cooler	In hallway adjacent to room 107 High Left	WF-03092022-004606	11/10/2022	FT-FY23-10102022-004606-A	<1	FT-FY23-10102022-004606-B	<1
WS-004607	3/9/2022	3/9/2023	1	Cooler	In hallway adjacent to room 107 Low Right	WF-03092022-004607	11/10/2022	FT-FY23-10102022-004607-A	<1	FT-FY23-10102022-004607-B	<1
WS-004608	8/29/2022	8/29/2023	1	Combo Faucet	In classroom 107 High Left	WF-08292022-004608	11/10/2022	FT-FY23-10102022-004608-A	3.1	FT-FY23-10102022-004608-B	<1
WS-004609	3/9/2022	3/9/2023	1	Combo Fountain	In classroom 107 Low Right	WF-03092022-004609	11/10/2022	FT-FY23-10102022-004609-A	<1	FT-FY23-10102022-004609-B	<1
WS-004610	8/29/2022	8/29/2023	1	Combo Faucet	In classroom 106	WF-08292022-004610	11/10/2022	FT-FY23-10102022-004610-A	1.1	FT-FY23-10102022-004610-B	<1
WS-004611	3/9/2022	3/9/2023	1	Combo Fountain	In classroom 106	WF-03092022-004611	11/10/2022	FT-FY23-10102022-004611-A	<1	FT-FY23-10102022-004611-B	<1
WS-004612	8/29/2022	8/29/2023	2	Combo Faucet	In classroom 205 High Left	WF-08292022-004612	11/10/2022	FT-FY23-10102022-004612-A	<1	FT-FY23-10102022-004612-B	<1
WS-004613	3/9/2022	3/9/2023	2	Combo Fountain	In classroom 205 Low Right	WF-03092022-004613	11/10/2022	FT-FY23-10102022-004613-A	<1	FT-FY23-10102022-004613-B	<1
WS-004614	8/29/2022	8/29/2023	2	Combo Faucet	In classroom 207 High Left	WF-08292022-004614	11/10/2022	FT-FY23-10102022-004614-A	2.0	FT-FY23-10102022-004614-B	<1
WS-004615	3/9/2022	3/9/2023	2	Combo Fountain	In classroom 207 Low Right	WF-03092022-004615	11/10/2022	FT-FY23-10102022-004615-A	1.7	FT-FY23-10102022-004615-B	<1
WS-004616	3/9/2022	3/9/2023	2	Cooler	In hallway adjacent to room 207 High Left	WF-03092022-004616	11/10/2022	FT-FY23-10102022-004616-A	<1	FT-FY23-10102022-004616-B	<1
WS-004619	8/29/2022	8/29/2023	2	Combo Faucet	In classroom 209 High Left	WF-08292022-004619	11/10/2022	FT-FY23-10102022-004619-A	<1	FT-FY23-10102022-004619-B	<1
WS-004620	3/9/2022	3/9/2023	2	Combo Fountain	In classroom 209 Low Right	WF-03092022-004620	11/10/2022	FT-FY23-10102022-004620-A	<1	FT-FY23-10102022-004620-B	<1
WS-004622	8/29/2022	8/29/2023	2	Combo Faucet	In classroom 200 Left	WF-08292022-004622	11/10/2022	FT-FY23-10102022-004622-A	<1	FT-FY23-10102022-004622-B	<1
WS-004623	3/9/2022	3/9/2023	2	Combo Fountain	In classroom 200 Right	WF-03092022-004623	11/10/2022	FT-FY23-10102022-004623-A	<1	FT-FY23-10102022-004623-B	<1
WS-004626	3/9/2022	3/9/2023	2	Break Room	In staff lounge 213	WF-03092022-004626	11/10/2022	FT-FY23-10102022-004626-A	<1	FT-FY23-10102022-004626-B	<1
WS-004627	3/9/2022	3/9/2023	2	Cooler	In staff lounge 213	WF-03092022-004627	11/10/2022	FT-FY23-10102022-004627-A	<1	FT-FY23-10102022-004627-B	<1
WS-004629	8/29/2022	8/29/2023	3	Combo Faucet	In classroom 312	WF-08292022-004629	11/10/2022	FT-FY23-10102022-004629-A	<1	FT-FY23-10102022-004629-B	<1
WS-004630	3/9/2022	3/9/2023	3	Combo Fountain	In classroom 312	WF-03092022-004630	11/10/2022	FT-FY23-10102022-004630-A	<1	FT-FY23-10102022-004630-B	<1
WS-004631	3/9/2022	3/9/2023	3	Cooler	In hallway adjacent to room 300 High Left	WF-03092022-004631	11/10/2022	FT-FY23-10102022-004631-A	<1	FT-FY23-10102022-004631-B	<1
WS-004641	3/9/2022	3/9/2023	4	Break Room	In staff lounge	WF-03092022-004641	11/10/2022	FT-FY23-10102022-004641-A	<1	FT-FY23-10102022-004641-B	<1
WS-004642	3/9/2022	3/9/2023	4	Cooler	In hallway adjacent to arts studio High Left	WF-03092022-004642	11/10/2022	FT-FY23-10102022-004642-A	<1	FT-FY23-10102022-004642-B	<1
WS-004643	3/9/2022	3/9/2023	4	Cooler	In hallway adjacent to arts studio Low Right	WF-03092022-004643	11/10/2022	FT-FY23-10102022-004643-A	<1	FT-FY23-10102022-004643-B	<1
WS-004649	3/9/2022	3/9/2023	4	Bottle Filler	In hallway adjacent to arts studio	WF-03092022-004649	11/10/2022	FT-FY23-10102022-004649-A	<1	FT-FY23-10102022-004649-B	<1
WS-009118	8/29/2022	8/29/2023	2	Combo Faucet	In classroom 212	WF-08292022-009118	11/10/2022	FT-FY23-10102022-009118-A	<1	FT-FY23-10102022-009118-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004601	1/10/2022	1/10/2023	1	Food Prep Sink	In kitchen	WF-01102022-004601	11/10/2022	FT-FY23-10102022-004601-A	<1	FT-FY23-10102022-004601-B	<1