



Drew Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004592	3/24/2020	3/24/2021	1	Cooler	In auditorium High Left	WF-03242020-004592	1/23/2021	FT-FY21-012021-004592-A	<1	FT-FY21-012021-004592-B	<1
WS-004593	3/24/2020	3/24/2021	1	Cooler	In auditorium Low Right	WF-03242020-004593	1/23/2021	FT-FY21-012021-004593-A	<1	FT-FY21-012021-004593-B	<1
WS-004594	3/24/2020	3/24/2021	1	Cooler	In cafeteria	WF-03242020-004594	1/23/2021	FT-FY21-012021-004594-A	<1	FT-FY21-012021-004594-B	<1
WS-004595	3/24/2020	3/24/2021	1	Cooler	In hallway across from health suite High Left	WF-03242020-004595	1/23/2021	FT-FY21-012021-004595-A	<1	FT-FY21-012021-004595-B	<1
WS-004596	3/24/2020	3/24/2021	1	Cooler	In hallway across from health suite Low Right	WF-03242020-004596	1/23/2021	FT-FY21-012021-004596-A	<1	FT-FY21-012021-004596-B	<1
WS-004597	3/24/2020	3/24/2021	1	Cooler	In health suite	WF-03242020-004597	1/23/2021	FT-FY21-012021-004597-A	<1	FT-FY21-012021-004597-B	<1
WS-004599	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 104	WF-09162020-004599	1/23/2021	FT-FY21-012021-004599-A	2.5	FT-FY21-012021-004599-B	<1
WS-004600	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 104	WF-03242020-004600	1/23/2021	FT-FY21-012021-004600-A	<1	FT-FY21-012021-004600-B	<1
WS-004602	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 108 High Left	WF-09162020-004602	1/23/2021	FT-FY21-012021-004602-A	<1	FT-FY21-012021-004602-B	<1
WS-004603	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 108 Low Right	WF-03242020-004603	1/23/2021	FT-FY21-012021-004603-A	<1	FT-FY21-012021-004603-B	<1
WS-004604	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 105	WF-09162020-004604	1/23/2021	FT-FY21-012021-004604-A	<1	FT-FY21-012021-004604-B	<1
WS-004605	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 105	WF-03242020-004605	1/23/2021	FT-FY21-012021-004605-A	<1	FT-FY21-012021-004605-B	<1
WS-004606	3/24/2020	3/24/2021	1	Cooler	In hallway adjacent to room 107 High Left	WF-03242020-004606	1/23/2021	FT-FY21-012021-004606-A	<1	FT-FY21-012021-004606-B	<1
WS-004607	3/24/2020	3/24/2021	1	Cooler	In hallway adjacent to room 107 Low Right	WF-03242020-004607	1/23/2021	FT-FY21-012021-004607-A	<1	FT-FY21-012021-004607-B	<1
WS-004608	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 107 High Left	WF-09162020-004608	1/23/2021	FT-FY21-012021-004608-A	<1	FT-FY21-012021-004608-B	<1
WS-004609	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 107 Low Right	WF-03242020-004609	1/23/2021	FT-FY21-012021-004609-A	<1	FT-FY21-012021-004609-B	<1
WS-004610	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 106	WF-09162020-004610	1/23/2021	FT-FY21-012021-004610-A	<1	FT-FY21-012021-004610-B	<1
WS-004611	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 106	WF-03242020-004611	1/23/2021	FT-FY21-012021-004611-A	<1	FT-FY21-012021-004611-B	<1
WS-004612	9/16/2020	9/16/2021	2	Combo Faucet	In classroom 205 High Left	WF-09162020-004612	1/23/2021	FT-FY21-012021-004612-A	<1	FT-FY21-012021-004612-B	<1
WS-004613	3/24/2020	3/24/2021	2	Combo Fountain	In classroom 205 Low Right	WF-03242020-004613	1/23/2021	FT-FY21-012021-004613-A	<1	FT-FY21-012021-004613-B	<1
WS-004614	9/16/2020	9/16/2021	2	Combo Faucet	In classroom 207 High Left	WF-09162020-004614	1/23/2021	FT-FY21-012021-004614-A	<1	FT-FY21-012021-004614-B	<1
WS-004616	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to room 207 High Left	WF-03242020-004616	1/23/2021	FT-FY21-012021-004616-A	<1	FT-FY21-012021-004616-B	<1
WS-004617	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to room 207 Low Right	WF-03242020-004617	1/23/2021	FT-FY21-012021-004617-A	<1	FT-FY21-012021-004617-B	<1
WS-004619	9/16/2020	9/16/2021	2	Combo Faucet	In classroom 209 High Left	WF-09162020-004619	1/23/2021	FT-FY21-012021-004619-A	<1	FT-FY21-012021-004619-B	<1
WS-004620	3/24/2020	3/24/2021	2	Combo Fountain	In classroom 209 Low Right	WF-03242020-004620	1/23/2021	FT-FY21-012021-004620-A	<1	FT-FY21-012021-004620-B	<1
WS-004623	3/24/2020	3/24/2021	2	Combo Fountain	In classroom 200 Right	WF-03242020-004623	1/23/2021	FT-FY21-012021-004623-A	<1	FT-FY21-012021-004623-B	<1
WS-004624	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to room 212 High Left	WF-03242020-004624	1/23/2021	FT-FY21-012021-004624-A	<1	FT-FY21-012021-004624-B	<1
WS-004625	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to room 212 Low Right	WF-03242020-004625	1/23/2021	FT-FY21-012021-004625-A	<1	FT-FY21-012021-004625-B	<1
WS-004626	3/24/2020	3/24/2021	2	Break Room	In staff lounge 213	WF-03242020-004626	1/23/2021	FT-FY21-012021-004626-A	<1	FT-FY21-012021-004626-B	<1
WS-004627	3/24/2020	3/24/2021	2	Cooler	In staff lounge 213	WF-03242020-004627	1/23/2021	FT-FY21-012021-004627-A	<1	FT-FY21-012021-004627-B	<1
WS-004629	9/16/2020	9/16/2021	3	Combo Faucet	In classroom 312	WF-09162020-004629	1/23/2021	FT-FY21-012021-004629-A	<1	FT-FY21-012021-004629-B	<1
WS-004630	3/24/2020	3/24/2021	3	Combo Fountain	In classroom 312	WF-03242020-004630	1/23/2021	FT-FY21-012021-004630-A	<1	FT-FY21-012021-004630-B	<1

WS- 004631	3/24/2020	3/24/2021	3	Cooler	In hallway adjacent to room 300	High	Left	WF-03242020-004631	1/23/2021	FT-FY21-012021-004631-A	<1	FT-FY21-012021-004631-B	<1
WS- 004632	3/24/2020	3/24/2021	3	Cooler	In hallway adjacent to room 300	Low	Right	WF-03242020-004632	1/23/2021	FT-FY21-012021-004632-A	<1	FT-FY21-012021-004632-B	<1
WS- 004638	3/24/2020	3/24/2021	3	Cooler	In hallway adjacent to room 307	High	Left	WF-03242020-004638	1/23/2021	FT-FY21-012021-004638-A	<1	FT-FY21-012021-004638-B	<1
WS- 004639	3/24/2020	3/24/2021	3	Cooler	In hallway adjacent to room 307	Low	Right	WF-03242020-004639	1/23/2021	FT-FY21-012021-004639-A	<1	FT-FY21-012021-004639-B	<1
WS- 004641	3/24/2020	3/24/2021	4	Break Room	In staff lounge			WF-03242020-004641	1/23/2021	FT-FY21-012021-004641-A	<1	FT-FY21-012021-004641-B	<1
WS- 004644	3/24/2020	3/24/2021	4	Cooler	In hallway adjacent to room 407	High	Left	WF-03242020-004644	1/23/2021	FT-FY21-012021-004644-A	<1	FT-FY21-012021-004644-B	<1
WS- 004645	3/24/2020	3/24/2021	4	Cooler	In hallway adjacent to room 407	Low	Right	WF-03242020-004645	1/23/2021	FT-FY21-012021-004645-A	<1	FT-FY21-012021-004645-B	<1
WS- 004646	3/24/2020	3/24/2021	3	Break Room	In staff lounge			WF-03242020-004646	1/23/2021	FT-FY21-012021-004646-A	<1	FT-FY21-012021-004646-B	<1
WS- 009118	9/16/2020	9/16/2021	2	Combo Faucet	In classroom 212			WF-09162020-009118	1/23/2021	FT-FY21-012021-009118-A	<1	FT-FY21-012021-009118-B	<1
WS- 009119	3/24/2020	3/24/2021	2	Combo Fountain	In classroom 212			WF-03242020-009119	1/23/2021	FT-FY21-012021-009119-A	<1	FT-FY21-012021-009119-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004601	2/24/2020	2/24/2021	1	Food Prep Sink	In kitchen	WF-02242020-004601	1/23/2021	FT-FY21-012021-004601-A	<1	FT-FY21-012021-004601-B	<1	

FY21 Filter Test

Greater than than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004622	9/16/2020	9/16/2021	2	Combo Faucet	In classroom 200	Left	WF-09162020-004622	1/23/2021	FT-FY21-012021-004622-A	6.2	FT-FY21-012021-004622-B	<1

First Re-test (After Plumbing Check)

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004622	2/3/2021	2/3/2022	2	Combo Faucet	In classroom 200	Left	WF-02032021-004622	2/8/2021	FT-FY21-022021-004622-A	<1	FT-FY21-022021-004622-B	<1