



DREW LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	DREW ES	5/6/2016	WS-004650	Classroom	3	In room 113	WT-042916-4667-A	10	WT-042916-4667-B	2			
2	DREW ES	5/6/2016	WS-004649	Cooler	4	In hallway across from office LPTM (bottle filler)	WT-042916-4666-A	< 1	WT-042916-4666-B	< 1			
3	DREW ES	5/5/2016	WS-004648	Classroom	4	In room 407 Left	WT-042916-4665-A	3	WT-042916-4665-B	< 1			
4	DREW ES	5/5/2016	WS-004647	Classroom	4	In room 407 Right	WT-042916-4664-A	< 1	WT-042916-4664-B	< 1			
5	DREW ES	5/5/2016	WS-004646	Break Room	3	In teachers lounge	WT-042916-4663-A	5	WT-042916-4663-B	2			
6	DREW ES	5/5/2016	WS-004645	Cooler	4	In hallway adjacent to room 407 Low	WT-042916-4662-A	< 1	WT-042916-4662-B	< 1			
7	DREW ES	5/5/2016	WS-004644	Cooler	4	In hallway adjacent to room 407 High	WT-042916-4661-A	< 1	WT-042916-4661-B	< 1			
8	DREW ES	5/5/2016	WS-004643	Cooler	4	In hallway across from office LPTM Low	WT-042916-4660-A	< 1	WT-042916-4660-B	< 1			
9	DREW ES	5/5/2016	WS-004642	Cooler	4	In hallway across from office LPTM High	WT-042916-4659-A	< 1	WT-042916-4659-B	< 1			
10	DREW ES	5/5/2016	WS-004641	Break Room	4	In teacher lounge	WT-042916-4658-A	53	WT-042916-4658-B	< 1	Filter will be installed and then retested		
11	DREW ES	5/5/2016	WS-004640	Classroom	3	In room 305	WT-042916-4657-A	< 1	WT-042916-4657-B	< 1			
12	DREW ES	5/5/2016	WS-004639	Cooler	3	In hallway adjacent to room 307 Low	WT-042916-4656-A	< 1	WT-042916-4656-B	< 1			
13	DREW ES	5/5/2016	WS-004638	Cooler	3	In hallway adjacent to room 307 High	WT-042916-4655-A	< 1	WT-042916-4655-B	< 1			
14	DREW ES	5/5/2016	WS-004637	Classroom	3	In room 307	WT-042916-4654-A	< 1	WT-042916-4654-B	< 1			
15	DREW ES	5/5/2016	WS-004636	Classroom	3	In room 303	WT-042916-4653-A	< 1	WT-042916-4653-B	< 1			
16	DREW ES	5/5/2016	WS-004635	Classroom	3	In room 309	WT-042916-4652-A	1	WT-042916-4652-B	< 1			
17	DREW ES	5/5/2016	WS-004634	Classroom	3	In room 302	WT-042916-4651-A	< 1	WT-042916-4651-B	< 1			
18	DREW ES	5/5/2016	WS-004633	Classroom	3	In classroom 300 Left High	WT-042916-4650-A	< 1	WT-042916-4650-B	< 1			
19	DREW ES	5/5/2016	WS-004632	Fountain	3	In hallway adjacent to classroom 300 Right Low	WT-042916-4649-A	< 1	WT-042916-4649-B	< 1			
20	DREW ES	5/5/2016	WS-004631	Fountain	3	In hallway adjacent to classroom 300 Left High	WT-042916-4648-A	< 1	WT-042916-4648-B	< 1			
21	DREW ES	5/5/2016	WS-004630	Fountain	3	In room 312	WT-042916-4647-A	3	WT-042916-4647-B	< 1			
22	DREW ES	5/5/2016	WS-004629	Classroom	3	In room 312	WT-042916-4646-A	< 1	WT-042916-4646-B	< 1			
23	DREW ES	5/5/2016	WS-004628	Classroom	3	In classroom 313 Right Low	WT-042916-4645-A	70	WT-042916-4645-B	35	Filter will be installed and then retested		
24	DREW ES	5/5/2016	WS-004627	Fountain	2	In classroom 213 teacher lounge Mid	WT-042916-4644-A	< 1	WT-042916-4644-B	< 1			
25	DREW ES	5/5/2016	WS-004626	Break Room	2	In room 213 teacher lounge kitchenette Mid	WT-042916-4643-A	< 1	WT-042916-4643-B	< 1			
26	DREW ES	5/5/2016	WS-004625	Fountain	2	In hallway adjacent to classroom 200 Right Low	WT-042916-4642-A	< 1	WT-042916-4642-B	< 1			
27	DREW ES	5/5/2016	WS-004624	Fountain	2	In hallway adjacent to classroom 200 Left High	WT-042916-4641-A	< 1	WT-042916-4641-B	< 1			
28	DREW ES	5/5/2016	WS-004623	Fountain	2	In classroom 200 Right Low	WT-042916-4640-A	1	WT-042916-4640-B	< 1			
29	DREW ES	5/5/2016	WS-004622	Classroom	2	In classroom Left	WT-042916-4639-A	< 1	WT-042916-4639-B	< 1			
30	DREW ES	5/5/2016	WS-004621	Classroom	2	In classroom 202 Right	WT-042916-4638-A	< 1	WT-042916-4638-B	1			
31	DREW ES	5/5/2016	WS-004620	Fountain	2	In classroom 209 Right Low	WT-042916-4637-A	< 1	WT-042916-4637-B	< 1			
32	DREW ES	5/5/2016	WS-004619	Classroom	2	In classroom 209 Left High	WT-042916-4636-A	4	WT-042916-4636-B	1			
33	DREW ES	5/5/2016	WS-004618	Classroom	2	In classroom 204 Mid High	WT-042916-4635-A	< 1	WT-042916-4635-B	< 1			
34	DREW ES	5/6/2016	WS-004617	Cooler	2	In hallway across from room 204 Low	WT-042916-4634-A	< 1	WT-042916-4634-B	< 1			
35	DREW ES	5/6/2016	WS-004616	Cooler	2	In hallway across from room 204 High	WT-042916-4633-A	< 1	WT-042916-4633-B	< 1			
36	DREW ES	5/5/2016	WS-004615	Fountain	2	In classroom 207 Right Low	WT-042916-4632-A	< 1	WT-042916-4632-B	< 1			
37	DREW ES	5/5/2016	WS-004614	Classroom	2	In classroom 207 Left High	WT-042916-4631-A	< 1	WT-042916-4631-B	< 1			
38	DREW ES	5/5/2016	WS-004613	Fountain	2	In classroom 205 Right Low	WT-042916-4630-A	< 1	WT-042916-4630-B	< 1			
39	DREW ES	5/5/2016	WS-004612	Classroom	2	In classroom 205 Left High	WT-042916-4629-A	< 1	WT-042916-4629-B	< 1			
40	DREW ES	5/5/2016	WS-004611	Fountain	1	In room 106	WT-042916-4628-A	< 1	WT-042916-4628-B	< 1			
41	DREW ES	5/5/2016	WS-004610	Classroom	1	In room 106	WT-042916-4627-A	< 1	WT-042916-4627-B	< 1			
42	DREW ES	5/5/2016	WS-004609	Fountain	1	In classroom Right Low	WT-042916-4626-A	< 1	WT-042916-4626-B	< 1			
43	DREW ES	5/5/2016	WS-004608	Classroom	1	In classroom 107 Left High	WT-042916-4625-A	< 1	WT-042916-4625-B	< 1			
44	DREW ES	5/5/2016	WS-004607	Fountain	1	In hallway adjacent to room 107 Right Low	WT-042916-4624-A	< 1	WT-042916-4624-B	< 1			
45	DREW ES	5/5/2016	WS-004606	Fountain	1	In hallway adjacent to room 107 Left High	WT-042916-4623-A	< 1	WT-042916-4623-B	< 1			
46	DREW ES	5/5/2016	WS-004605	Fountain	1	In room 105	WT-042916-4622-A	< 1	WT-042916-4622-B	< 1			
47	DREW ES	5/5/2016	WS-004604	Classroom	1	In room 105	WT-042916-4621-A	< 1	WT-042916-4621-B	< 1			
48	DREW ES	5/5/2016	WS-004603	Fountain	1	In classroom 108 Right Low	WT-042916-4620-A	< 1	WT-042916-4620-B	< 1			
49	DREW ES	5/5/2016	WS-004602	Classroom	1	In classroom 108 Left High	WT-042916-4619-A	< 1	WT-042916-4619-B	< 1			
50	DREW ES	5/5/2016	WS-004601	Kitchen	1	In kitchen	WT-042916-4618-A	< 1	WT-042916-4618-B	< 1			
51	DREW ES	5/5/2016	WS-004600	Fountain	1	In room 104	WT-042916-4617-A	< 1	WT-042916-4617-B	< 1			
52	DREW ES	5/5/2016	WS-004599	Classroom	1	In room 104	WT-042916-4616-A	< 1	WT-042916-4616-B	< 1			



DREW LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
53 DREW ES	5/5/2016	WS- 004598	Health Suite	1	In health suite	WT-042916-4615- A	3	WT-042916-4615- B	4				
54 DREW ES	5/5/2016	WS- 004597	Cooler	1	In health suite	WT-042916-4614- A	< 1	WT-042916-4614- B	< 1				
55 DREW ES	5/5/2016	WS- 004596	Cooler	1	In hallway adjacent health suite	Low WT-042916-4613- A	< 1	WT-042916-4613- B	< 1				
56 DREW ES	5/5/2016	WS- 004595	Cooler	1	In hallway adjacent health suite	High WT-042916-4612- A	< 1	WT-042916-4612- B	< 1				
57 DREW ES	5/5/2016	WS- 004594	Cooler	1	In cafeteria	WT-042916-4611- A	< 1	WT-042916-4611- B	< 1				
58 DREW ES	5/5/2016	WS- 004593	Cooler	1	In auditorium	Low WT-042916-4610- A	< 1	WT-042916-4610- B	< 1				
59 DREW ES	5/5/2016	WS- 004592	Cooler	1	In auditorium	High WT-042916-4609- A	< 1	WT-042916-4609- B	< 1				
60 DREW ES	5/5/2016	WS- 004591	Utility	1	In boiler room main line	Mid Low WT-042916-4608- A	< 1	WT-042916-4608- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.