



DREW ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	DREW ELEMENTARY SCHOOL	WS-004626	12/11/2016	2	Break Room	In staff lounge 213	FT-102016-004626-A	< 1	FT-102016-004626-B	< 1
2	DREW ELEMENTARY SCHOOL	WS-004641	12/11/2016	4	Break Room	In staff lounge	FT-102016-004641-A	< 1	FT-102016-004641-B	< 1
3	DREW ELEMENTARY SCHOOL	WS-004646	12/11/2016	3	Break Room	In staff lounge	FT-102016-004646-A	< 1	FT-102016-004646-B	< 1
4	DREW ELEMENTARY SCHOOL	WS-004602	12/11/2016	1	Combo Faucet	In classroom 108 High Left	FT-122016-004602-A	< 1	FT-122016-004602-B	< 1
5	DREW ELEMENTARY SCHOOL	WS-004612	12/11/2016	2	Combo Faucet	In classroom 205 High Left	FT-112016-004612-A	< 1	FT-112016-004612-B	< 1
6	DREW ELEMENTARY SCHOOL	WS-004622	12/11/2016	2	Combo Faucet	In classroom 200 Left	FT-112016-004622-A	< 1	FT-112016-004622-B	< 1
7	DREW ELEMENTARY SCHOOL	WS-004629	12/11/2016	3	Combo Faucet	In classroom 312	FT-112016-004629-A	< 1	FT-112016-004629-B	< 1
8	DREW ELEMENTARY SCHOOL	WS-004608	12/11/2016	1	Combo Faucet	In classroom 107 High Left	FT-112016-004608-A	< 1	FT-112016-004608-B	< 1
9	DREW ELEMENTARY SCHOOL	WS-009118	12/11/2016	2	Combo Faucet	In classroom 212	FT-112016-009118-A	< 1	FT-112016-009118-B	< 1
10	DREW ELEMENTARY SCHOOL	WS-004604	12/11/2016	1	Combo Faucet	In classroom 105	FT-112016-004604-A	< 1	FT-112016-004604-B	< 1
11	DREW ELEMENTARY SCHOOL	WS-004599	12/11/2016	1	Combo Faucet	In classroom 104	FT-112016-004599-A	< 1	FT-112016-004599-B	< 1
Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	DREW ELEMENTARY SCHOOL	WS-004614	12/11/2016	2	Combo Faucet	In classroom 207 High Left	FT-112016-004614-A	1.5	FT-112016-004614-B	< 1
2	DREW ELEMENTARY SCHOOL	WS-004619	12/11/2016	2	Combo Faucet	In classroom 209 High Left	FT-112016-004619-A	2.2	FT-112016-004619-B	< 1
3	DREW ELEMENTARY SCHOOL	WS-004610	12/11/2016	1	Combo Faucet	In classroom 106	FT-112016-004610-A	1.9	FT-112016-004610-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	DREW ELEMENTARY SCHOOL	WS-004614	1/25/2017	2	Combo Faucet	In classroom 207 High Left	FT-112016-004614-A	1.8	FT-112016-004614-B	1.4
2	DREW ELEMENTARY SCHOOL	WS-004619	1/25/2017	2	Combo Faucet	In classroom 209 High Left	FT-112016-004619-A	2.1	FT-112016-004619-B	< 1
3	DREW ELEMENTARY SCHOOL	WS-004610	1/25/2017	1	Combo Faucet	In classroom 106	FT-112016-004610-A	2.4	FT-112016-004610-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	DREW ELEMENTARY SCHOOL	WS-004614	3/27/2017	2	Combo Faucet	In classroom 207 High Left	FT-112016-004614-A	2.5	FT-112016-004614-B	< 1
2	DREW ELEMENTARY SCHOOL	WS-004619	3/27/2017	2	Combo Faucet	In classroom 209 High Left	FT-112016-004619-A	3.5	FT-112016-004619-B	< 1
3	DREW ELEMENTARY SCHOOL	WS-004610	3/27/2017	1	Combo Faucet	In classroom 106	FT-112016-004610-A	5.9	FT-112016-004610-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb