



Drew ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004592	4/9/2018	4/9/2019	1	Cooler	In auditorium High Left	WF-04092018-004592	11/20/2018	FT-FY19-112018-004592-A	< 1	FT-FY19-112018-004592-B	< 1
WS- 004593	4/9/2018	4/9/2019	1	Cooler	In auditorium Low Right	WF-04092018-004593	11/20/2018	FT-FY19-112018-004593-A	< 1	FT-FY19-112018-004593-B	< 1
WS- 004594	4/9/2018	4/9/2019	1	Cooler	In cafeteria	WF-04092018-004594	11/20/2018	FT-FY19-112018-004594-A	< 1	FT-FY19-112018-004594-B	< 1
WS- 004595	4/9/2018	4/9/2019	1	Cooler	In hallway across from health suite High Left	WF-04092018-004595	11/20/2018	FT-FY19-112018-004595-A	< 1	FT-FY19-112018-004595-B	< 1
WS- 004596	4/9/2018	4/9/2019	1	Cooler	In hallway across from health suite Low Right	WF-04092018-004596	11/20/2018	FT-FY19-112018-004596-A	< 1	FT-FY19-112018-004596-B	< 1
WS- 004597	4/9/2018	4/9/2019	1	Cooler	In health suite	WF-04092018-004597	11/20/2018	FT-FY19-112018-004597-A	< 1	FT-FY19-112018-004597-B	< 1
WS- 004599	10/1/2018	10/1/2019	1	Combo Faucet	In classroom 104	WF-10012018-004599	11/20/2018	FT-FY19-112018-004599-A	< 1	FT-FY19-112018-004599-B	< 1
WS- 004600	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 104	WF-04092018-004600	11/20/2018	FT-FY19-112018-004600-A	< 1	FT-FY19-112018-004600-B	< 1
WS- 004602	10/1/2018	10/1/2019	1	Combo Faucet	In classroom 108 High Left	WF-10012018-004602	11/20/2018	FT-FY19-112018-004602-A	< 1	FT-FY19-112018-004602-B	< 1
WS- 004603	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 108 Low Right	WF-04092018-004603	11/20/2018	FT-FY19-112018-004603-A	< 1	FT-FY19-112018-004603-B	< 1
WS- 004604	10/1/2018	10/1/2019	1	Combo Faucet	In classroom 105	WF-10012018-004604	11/20/2018	FT-FY19-112018-004604-A	< 1	FT-FY19-112018-004604-B	< 1
WS- 004605	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 105	WF-04092018-004605	11/20/2018	FT-FY19-112018-004605-A	< 1	FT-FY19-112018-004605-B	< 1
WS- 004606	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to room 107 High Left	WF-04092018-004606	11/20/2018	FT-FY19-112018-004606-A	< 1	FT-FY19-112018-004606-B	< 1
WS- 004607	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to room 107 Low Right	WF-04092018-004607	11/20/2018	FT-FY19-112018-004607-A	< 1	FT-FY19-112018-004607-B	< 1
WS- 004608	10/1/2018	10/1/2019	1	Combo Faucet	In classroom 107 High Left	WF-10012018-004608	11/20/2018	FT-FY19-112018-004608-A	< 1	FT-FY19-112018-004608-B	< 1
WS- 004609	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 107 Low Right	WF-04092018-004609	11/20/2018	FT-FY19-112018-004609-A	< 1	FT-FY19-112018-004609-B	< 1
WS- 004610	10/1/2018	10/1/2019	1	Combo Faucet	In classroom 106	WF-10012018-004610	11/20/2018	FT-FY19-112018-004610-A	< 1	FT-FY19-112018-004610-B	< 1
WS- 004611	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 106	WF-04092018-004611	11/20/2018	FT-FY19-112018-004611-A	< 1	FT-FY19-112018-004611-B	< 1
WS- 004612	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 205 High Left	WF-10012018-004612	11/20/2018	FT-FY19-112018-004612-A	< 1	FT-FY19-112018-004612-B	< 1
WS- 004613	4/9/2018	4/9/2019	2	Combo Fountain	In classroom 205 Low Right	WF-04092018-004613	11/20/2018	FT-FY19-112018-004613-A	< 1	FT-FY19-112018-004613-B	< 1
WS- 004614	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 207 High Left	WF-10012018-004614	11/20/2018	FT-FY19-112018-004614-A	< 1	FT-FY19-112018-004614-B	< 1
WS- 004615	4/9/2018	4/9/2019	2	Combo Fountain	In classroom 207 Low Right	WF-04092018-004615	11/20/2018	FT-FY19-112018-004615-A	< 1	FT-FY19-112018-004615-B	< 1
WS- 004616	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to room 207 High Left	WF-04092018-004616	11/20/2018	FT-FY19-112018-004616-A	< 1	FT-FY19-112018-004616-B	< 1
WS- 004617	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to room 207 Low Right	WF-04092018-004617	11/20/2018	FT-FY19-112018-004617-A	< 1	FT-FY19-112018-004617-B	< 1
WS- 004619	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 209 High Left	WF-10012018-004619	11/20/2018	FT-FY19-112018-004619-A	< 1	FT-FY19-112018-004619-B	< 1
WS- 004620	4/9/2018	4/9/2019	2	Combo Fountain	In classroom 209 Low Right	WF-04092018-004620	11/20/2018	FT-FY19-112018-004620-A	< 1	FT-FY19-112018-004620-B	< 1
WS- 004622	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 200 Left	WF-10012018-004622	11/20/2018	FT-FY19-112018-004622-A	< 1	FT-FY19-112018-004622-B	< 1
WS- 004623	4/9/2018	4/9/2019	2	Combo Fountain	In classroom 200 Right	WF-04092018-004623	11/20/2018	FT-FY19-112018-004623-A	1.9	FT-FY19-112018-004623-B	< 1
WS- 004624	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to room 212 High Left	WF-04092018-004624	11/20/2018	FT-FY19-112018-004624-A	< 1	FT-FY19-112018-004624-B	< 1

WS- 004625	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to room 212	Low	Right	WF-04092018-004625	11/20/2018	FT-FY19-112018-004625-A	< 1	FT-FY19-112018-004625-B	< 1
WS- 004626	4/9/2018	4/9/2019	2	Break Room	In staff lounge 213			WF-04092018-004626	11/20/2018	FT-FY19-112018-004626-A	< 1	FT-FY19-112018-004626-B	< 1
WS- 004627	4/9/2018	4/9/2019	2	Cooler	In staff lounge 213			WF-04092018-004627	11/20/2018	FT-FY19-112018-004627-A	< 1	FT-FY19-112018-004627-B	< 1
WS- 004629	10/1/2018	10/1/2019	3	Combo Faucet	In classroom 312			WF-10012018-004629	11/20/2018	FT-FY19-112018-004629-A	< 1	FT-FY19-112018-004629-B	< 1
WS- 004630	4/9/2018	4/9/2019	3	Combo Fountain	In classroom 312			WF-04092018-004630	11/20/2018	FT-FY19-112018-004630-A	< 1	FT-FY19-112018-004630-B	< 1
WS- 004631	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 300	High	Left	WF-04092018-004631	11/20/2018	FT-FY19-112018-004631-A	< 1	FT-FY19-112018-004631-B	< 1
WS- 004632	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 300	Low	Right	WF-04092018-004632	11/20/2018	FT-FY19-112018-004632-A	< 1	FT-FY19-112018-004632-B	< 1
WS- 004638	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 307	High	Left	WF-04092018-004638	11/20/2018	FT-FY19-112018-004638-A	< 1	FT-FY19-112018-004638-B	< 1
WS- 004639	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 307	Low	Right	WF-04092018-004639	11/20/2018	FT-FY19-112018-004639-A	< 1	FT-FY19-112018-004639-B	< 1
WS- 004641	4/9/2018	4/9/2019	4	Break Room	In staff lounge			WF-04092018-004641	11/20/2018	FT-FY19-112018-004641-A	< 1	FT-FY19-112018-004641-B	< 1
WS- 004642	4/9/2018	4/9/2019	4	Cooler	In hallway adjacent to arts studio	High	Left	WF-04092018-004642	11/20/2018	FT-FY19-112018-004642-A	< 1	FT-FY19-112018-004642-B	< 1
WS- 004643	4/9/2018	4/9/2019	4	Cooler	In hallway adjacent to arts studio	Low	Right	WF-04092018-004643	11/20/2018	FT-FY19-112018-004643-A	< 1	FT-FY19-112018-004643-B	< 1
WS- 004644	4/9/2018	4/9/2019	4	Cooler	In hallway adjacent to room 407	High	Left	WF-04092018-004644	11/20/2018	FT-FY19-112018-004644-A	< 1	FT-FY19-112018-004644-B	< 1
WS- 004645	4/9/2018	4/9/2019	4	Cooler	In hallway adjacent to room 407	Low	Right	WF-04092018-004645	11/20/2018	FT-FY19-112018-004645-A	< 1	FT-FY19-112018-004645-B	< 1
WS- 004646	4/9/2018	4/9/2019	3	Break Room	In staff lounge			WF-04092018-004646	11/20/2018	FT-FY19-112018-004646-A	< 1	FT-FY19-112018-004646-B	< 1
WS- 004649	4/9/2018	4/9/2019	4	Bottle Filler	In hallway adjacent to arts studio			WF-04092018-004649	11/20/2018	FT-FY19-112018-004649-A	< 1	FT-FY19-112018-004649-B	< 1
WS- 009118	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 212			WF-10012018-009118	11/20/2018	FT-FY19-112018-009118-A	< 1	FT-FY19-112018-009118-B	< 1
WS- 009119	4/9/2018	4/9/2019	2	Combo Fountain	In classroom 212			WF-04092018-009119	11/20/2018	FT-FY19-112018-009119-A	< 1	FT-FY19-112018-009119-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004601	1	Food Prep Sink	In kitchen	11/20/2018	FT-FY19-112018-004601-A	< 1	FT-FY19-112018-004601-B	< 1	