



Duke Ellington High School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009191	4/26/2022	4/26/2023	1	Cooler	In hallway across from electrical room 124a	WF-04262022-009191	2/15/2023	FT-FY23-01262023-009191-A	<1	FT-FY23-01262023-009191-B	<1
WS- 009192	4/26/2022	4/26/2023	1	Cooler	In hallway across from electrical room 124a	WF-04262022-009192	2/15/2023	FT-FY23-01262023-009192-A	<1	FT-FY23-01262023-009192-B	<1
WS- 009402	4/26/2022	4/26/2023	Ground Floor	Cooler	In hallway adjacent to room G32A	WF-04262022-009402	2/15/2023	FT-FY23-01262023-009402-A	<1	FT-FY23-01262023-009402-B	<1
WS- 009403	4/26/2022	4/26/2023	Ground Floor	Cooler	In hallway adjacent to room G32A	WF-04262022-009403	2/15/2023	FT-FY23-01262023-009403-A	<1	FT-FY23-01262023-009403-B	<1
WS- 009404	4/26/2022	4/26/2023	Ground Floor	Cooler	In hallway across from room G60	WF-04262022-009404	2/15/2023	FT-FY23-01262023-009404-A	<1	FT-FY23-01262023-009404-B	<1
WS- 009405	4/26/2022	4/26/2023	Ground Floor	Cooler	In hallway across from room G60	WF-04262022-009405	2/15/2023	FT-FY23-01262023-009405-A	<1	FT-FY23-01262023-009405-B	<1
WS- 009406	4/26/2022	4/26/2023	Ground Floor	Cooler	In cafeteria	WF-04262022-009406	2/15/2023	FT-FY23-01262023-009406-A	<1	FT-FY23-01262023-009406-B	<1
WS- 009407	4/26/2022	4/26/2023	Ground Floor	Cooler	In cafeteria	WF-04262022-009407	2/15/2023	FT-FY23-01262023-009407-A	<1	FT-FY23-01262023-009407-B	<1
WS- 009417	4/26/2022	4/26/2023	Ground Floor	Cooler	In hallway adjacent to workroom G08	WF-04262022-009417	2/15/2023	FT-FY23-01262023-009417-A	<1	FT-FY23-01262023-009417-B	<1
WS- 009418	4/26/2022	4/26/2023	Ground Floor	Cooler	In hallway adjacent to workroom G08	WF-04262022-009418	2/15/2023	FT-FY23-01262023-009418-A	<1	FT-FY23-01262023-009418-B	<1
WS- 009419	4/26/2022	4/26/2023	Ground Floor	Health Suite	In health suite in alcove G16	WF-04262022-009419	2/15/2023	FT-FY23-01262023-009419-A	<1	FT-FY23-01262023-009419-B	<1
WS- 009420	4/26/2022	4/26/2023	Ground Floor	Health Suite	In health suite in health lab room G24	WF-04262022-009420	2/15/2023	FT-FY23-01262023-009420-A	<1	FT-FY23-01262023-009420-B	<1
WS- 009421	4/26/2022	4/26/2023	Ground Floor	Health Suite	In health suite in treatment room G18	WF-04262022-009421	2/15/2023	FT-FY23-01262023-009421-A	<1	FT-FY23-01262023-009421-B	<1
WS- 009422	4/26/2022	4/26/2023	Ground Floor	Cooler	In fitness center room G26	WF-04262022-009422	2/15/2023	FT-FY23-01262023-009422-A	<1	FT-FY23-01262023-009422-B	<1
WS- 009423	4/26/2022	4/26/2023	Ground Floor	Cooler	In fitness center room G26	WF-04262022-009423	2/15/2023	FT-FY23-01262023-009423-A	<1	FT-FY23-01262023-009423-B	<1
WS- 009424	4/26/2022	4/26/2023	1	Cooler	In hallway adjacent to storage room 131	WF-04262022-009424	2/15/2023	FT-FY23-01262023-009424-A	<1	FT-FY23-01262023-009424-B	<1
WS- 009425	4/26/2022	4/26/2023	1	Cooler	In hallway adjacent to storage room 131	WF-04262022-009425	2/15/2023	FT-FY23-01262023-009425-A	<1	FT-FY23-01262023-009425-B	<1
WS- 009427	4/26/2022	4/26/2023	1	Combo Fountain	In classroom 135	WF-04262022-009427	2/15/2023	FT-FY23-01262023-009427-A	<1	FT-FY23-01262023-009427-B	<1
WS- 009429	4/26/2022	4/26/2023	1	Combo Fountain	In office room 136	WF-04262022-009429	2/15/2023	FT-FY23-01262023-009429-A	<1	FT-FY23-01262023-009429-B	<1
WS- 009430	4/26/2022	4/26/2023	1	Cooler	In hallway adjacent to storage room 155	WF-04262022-009430	2/15/2023	FT-FY23-01262023-009430-A	<1	FT-FY23-01262023-009430-B	<1
WS- 009431	4/26/2022	4/26/2023	1	Cooler	In hallway adjacent to storage room 155	WF-04262022-009431	2/15/2023	FT-FY23-01262023-009431-A	<1	FT-FY23-01262023-009431-B	<1
WS- 009440	4/26/2022	4/26/2023	1	Cooler	In hallway adjacent to custodial room 123	WF-04262022-009440	2/15/2023	FT-FY23-01262023-009440-A	<1	FT-FY23-01262023-009440-B	<1
WS- 009441	4/26/2022	4/26/2023	1	Cooler	In hallway adjacent to custodial room 123	WF-04262022-009441	2/15/2023	FT-FY23-01262023-009441-A	<1	FT-FY23-01262023-009441-B	<1
WS- 009444	4/26/2022	4/26/2023	1	Break Room	In workroom 108	WF-04262022-009444	2/15/2023	FT-FY23-01262023-009444-A	<1	FT-FY23-01262023-009444-B	<1
WS- 009446	4/26/2022	4/26/2023	1	Break Room	In main office across from office room 119	WF-04262022-009446	2/15/2023	FT-FY23-01262023-009446-A	<1	FT-FY23-01262023-009446-B	<1
WS- 009448	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to dance studio 218	WF-04262022-009448	2/15/2023	FT-FY23-01262023-009448-A	<1	FT-FY23-01262023-009448-B	<1
WS- 009449	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to dance studio 225	WF-04262022-009449	2/15/2023	FT-FY23-01262023-009449-A	<1	FT-FY23-01262023-009449-B	<1
WS- 009450	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to dance studio 225	WF-04262022-009450	2/15/2023	FT-FY23-01262023-009450-A	<1	FT-FY23-01262023-009450-B	<1
WS- 009452	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to dance studio 232	WF-04262022-009452	2/15/2023	FT-FY23-01262023-009452-A	<1	FT-FY23-01262023-009452-B	<1
WS- 009453	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to dance studio 232	WF-04262022-009453	2/15/2023	FT-FY23-01262023-009453-A	<1	FT-FY23-01262023-009453-B	<1
WS- 009455	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to LMC studio 245	WF-04262022-009455	2/15/2023	FT-FY23-01262023-009455-A	<1	FT-FY23-01262023-009455-B	<1
WS- 009458	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to classroom 265	WF-04262022-009458	2/15/2023	FT-FY23-01262023-009458-A	<1	FT-FY23-01262023-009458-B	<1
WS- 009459	4/26/2022	4/26/2023	2	Break Room	In workroom 206	WF-04262022-009459	2/15/2023	FT-FY23-01262023-009459-A	<1	FT-FY23-01262023-009459-B	<1
WS- 009460	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to classroom 209	WF-04262022-009460	2/15/2023	FT-FY23-01262023-009460-A	<1	FT-FY23-01262023-009460-B	<1
WS- 009461	4/26/2022	4/26/2023	2	Cooler	In hallway adjacent to classroom 209	WF-04262022-009461	2/15/2023	FT-FY23-01262023-009461-A	<1	FT-FY23-01262023-009461-B	<1

WS- 009463	4/26/2022	4/26/2023	3	Cooler	In hallway adjacent to instrumental studio 313	High	Left	WF-04262022-009463	2/15/2023	FT-FY23-01262023-009463-A	<1	FT-FY23-01262023-009463-B	<1
WS- 009464	4/26/2022	4/26/2023	3	Cooler	In hallway adjacent to instrumental studio 313	Low	Right	WF-04262022-009464	2/15/2023	FT-FY23-01262023-009464-A	<1	FT-FY23-01262023-009464-B	<1
WS- 009468	4/26/2022	4/26/2023	3	Cooler	In orchestra rehearsal room 363			WF-04262022-009468	2/15/2023	FT-FY23-01262023-009468-A	<1	FT-FY23-01262023-009468-B	<1
WS- 009471	4/26/2022	4/26/2023	3	Cooler	In hallway adjacent to classroom 304	High	Left	WF-04262022-009471	2/15/2023	FT-FY23-01262023-009471-A	<1	FT-FY23-01262023-009471-B	<1
WS- 009472	4/26/2022	4/26/2023	3	Cooler	In hallway adjacent to classroom 304	Low	Right	WF-04262022-009472	2/15/2023	FT-FY23-01262023-009472-A	<1	FT-FY23-01262023-009472-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009408	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	WF-12202022-009408	2/15/2023	FT-FY23-01262023-009408-A	<1	FT-FY23-01262023-009408-B	<1
WS- 009409	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	WF-12202022-009409	2/15/2023	FT-FY23-01262023-009409-A	<1	FT-FY23-01262023-009409-B	<1
WS- 009410	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door	WF-12202022-009410	2/15/2023	FT-FY23-01262023-009410-A	<1	FT-FY23-01262023-009410-B	<1