



Duke Ellington HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009191	6/11/2019	6/11/2020	1	Cooler	In hallway across from electrical room 124a	Low Right	WF-06112019-009191	1/14/2020	FT-FY20-122019-009191-A	<1	FT-FY20-122019-009191-B	<1
WS-009192	6/11/2019	6/11/2020	1	Cooler	In hallway across from electrical room 124a	High Left	WF-06112019-009192	1/14/2020	FT-FY20-122019-009192-A	<1	FT-FY20-122019-009192-B	<1
WS-009402	6/11/2019	6/11/2020	Ground Floor	Cooler	In hallway adjacent to room G32A	High Left	WF-06112019-009402	1/14/2020	FT-FY20-122019-009402-A	<1	FT-FY20-122019-009402-B	<1
WS-009403	6/11/2019	6/11/2020	Ground Floor	Cooler	In hallway adjacent to room G32A	Low Right	WF-06112019-009403	1/14/2020	FT-FY20-122019-009403-A	<1	FT-FY20-122019-009403-B	<1
WS-009404	6/11/2019	6/11/2020	Ground Floor	Cooler	In hallway across from room G60	High Left	WF-06112019-009404	1/14/2020	FT-FY20-122019-009404-A	<1	FT-FY20-122019-009404-B	<1
WS-009405	6/11/2019	6/11/2020	Ground Floor	Cooler	In hallway across from room G60	Low Right	WF-06112019-009405	1/14/2020	FT-FY20-122019-009405-A	<1	FT-FY20-122019-009405-B	<1
WS-009406	6/11/2019	6/11/2020	Ground Floor	Cooler	In cafeteria	High Left	WF-06112019-009406	1/14/2020	FT-FY20-122019-009406-A	<1	FT-FY20-122019-009406-B	<1
WS-009407	6/11/2019	6/11/2020	Ground Floor	Cooler	In cafeteria	Low Right	WF-06112019-009407	1/14/2020	FT-FY20-122019-009407-A	<1	FT-FY20-122019-009407-B	<1
WS-009417	6/11/2019	6/11/2020	Ground Floor	Cooler	In hallway adjacent to workroom G08	High Left	WF-06112019-009417	1/14/2020	FT-FY20-122019-009417-A	<1	FT-FY20-122019-009417-B	<1
WS-009418	6/11/2019	6/11/2020	Ground Floor	Cooler	In hallway adjacent to workroom G08	Low Right	WF-06112019-009418	1/14/2020	FT-FY20-122019-009418-A	<1	FT-FY20-122019-009418-B	<1
WS-009419	6/11/2019	6/11/2020	Ground Floor	Health Suite	In health suite in alcove G16		WF-06112019-009419	1/14/2020	FT-FY20-122019-009419-A	<1	FT-FY20-122019-009419-B	<1
WS-009420	6/11/2019	6/11/2020	Ground Floor	Health Suite	In health suite in health lab room G24		WF-06112019-009420	1/14/2020	FT-FY20-122019-009420-A	<1	FT-FY20-122019-009420-B	<1
WS-009421	6/11/2019	6/11/2020	Ground Floor	Health Suite	In health suite in treatment room G18		WF-06112019-009421	1/14/2020	FT-FY20-122019-009421-A	<1	FT-FY20-122019-009421-B	<1
WS-009422	6/11/2019	6/11/2020	Ground Floor	Cooler	In fitness center room G26	High Left	WF-06112019-009422	1/14/2020	FT-FY20-122019-009422-A	<1	FT-FY20-122019-009422-B	<1
WS-009423	6/11/2019	6/11/2020	Ground Floor	Cooler	In fitness center room G26	Low Right	WF-06112019-009423	1/14/2020	FT-FY20-122019-009423-A	<1	FT-FY20-122019-009423-B	<1
WS-009424	6/11/2019	6/11/2020	1	Cooler	In hallway adjacent to storage room 131	High Left	WF-06112019-009424	1/14/2020	FT-FY20-122019-009424-A	<1	FT-FY20-122019-009424-B	<1
WS-009425	6/11/2019	6/11/2020	1	Cooler	In hallway adjacent to storage room 131	Low Right	WF-06112019-009425	1/14/2020	FT-FY20-122019-009425-A	<1	FT-FY20-122019-009425-B	<1
WS-009427	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 135		WF-06112019-009427	1/14/2020	FT-FY20-122019-009427-A	<1	FT-FY20-122019-009427-B	<1
WS-009429	6/11/2019	6/11/2020	1	Combo Fountain	In office room 136		WF-06112019-009429	1/14/2020	FT-FY20-122019-009429-A	<1	FT-FY20-122019-009429-B	<1
WS-009430	6/11/2019	6/11/2020	1	Cooler	In hallway adjacent to storage room 155	High Left	WF-06112019-009430	1/14/2020	FT-FY20-122019-009430-A	<1	FT-FY20-122019-009430-B	<1
WS-009431	6/11/2019	6/11/2020	1	Cooler	In hallway adjacent to storage room 155	Low Right	WF-06112019-009431	1/14/2020	FT-FY20-122019-009431-A	<1	FT-FY20-122019-009431-B	<1
WS-009440	6/11/2019	6/11/2020	1	Cooler	In hallway adjacent to custodial room 123	High Left	WF-06112019-009440	1/14/2020	FT-FY20-122019-009440-A	<1	FT-FY20-122019-009440-B	<1
WS-009441	6/11/2019	6/11/2020	1	Cooler	In hallway adjacent to custodial room 123	Low Right	WF-06112019-009441	1/14/2020	FT-FY20-122019-009441-A	<1	FT-FY20-122019-009441-B	<1
WS-009444	6/11/2019	6/11/2020	1	Break Room	In workroom 108		WF-06112019-009444	1/14/2020	FT-FY20-122019-009444-A	<1	FT-FY20-122019-009444-B	<1
WS-009446	6/11/2019	6/11/2020	1	Break Room	In main office across from office room 119		WF-06112019-009446	1/14/2020	FT-FY20-122019-009446-A	<1	FT-FY20-122019-009446-B	<1
WS-009447	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to dance studio 218	High Left	WF-06112019-009447	1/14/2020	FT-FY20-122019-009447-A	<1	FT-FY20-122019-009447-B	<1
WS-009448	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to dance studio 218	Low Right	WF-06112019-009448	1/14/2020	FT-FY20-122019-009448-A	<1	FT-FY20-122019-009448-B	<1
WS-009449	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to dance studio 225	High Left	WF-06112019-009449	1/14/2020	FT-FY20-122019-009449-A	<1	FT-FY20-122019-009449-B	<1
WS-009450	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to dance studio 225	Low Right	WF-06112019-009450	1/14/2020	FT-FY20-122019-009450-A	<1	FT-FY20-122019-009450-B	<1
WS-009452	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to dance studio 232	High Left	WF-06112019-009452	1/14/2020	FT-FY20-122019-009452-A	<1	FT-FY20-122019-009452-B	<1
WS-009453	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to dance studio 232	Low Right	WF-06112019-009453	1/14/2020	FT-FY20-122019-009453-A	<1	FT-FY20-122019-009453-B	<1
WS-009455	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to LMC studio 245	High Left	WF-06112019-009455	1/14/2020	FT-FY20-122019-009455-A	<1	FT-FY20-122019-009455-B	<1
WS-009456	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to LMC studio 245	Low Right	WF-06112019-009456	1/14/2020	FT-FY20-122019-009456-A	<1	FT-FY20-122019-009456-B	<1
WS-009457	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to classroom 265	High Left	WF-06112019-009457	1/14/2020	FT-FY20-122019-009457-A	<1	FT-FY20-122019-009457-B	<1
WS-009458	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to classroom 265	Low Right	WF-06112019-009458	1/14/2020	FT-FY20-122019-009458-A	<1	FT-FY20-122019-009458-B	<1

WS- 009459	6/11/2019	6/11/2020	2	Break Room	In workroom 206			WF-06112019-009459	1/14/2020	FT-FY20-122019-009459-A	<1	FT-FY20-122019-009459-B	<1
WS- 009460	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to classroom 209	High	Left	WF-06112019-009460	1/14/2020	FT-FY20-122019-009460-A	<1	FT-FY20-122019-009460-B	<1
WS- 009461	6/11/2019	6/11/2020	2	Cooler	In hallway adjacent to classroom 209	Low	Right	WF-06112019-009461	1/14/2020	FT-FY20-122019-009461-A	<1	FT-FY20-122019-009461-B	<1
WS- 009462	6/11/2019	6/11/2020	3	Cooler	In instrumental studio room 313			WF-06112019-009462	1/14/2020	FT-FY20-122019-009462-A	<1	FT-FY20-122019-009462-B	<1
WS- 009463	6/11/2019	6/11/2020	3	Cooler	In hallway adjacent to instrumental studio 313	High	Left	WF-06112019-009463	1/14/2020	FT-FY20-122019-009463-A	<1	FT-FY20-122019-009463-B	<1
WS- 009464	6/11/2019	6/11/2020	3	Cooler	In hallway adjacent to instrumental studio 313	Low	Right	WF-06112019-009464	1/14/2020	FT-FY20-122019-009464-A	<1	FT-FY20-122019-009464-B	<1
WS- 009465	6/11/2019	6/11/2020	3	Cooler	In hallway adjacent to classroom 353	High	Left	WF-06112019-009465	1/14/2020	FT-FY20-122019-009465-A	<1	FT-FY20-122019-009465-B	<1
WS- 009466	6/11/2019	6/11/2020	3	Cooler	In hallway adjacent to classroom 353	Low	Right	WF-06112019-009466	1/14/2020	FT-FY20-122019-009466-A	<1	FT-FY20-122019-009466-B	<1
WS- 009468	6/11/2019	6/11/2020	3	Cooler	In orchestra rehearsal room 363			WF-06112019-009468	1/14/2020	FT-FY20-122019-009468-A	<1	FT-FY20-122019-009468-B	<1
WS- 009469	6/11/2019	6/11/2020	3	Cooler	In hallway adjacent to classroom 372	High	Left	WF-06112019-009469	1/14/2020	FT-FY20-122019-009469-A	<1	FT-FY20-122019-009469-B	<1
WS- 009470	6/11/2019	6/11/2020	3	Cooler	In hallway adjacent to classroom 372	Low	Right	WF-06112019-009470	1/14/2020	FT-FY20-122019-009470-A	<1	FT-FY20-122019-009470-B	<1
WS- 009471	6/11/2019	6/11/2020	3	Cooler	In hallway adjacent to classroom 304	High	Left	WF-06112019-009471	1/14/2020	FT-FY20-122019-009471-A	<1	FT-FY20-122019-009471-B	<1
WS- 009472	6/11/2019	6/11/2020	3	Cooler	In hallway adjacent to classroom 304	Low	Right	WF-06112019-009472	1/14/2020	FT-FY20-122019-009472-A	<1	FT-FY20-122019-009472-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009408	7/18/2019	7/18/2020	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	WF-07182019-009408	1/14/2020	FT-FY20-122019-009408-A	<1	FT-FY20-122019-009408-B	<1
WS- 009409	7/18/2019	7/18/2020	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	WF-07182019-009409	1/14/2020	FT-FY20-122019-009409-A	<1	FT-FY20-122019-009409-B	<1
WS- 009410	7/18/2019	7/18/2020	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door	WF-07182019-009410	1/14/2020	FT-FY20-122019-009410-A	<1	FT-FY20-122019-009410-B	<1