



# Duke Ellington High School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009191	6/3/2020	6/3/2021	1	Cooler	In hallway across from electrical room 124a	Low Right	WF-06032020-009191	4/4/2021	FT-FY21-032021-009191-A	<1	FT-FY21-032021-009191-B	<1
WS- 009192	6/3/2020	6/3/2021	1	Cooler	In hallway across from electrical room 124a	High Left	WF-06032020-009192	4/4/2021	FT-FY21-032021-009192-A	<1	FT-FY21-032021-009192-B	<1
WS- 009402	6/3/2020	6/3/2021	Ground Floor	Cooler	In hallway adjacent to room G32A	High Left	WF-06032020-009402	4/4/2021	FT-FY21-032021-009402-A	<1	FT-FY21-032021-009402-B	<1
WS- 009403	6/3/2020	6/3/2021	Ground Floor	Cooler	In hallway adjacent to room G32A	Low Right	WF-06032020-009403	4/4/2021	FT-FY21-032021-009403-A	<1	FT-FY21-032021-009403-B	<1
WS- 009404	6/3/2020	6/3/2021	Ground Floor	Cooler	In hallway across from room G60	High Left	WF-06032020-009404	4/4/2021	FT-FY21-032021-009404-A	<1	FT-FY21-032021-009404-B	<1
WS- 009405	6/3/2020	6/3/2021	Ground Floor	Cooler	In hallway across from room G60	Low Right	WF-06032020-009405	4/4/2021	FT-FY21-032021-009405-A	<1	FT-FY21-032021-009405-B	<1
WS- 009406	6/3/2020	6/3/2021	Ground Floor	Cooler	In cafeteria	High Left	WF-06032020-009406	4/4/2021	FT-FY21-032021-009406-A	<1	FT-FY21-032021-009406-B	<1
WS- 009407	6/3/2020	6/3/2021	Ground Floor	Cooler	In cafeteria	Low Right	WF-06032020-009407	4/4/2021	FT-FY21-032021-009407-A	<1	FT-FY21-032021-009407-B	<1
WS- 009417	6/3/2020	6/3/2021	Ground Floor	Cooler	In hallway adjacent to workroom G08	High Left	WF-06032020-009417	4/4/2021	FT-FY21-032021-009417-A	<1	FT-FY21-032021-009417-B	<1
WS- 009418	6/3/2020	6/3/2021	Ground Floor	Cooler	In hallway adjacent to workroom G08	Low Right	WF-06032020-009418	4/4/2021	FT-FY21-032021-009418-A	<1	FT-FY21-032021-009418-B	<1
WS- 009419	6/3/2020	6/3/2021	Ground Floor	Health Suite	In health suite in alcove G16		WF-06032020-009419	4/4/2021	FT-FY21-032021-009419-A	<1	FT-FY21-032021-009419-B	<1
WS- 009420	6/3/2020	6/3/2021	Ground Floor	Health Suite	In health suite in health lab room G24		WF-06032020-009420	4/4/2021	FT-FY21-032021-009420-A	<1	FT-FY21-032021-009420-B	<1
WS- 009421	6/3/2020	6/3/2021	Ground Floor	Health Suite	In health suite in treatment room G18		WF-06032020-009421	4/4/2021	FT-FY21-032021-009421-A	<1	FT-FY21-032021-009421-B	<1
WS- 009422	6/3/2020	6/3/2021	Ground Floor	Cooler	In fitness center room G26	High Left	WF-06032020-009422	4/4/2021	FT-FY21-032021-009422-A	<1	FT-FY21-032021-009422-B	<1
WS- 009423	6/3/2020	6/3/2021	Ground Floor	Cooler	In fitness center room G26	Low Right	WF-06032020-009423	4/4/2021	FT-FY21-032021-009423-A	<1	FT-FY21-032021-009423-B	<1
WS- 009424	6/3/2020	6/3/2021	1	Cooler	In hallway adjacent to storage room 131	High Left	WF-06032020-009424	4/4/2021	FT-FY21-032021-009424-A	<1	FT-FY21-032021-009424-B	<1
WS- 009425	6/3/2020	6/3/2021	1	Cooler	In hallway adjacent to storage room 131	Low Right	WF-06032020-009425	4/4/2021	FT-FY21-032021-009425-A	<1	FT-FY21-032021-009425-B	<1
WS- 009427	6/3/2020	6/3/2021	1	Combo Fountain	In classroom 135		WF-06032020-009427	4/4/2021	FT-FY21-032021-009427-A	<1	FT-FY21-032021-009427-B	<1
WS- 009429	6/3/2020	6/3/2021	1	Combo Fountain	In office room 136		WF-06032020-009429	4/4/2021	FT-FY21-032021-009429-A	<1	FT-FY21-032021-009429-B	<1
WS- 009430	6/3/2020	6/3/2021	1	Cooler	In hallway adjacent to storage room 155	High Left	WF-06032020-009430	4/4/2021	FT-FY21-032021-009430-A	<1	FT-FY21-032021-009430-B	<1
WS- 009431	6/3/2020	6/3/2021	1	Cooler	In hallway adjacent to storage room 155	Low Right	WF-06032020-009431	4/4/2021	FT-FY21-032021-009431-A	<1	FT-FY21-032021-009431-B	<1
WS- 009440	6/3/2020	6/3/2021	1	Cooler	In hallway adjacent to custodial room 123	High Left	WF-06032020-009440	4/4/2021	FT-FY21-032021-009440-A	<1	FT-FY21-032021-009440-B	<1
WS- 009441	6/3/2020	6/3/2021	1	Cooler	In hallway adjacent to custodial room 123	Low Right	WF-06032020-009441	4/4/2021	FT-FY21-032021-009441-A	<1	FT-FY21-032021-009441-B	<1
WS- 009444	6/3/2020	6/3/2021	1	Break Room	In workroom 108		WF-06032020-009444	4/4/2021	FT-FY21-032021-009444-A	<1	FT-FY21-032021-009444-B	<1
WS- 009446	6/3/2020	6/3/2021	1	Break Room	In main office across from office room 119		WF-06032020-009446	4/4/2021	FT-FY21-032021-009446-A	<1	FT-FY21-032021-009446-B	<1
WS- 009447	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to dance studio 218	High Left	WF-06032020-009447	4/4/2021	FT-FY21-032021-009447-A	<1	FT-FY21-032021-009447-B	<1
WS- 009448	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to dance studio 218	Low Right	WF-06032020-009448	4/4/2021	FT-FY21-032021-009448-A	<1	FT-FY21-032021-009448-B	<1
WS- 009449	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to dance studio 225	High Left	WF-06032020-009449	4/4/2021	FT-FY21-032021-009449-A	<1	FT-FY21-032021-009449-B	<1
WS- 009450	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to dance studio 225	Low Right	WF-06032020-009450	4/4/2021	FT-FY21-032021-009450-A	<1	FT-FY21-032021-009450-B	<1
WS- 009452	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to dance studio 232	High Left	WF-06032020-009452	4/4/2021	FT-FY21-032021-009452-A	<1	FT-FY21-032021-009452-B	<1
WS- 009453	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to dance studio 232	Low Right	WF-06032020-009453	4/4/2021	FT-FY21-032021-009453-A	<1	FT-FY21-032021-009453-B	<1
WS- 009455	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to LMC studio 245	High Left	WF-06032020-009455	4/4/2021	FT-FY21-032021-009455-A	<1	FT-FY21-032021-009455-B	<1
WS- 009456	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to LMC studio 245	Low Right	WF-06032020-009456	4/4/2021	FT-FY21-032021-009456-A	<1	FT-FY21-032021-009456-B	<1
WS- 009457	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to classroom 265	High Left	WF-06032020-009457	4/4/2021	FT-FY21-032021-009457-A	<1	FT-FY21-032021-009457-B	<1

WS- 009458	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to classroom 265	Low	Right	WF-06032020-009458	4/4/2021	FT-FY21-032021-009458-A	<1	FT-FY21-032021-009458-B	<1
WS- 009459	6/3/2020	6/3/2021	2	Break Room	In workroom 206			WF-06032020-009459	4/4/2021	FT-FY21-032021-009459-A	<1	FT-FY21-032021-009459-B	<1
WS- 009460	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to classroom 209	High	Left	WF-06032020-009460	4/4/2021	FT-FY21-032021-009460-A	<1	FT-FY21-032021-009460-B	<1
WS- 009461	6/3/2020	6/3/2021	2	Cooler	In hallway adjacent to classroom 209	Low	Right	WF-06032020-009461	4/4/2021	FT-FY21-032021-009461-A	<1	FT-FY21-032021-009461-B	<1
WS- 009463	6/3/2020	6/3/2021	3	Cooler	In hallway adjacent to instrumental studio 313	High	Left	WF-06032020-009463	4/4/2021	FT-FY21-032021-009463-A	<1	FT-FY21-032021-009463-B	<1
WS- 009464	6/3/2020	6/3/2021	3	Cooler	In hallway adjacent to instrumental studio 313	Low	Right	WF-06032020-009464	4/4/2021	FT-FY21-032021-009464-A	<1	FT-FY21-032021-009464-B	<1
WS- 009465	6/3/2020	6/3/2021	3	Cooler	In hallway adjacent to classroom 353	High	Left	WF-06032020-009465	4/4/2021	FT-FY21-032021-009465-A	<1	FT-FY21-032021-009465-B	<1
WS- 009466	6/3/2020	6/3/2021	3	Cooler	In hallway adjacent to classroom 353	Low	Right	WF-06032020-009466	4/4/2021	FT-FY21-032021-009466-A	<1	FT-FY21-032021-009466-B	<1
WS- 009468	6/3/2020	6/3/2021	3	Cooler	In orchestra rehearsal room 363			WF-06032020-009468	4/4/2021	FT-FY21-032021-009468-A	<1	FT-FY21-032021-009468-B	<1
WS- 009469	6/3/2020	6/3/2021	3	Cooler	In hallway adjacent to classroom 372	High	Left	WF-06032020-009469	4/4/2021	FT-FY21-032021-009469-A	<1	FT-FY21-032021-009469-B	<1
WS- 009470	6/3/2020	6/3/2021	3	Cooler	In hallway adjacent to classroom 372	Low	Right	WF-06032020-009470	4/4/2021	FT-FY21-032021-009470-A	<1	FT-FY21-032021-009470-B	<1
WS- 009471	6/3/2020	6/3/2021	3	Cooler	In hallway adjacent to classroom 304	High	Left	WF-06032020-009471	4/4/2021	FT-FY21-032021-009471-A	<1	FT-FY21-032021-009471-B	<1
WS- 009472	6/3/2020	6/3/2021	3	Cooler	In hallway adjacent to classroom 304	Low	Right	WF-06032020-009472	4/4/2021	FT-FY21-032021-009472-A	<1	FT-FY21-032021-009472-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009408	1/13/2021	1/13/2022	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	WF-01132021-009408	4/4/2021	FT-FY21-032021-009408-A	<1	FT-FY21-032021-009408-B	<1	
WS- 009409	1/13/2021	1/13/2022	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	WF-01132021-009409	4/4/2021	FT-FY21-032021-009409-A	<1	FT-FY21-032021-009409-B	<1	
WS- 009410	1/13/2021	1/13/2022	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door	WF-01132021-009410	4/4/2021	FT-FY21-032021-009410-A	<1	FT-FY21-032021-009410-B	<1	