



# Duke Ellington High School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009191	4/18/2023	4/18/2024	1	Cooler	In hallway across from electrical room 124a	Low	Right	WF-04182023-009191	11/13/2023	FT-FY24-10102023-009191-A	<1	FT-FY24-10102023-009191-B	<1
WS- 009192	4/18/2023	4/18/2024	1	Cooler	In hallway across from electrical room 124a	High	Left	WF-04182023-009192	11/13/2023	FT-FY24-10102023-009192-A	<1	FT-FY24-10102023-009192-B	<1
WS- 009402	4/18/2023	4/18/2024	Ground Floor	Cooler	In hallway adjacent to room G32A	High	Left	WF-04182023-009402	11/13/2023	FT-FY24-10102023-009402-A	<1	FT-FY24-10102023-009402-B	<1
WS- 009403	4/18/2023	4/18/2024	Ground Floor	Cooler	In hallway adjacent to room G32A	Low	Right	WF-04182023-009403	11/13/2023	FT-FY24-10102023-009403-A	<1	FT-FY24-10102023-009403-B	<1
WS- 009404	4/18/2023	4/18/2024	Ground Floor	Cooler	In hallway across from room G60	High	Left	WF-04182023-009404	11/13/2023	FT-FY24-10102023-009404-A	<1	FT-FY24-10102023-009404-B	<1
WS- 009405	4/18/2023	4/18/2024	Ground Floor	Cooler	In hallway across from room G60	Low	Right	WF-04182023-009405	11/13/2023	FT-FY24-10102023-009405-A	<1	FT-FY24-10102023-009405-B	<1
WS- 009406	4/18/2023	4/18/2024	Ground Floor	Cooler	In cafeteria	High	Left	WF-04182023-009406	11/13/2023	FT-FY24-10102023-009406-A	<1	FT-FY24-10102023-009406-B	<1
WS- 009407	4/18/2023	4/18/2024	Ground Floor	Cooler	In cafeteria	Low	Right	WF-04182023-009407	11/13/2023	FT-FY24-10102023-009407-A	<1	FT-FY24-10102023-009407-B	<1
WS- 009417	4/18/2023	4/18/2024	Ground Floor	Cooler	In hallway adjacent to workroom G08	High	Left	WF-04182023-009417	11/13/2023	FT-FY24-10102023-009417-A	<1	FT-FY24-10102023-009417-B	<1
WS- 009418	4/18/2023	4/18/2024	Ground Floor	Cooler	In hallway adjacent to workroom G08	Low	Right	WF-04182023-009418	11/13/2023	FT-FY24-10102023-009418-A	<1	FT-FY24-10102023-009418-B	<1
WS- 009419	4/18/2023	4/18/2024	Ground Floor	Health Suite	In health suite in alcove G16			WF-04182023-009419	11/13/2023	FT-FY24-10102023-009419-A	<1	FT-FY24-10102023-009419-B	<1
WS- 009420	4/18/2023	4/18/2024	Ground Floor	Health Suite	In health suite in health lab room G24			WF-04182023-009420	11/13/2023	FT-FY24-10102023-009420-A	<1	FT-FY24-10102023-009420-B	<1
WS- 009421	4/18/2023	4/18/2024	Ground Floor	Health Suite	In health suite in treatment room G18			WF-04182023-009421	11/13/2023	FT-FY24-10102023-009421-A	<1	FT-FY24-10102023-009421-B	<1
WS- 009422	4/18/2023	4/18/2024	Ground Floor	Cooler	In fitness center room G26	High	Left	WF-04182023-009422	11/13/2023	FT-FY24-10102023-009422-A	<1	FT-FY24-10102023-009422-B	<1
WS- 009423	4/18/2023	4/18/2024	Ground Floor	Cooler	In fitness center room G26	Low	Right	WF-04182023-009423	11/13/2023	FT-FY24-10102023-009423-A	<1	FT-FY24-10102023-009423-B	<1
WS- 009424	4/18/2023	4/18/2024	1	Cooler	In hallway adjacent to storage room 131	High	Left	WF-04182023-009424	11/13/2023	FT-FY24-10102023-009424-A	<1	FT-FY24-10102023-009424-B	<1
WS- 009425	4/18/2023	4/18/2024	1	Cooler	In hallway adjacent to storage room 131	Low	Right	WF-04182023-009425	11/13/2023	FT-FY24-10102023-009425-A	<1	FT-FY24-10102023-009425-B	<1
WS- 009427	4/18/2023	4/18/2024	1	Combo Fountain	In classroom 135			WF-04182023-009427	11/13/2023	FT-FY24-10102023-009427-A	<1	FT-FY24-10102023-009427-B	<1
WS- 009429	4/18/2023	4/18/2024	1	Combo Fountain	In office room 136			WF-04182023-009429	11/13/2023	FT-FY24-10102023-009429-A	<1	FT-FY24-10102023-009429-B	<1
WS- 009430	4/18/2023	4/18/2024	1	Cooler	In hallway adjacent to storage room 155	High	Left	WF-04182023-009430	11/13/2023	FT-FY24-10102023-009430-A	<1	FT-FY24-10102023-009430-B	<1
WS- 009431	4/18/2023	4/18/2024	1	Cooler	In hallway adjacent to storage room 155	Low	Right	WF-04182023-009431	11/13/2023	FT-FY24-10102023-009431-A	<1	FT-FY24-10102023-009431-B	<1
WS- 009440	4/18/2023	4/18/2024	1	Cooler	In hallway adjacent to custodial room 123	High	Left	WF-04182023-009440	11/13/2023	FT-FY24-10102023-009440-A	<1	FT-FY24-10102023-009440-B	<1
WS- 009441	4/18/2023	4/18/2024	1	Cooler	In hallway adjacent to custodial room 123	Low	Right	WF-04182023-009441	11/13/2023	FT-FY24-10102023-009441-A	<1	FT-FY24-10102023-009441-B	<1
WS- 009444	4/18/2023	4/18/2024	1	Break Room	In workroom 108			WF-04182023-009444	11/13/2023	FT-FY24-10102023-009444-A	<1	FT-FY24-10102023-009444-B	<1
WS- 009446	4/18/2023	4/18/2024	1	Break Room	In main office across from office room 119			WF-04182023-009446	11/13/2023	FT-FY24-10102023-009446-A	<1	FT-FY24-10102023-009446-B	<1
WS- 009447	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to dance studio 218	High	Left	WF-04182023-009447	11/13/2023	FT-FY24-10102023-009447-A	<1	FT-FY24-10102023-009447-B	<1
WS- 009448	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to dance studio 218	Low	Right	WF-04182023-009448	11/13/2023	FT-FY24-10102023-009448-A	<1	FT-FY24-10102023-009448-B	<1
WS- 009449	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to dance studio 225	High	Left	WF-04182023-009449	11/13/2023	FT-FY24-10102023-009449-A	<1	FT-FY24-10102023-009449-B	<1
WS- 009450	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to dance studio 225	Low	Right	WF-04182023-009450	11/13/2023	FT-FY24-10102023-009450-A	<1	FT-FY24-10102023-009450-B	<1
WS- 009452	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to dance studio 232	High	Left	WF-04182023-009452	11/13/2023	FT-FY24-10102023-009452-A	<1	FT-FY24-10102023-009452-B	<1
WS- 009453	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to dance studio 232	Low	Right	WF-04182023-009453	11/13/2023	FT-FY24-10102023-009453-A	<1	FT-FY24-10102023-009453-B	<1
WS- 009455	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to LMC studio 245	High	Left	WF-04182023-009455	11/13/2023	FT-FY24-10102023-009455-A	<1	FT-FY24-10102023-009455-B	<1
WS- 009456	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to LMC studio 245	Low	Right	WF-04182023-009456	11/13/2023	FT-FY24-10102023-009456-A	<1	FT-FY24-10102023-009456-B	<1
WS- 009457	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to classroom 265	High	Left	WF-04182023-009457	11/13/2023	FT-FY24-10102023-009457-A	<1	FT-FY24-10102023-009457-B	<1

WS- 009458	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to classroom 265	Low	Right	WF-04182023-009458	11/13/2023	FT-FY24-10102023-009458-A	<1	FT-FY24-10102023-009458-B	<1
WS- 009459	4/18/2023	4/18/2024	2	Break Room	In workroom 206			WF-04182023-009459	11/13/2023	FT-FY24-10102023-009459-A	<1	FT-FY24-10102023-009459-B	<1
WS- 009460	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to classroom 209	High	Left	WF-04182023-009460	11/13/2023	FT-FY24-10102023-009460-A	<1	FT-FY24-10102023-009460-B	<1
WS- 009461	4/18/2023	4/18/2024	2	Cooler	In hallway adjacent to classroom 209	Low	Right	WF-04182023-009461	11/13/2023	FT-FY24-10102023-009461-A	<1	FT-FY24-10102023-009461-B	<1
WS- 009463	4/18/2023	4/18/2024	3	Cooler	In hallway adjacent to instrumental studio 313	High	Left	WF-04182023-009463	11/13/2023	FT-FY24-10102023-009463-A	<1	FT-FY24-10102023-009463-B	<1
WS- 009464	4/18/2023	4/18/2024	3	Cooler	In hallway adjacent to instrumental studio 313	Low	Right	WF-04182023-009464	11/13/2023	FT-FY24-10102023-009464-A	<1	FT-FY24-10102023-009464-B	<1
WS- 009465	4/18/2023	4/18/2024	3	Cooler	In hallway adjacent to classroom 353	High	Left	WF-04182023-009465	11/13/2023	FT-FY24-10102023-009465-A	<1	FT-FY24-10102023-009465-B	<1
WS- 009466	4/18/2023	4/18/2024	3	Cooler	In hallway adjacent to classroom 353	Low	Right	WF-04182023-009466	11/13/2023	FT-FY24-10102023-009466-A	<1	FT-FY24-10102023-009466-B	<1
WS- 009468	4/18/2023	4/18/2024	3	Cooler	In orchestra rehearsal room 363			WF-04182023-009468	11/13/2023	FT-FY24-10102023-009468-A	<1	FT-FY24-10102023-009468-B	<1
WS- 009469	4/18/2023	4/18/2024	3	Cooler	In hallway adjacent to classroom 372	High	Left	WF-04182023-009469	11/13/2023	FT-FY24-10102023-009469-A	<1	FT-FY24-10102023-009469-B	<1
WS- 009470	4/18/2023	4/18/2024	3	Cooler	In hallway adjacent to classroom 372	Low	Right	WF-04182023-009470	11/13/2023	FT-FY24-10102023-009470-A	<1	FT-FY24-10102023-009470-B	<1
WS- 009471	4/18/2023	4/18/2024	3	Cooler	In hallway adjacent to classroom 304	High	Left	WF-04182023-009471	11/13/2023	FT-FY24-10102023-009471-A	<1	FT-FY24-10102023-009471-B	<1
WS- 009472	4/18/2023	4/18/2024	3	Cooler	In hallway adjacent to classroom 304	Low	Right	WF-04182023-009472	11/13/2023	FT-FY24-10102023-009472-A	<1	FT-FY24-10102023-009472-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009408	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	WF-12202022-009408	11/13/2023	FT-FY24-10102023-009408-A	<1	FT-FY24-10102023-009408-B	<1
WS- 009409	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	WF-12202022-009409	11/13/2023	FT-FY24-10102023-009409-A	<1	FT-FY24-10102023-009409-B	<1
WS- 009410	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door	WF-12202022-009410	11/13/2023	FT-FY24-10102023-009410-A	2.6	FT-FY24-10102023-009410-B	<1