



# Duke Ellington Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009191	6/20/2018	6/20/2019	1	Cooler	In hallway across from electrical room 124a	WF-06202018-009191	1/14/2019	FT-FY19-012019-009191-A	<1	FT-FY19-012019-009191-B	<1
WS-009192	6/20/2018	6/20/2019	1	Cooler	In hallway across from electrical room 124a	WF-06202018-009192	1/14/2019	FT-FY19-012019-009192-A	<1	FT-FY19-012019-009192-B	<1
WS-009402	6/20/2018	6/20/2019	Ground Floor	Cooler	In hallway adjacent to room G32A	WF-06202018-009402	1/14/2019	FT-FY19-012019-009402-A	<1	FT-FY19-012019-009402-B	<1
WS-009403	6/20/2018	6/20/2019	Ground Floor	Cooler	In hallway adjacent to room G32A	WF-06202018-009403	1/14/2019	FT-FY19-012019-009403-A	<1	FT-FY19-012019-009403-B	<1
WS-009404	6/20/2018	6/20/2019	Ground Floor	Cooler	In hallway across from room G60	WF-06202018-009404	1/14/2019	FT-FY19-012019-009404-A	<1	FT-FY19-012019-009404-B	<1
WS-009405	6/20/2018	6/20/2019	Ground Floor	Cooler	In hallway across from room G60	WF-06202018-009405	1/14/2019	FT-FY19-012019-009405-A	<1	FT-FY19-012019-009405-B	<1
WS-009406	6/20/2018	6/20/2019	Ground Floor	Cooler	In cafeteria	WF-06202018-009406	1/14/2019	FT-FY19-012019-009406-A	<1	FT-FY19-012019-009406-B	<1
WS-009407	6/20/2018	6/20/2019	Ground Floor	Cooler	In cafeteria	WF-06202018-009407	1/14/2019	FT-FY19-012019-009407-A	<1	FT-FY19-012019-009407-B	<1
WS-009417	6/20/2018	6/20/2019	Ground Floor	Cooler	In hallway adjacent to workroom G08	WF-06202018-009417	1/14/2019	FT-FY19-012019-009417-A	<1	FT-FY19-012019-009417-B	<1
WS-009418	6/20/2018	6/20/2019	Ground Floor	Cooler	In hallway adjacent to workroom G08	WF-06202018-009418	1/14/2019	FT-FY19-012019-009418-A	<1	FT-FY19-012019-009418-B	<1
WS-009419	6/20/2018	6/20/2019	Ground Floor	Health Suite	In health suite in alcove G16	WF-06202018-009419	1/14/2019	FT-FY19-012019-009419-A	<1	FT-FY19-012019-009419-B	<1
WS-009420	6/20/2018	6/20/2019	Ground Floor	Health Suite	In health suite in health lab room G24	WF-06202018-009420	1/14/2019	FT-FY19-012019-009420-A	<1	FT-FY19-012019-009420-B	<1
WS-009421	6/20/2018	6/20/2019	Ground Floor	Health Suite	In health suite in treatment room G18	WF-06202018-009421	1/14/2019	FT-FY19-012019-009421-A	<1	FT-FY19-012019-009421-B	<1
WS-009422	6/20/2018	6/20/2019	Ground Floor	Cooler	In fitness center room G26	WF-06202018-009422	1/14/2019	FT-FY19-012019-009422-A	<1	FT-FY19-012019-009422-B	<1
WS-009423	6/20/2018	6/20/2019	Ground Floor	Cooler	In fitness center room G26	WF-06202018-009423	1/14/2019	FT-FY19-012019-009423-A	<1	FT-FY19-012019-009423-B	<1
WS-009424	6/20/2018	6/20/2019	1	Cooler	In hallway adjacent to storage room 131	WF-06202018-009424	1/14/2019	FT-FY19-012019-009424-A	<1	FT-FY19-012019-009424-B	<1
WS-009425	6/20/2018	6/20/2019	1	Cooler	In hallway adjacent to storage room 131	WF-06202018-009425	1/14/2019	FT-FY19-012019-009425-A	<1	FT-FY19-012019-009425-B	<1
WS-009427	6/20/2018	6/20/2019	1	Combo Fountain	In classroom 135	WF-06202018-009427	1/14/2019	FT-FY19-012019-009427-A	<1	FT-FY19-012019-009427-B	<1
WS-009429	6/20/2018	6/20/2019	1	Combo Fountain	In office room 136	WF-06202018-009429	1/14/2019	FT-FY19-012019-009429-A	<1	FT-FY19-012019-009429-B	<1
WS-009430	6/20/2018	6/20/2019	1	Cooler	In hallway adjacent to storage room 155	WF-06202018-009430	1/14/2019	FT-FY19-012019-009430-A	<1	FT-FY19-012019-009430-B	<1
WS-009431	6/20/2018	6/20/2019	1	Cooler	In hallway adjacent to storage room 155	WF-06202018-009431	1/14/2019	FT-FY19-012019-009431-A	<1	FT-FY19-012019-009431-B	<1
WS-009440	6/20/2018	6/20/2019	1	Cooler	In hallway adjacent to custodial room 123	WF-06202018-009440	1/14/2019	FT-FY19-012019-009440-A	<1	FT-FY19-012019-009440-B	<1
WS-009441	6/20/2018	6/20/2019	1	Cooler	In hallway adjacent to custodial room 123	WF-06202018-009441	1/14/2019	FT-FY19-012019-009441-A	<1	FT-FY19-012019-009441-B	<1
WS-009444	6/20/2018	6/20/2019	1	Break Room	In workroom 108	WF-06202018-009444	1/14/2019	FT-FY19-012019-009444-A	<1	FT-FY19-012019-009444-B	<1
WS-009446	6/20/2018	6/20/2019	1	Break Room	In main office across from office room 119	WF-06202018-009446	1/14/2019	FT-FY19-012019-009446-A	<1	FT-FY19-012019-009446-B	<1
WS-009447	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to dance studio 218	WF-06202018-009447	1/14/2019	FT-FY19-012019-009447-A	<1	FT-FY19-012019-009447-B	<1
WS-009448	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to dance studio 218	WF-06202018-009448	1/14/2019	FT-FY19-012019-009448-A	<1	FT-FY19-012019-009448-B	<1
WS-009449	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to dance studio 225	WF-06202018-009449	1/14/2019	FT-FY19-012019-009449-A	<1	FT-FY19-012019-009449-B	<1
WS-009450	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to dance studio 225	WF-06202018-009450	1/14/2019	FT-FY19-012019-009450-A	<1	FT-FY19-012019-009450-B	<1
WS-009452	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to dance studio 232	WF-06202018-009452	1/14/2019	FT-FY19-012019-009452-A	<1	FT-FY19-012019-009452-B	<1
WS-009453	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to dance studio 232	WF-06202018-009453	1/14/2019	FT-FY19-012019-009453-A	<1	FT-FY19-012019-009453-B	<1
WS-009455	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to LMC studio 245	WF-06202018-009455	1/14/2019	FT-FY19-012019-009455-A	<1	FT-FY19-012019-009455-B	<1
WS-009456	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to LMC studio 245	WF-06202018-009456	1/14/2019	FT-FY19-012019-009456-A	<1	FT-FY19-012019-009456-B	<1
WS-009457	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to classroom 265	WF-06202018-009457	1/14/2019	FT-FY19-012019-009457-A	<1	FT-FY19-012019-009457-B	<1

WS- 009458	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to classroom 265	Low Right	WF-06202018-009458	1/14/2019	FT-FY19-012019-009458-A	<1	FT-FY19-012019-009458-B	<1
WS- 009459	6/20/2018	6/20/2019	2	Break Room	In workroom 206		WF-06202018-009459	1/14/2019	FT-FY19-012019-009459-A	<1	FT-FY19-012019-009459-B	<1
WS- 009460	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to classroom 209	High Left	WF-06202018-009460	1/14/2019	FT-FY19-012019-009460-A	<1	FT-FY19-012019-009460-B	<1
WS- 009461	6/20/2018	6/20/2019	2	Cooler	In hallway adjacent to classroom 209	Low Right	WF-06202018-009461	1/14/2019	FT-FY19-012019-009461-A	<1	FT-FY19-012019-009461-B	<1
WS- 009462	6/20/2018	6/20/2019	3	Cooler	In instrumental studio room 313		WF-06202018-009462	1/14/2019	FT-FY19-012019-009462-A	<1	FT-FY19-012019-009462-B	<1
WS- 009463	6/20/2018	6/20/2019	3	Cooler	In hallway adjacent to instrumental studio 313	High Left	WF-06202018-009463	1/14/2019	FT-FY19-012019-009463-A	<1	FT-FY19-012019-009463-B	<1
WS- 009464	6/20/2018	6/20/2019	3	Cooler	In hallway adjacent to instrumental studio 313	Low Right	WF-06202018-009464	1/14/2019	FT-FY19-012019-009464-A	<1	FT-FY19-012019-009464-B	<1
WS- 009465	6/20/2018	6/20/2019	3	Cooler	In hallway adjacent to classroom 353	High Left	WF-06202018-009465	1/14/2019	FT-FY19-012019-009465-A	<1	FT-FY19-012019-009465-B	<1
WS- 009466	6/20/2018	6/20/2019	3	Cooler	In hallway adjacent to classroom 353	Low Right	WF-06202018-009466	1/14/2019	FT-FY19-012019-009466-A	<1	FT-FY19-012019-009466-B	<1
WS- 009468	6/20/2018	6/20/2019	3	Cooler	In orchestra rehearsal room 363		WF-06202018-009468	1/14/2019	FT-FY19-012019-009468-A	<1	FT-FY19-012019-009468-B	<1
WS- 009469	6/20/2018	6/20/2019	3	Cooler	In hallway adjacent to classroom 372	High Left	WF-06202018-009469	1/14/2019	FT-FY19-012019-009469-A	<1	FT-FY19-012019-009469-B	<1
WS- 009470	6/20/2018	6/20/2019	3	Cooler	In hallway adjacent to classroom 372	Low Right	WF-06202018-009470	1/14/2019	FT-FY19-012019-009470-A	<1	FT-FY19-012019-009470-B	<1
WS- 009471	6/20/2018	6/20/2019	3	Cooler	In hallway adjacent to classroom 304	High Left	WF-06202018-009471	1/14/2019	FT-FY19-012019-009471-A	<1	FT-FY19-012019-009471-B	<1
WS- 009472	6/20/2018	6/20/2019	3	Cooler	In hallway adjacent to classroom 304	Low Right	WF-06202018-009472	1/14/2019	FT-FY19-012019-009472-A	<1	FT-FY19-012019-009472-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation								
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009409	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	1/14/2019	FT-FY19-012019-009409-A	<1	FT-FY19-012019-009409-B	<1