



DUKE ELLINGTON @ MEYER LEAD WATER TEST RESULTS

May 16th, 2016



| Building Location | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|---------------------------|-----------------------|-----------------|--------------|--------------|-------------------------------------|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|-----------------|-----------------|
| 1 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012047 | Utility | Ground Floor | In room 226 (Main water source) | WT-042916-12064- A | 1.6 | WT-042916-12064- B | < 1 | | | | |
| 2 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012048 | Cooler | Ground Floor | In hallway across from room 14 | WT-042916-12065- A | < 1 | WT-042916-12065- B | < 1 | | | | |
| 3 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012049 | Cooler | Ground Floor | In hallway adjacent to the bathroom | WT-042916-12066- A | < 1 | WT-042916-12066- B | < 1 | | | | |
| 4 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012050 | Classroom | Ground Floor | G05 | WT-042916-12067- A | 5.4 | WT-042916-12067- B | < 1 | | | | |
| 5 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012051 | Classroom | Ground Floor | In Room B118 | Left | WT-042916-12068- A | < 1 | WT-042916-12068- B | < 1 | | | |
| 6 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012052 | Classroom | Ground Floor | In room B118 | Mid | WT-042916-12069- A | 1.5 | WT-042916-12069- B | < 1 | | | |
| 7 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012053 | Classroom | Ground Floor | In room B118 | Right | WT-042916-12070- A | 1.2 | WT-042916-12070- B | < 1 | | | |
| 8 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012054 | Classroom | Ground Floor | In room B117 | Left | WT-042916-12071- A | < 1 | WT-042916-12071- B | < 1 | | | |
| 9 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012055 | Classroom | Ground Floor | In room B117 | Right | WT-042916-12072- A | 1.7 | WT-042916-12072- B | < 1 | | | |
| 10 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012056 | Classroom | Ground Floor | In room B117 | Right | WT-042916-12073- A | 1.2 | WT-042916-12073- B | < 1 | | | |
| 11 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012057 | Classroom | Ground Floor | In room B116 | | WT-042916-12074- A | < 1 | WT-042916-12074- B | < 1 | | | |
| 12 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012058 | Classroom | Ground Floor | In room B115 | Left | WT-042916-12075- A | < 1 | WT-042916-12075- B | < 1 | | | |
| 13 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012059 | Classroom | Ground Floor | In room B115 | Mid | WT-042916-12076- A | < 1 | WT-042916-12076- B | < 1 | | | |
| 14 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012060 | Classroom | Ground Floor | In room B115 | Right | WT-042916-12077- A | < 1 | WT-042916-12077- B | < 1 | | | |
| 15 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012061 | Cooler | Ground Floor | In hallway across from B112 | Left High | WT-042916-12078- A | 1.8 | WT-042916-12078- B | < 1 | | | |
| 16 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012062 | Cooler | Ground Floor | In hallway across from B112 | Left Low | WT-042916-12079- A | < 1 | WT-042916-12079- B | < 1 | | | |
| 17 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012063 | Cooler | Ground Floor | In hallway across from B112 | Left High | WT-042916-12080- A | 1.7 | WT-042916-12080- B | < 1 | | | |
| 18 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012064 | Cooler | Ground Floor | In hallway across from B112 | Right Low | WT-042916-12081- A | < 1 | WT-042916-12081- B | < 1 | | | |
| 19 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012065 | Classroom | Ground Floor | In room B105 | | WT-042916-12082- A | < 1 | WT-042916-12082- B | < 1 | | | |
| 20 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012066 | Cooler | 1 | In hallway adjacent to room 143 | | WT-042916-12083- A | < 1 | WT-042916-12083- B | < 1 | | | |
| 21 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012067 | Health Suite | 1 | In health suite | Left | WT-042916-12084- A | 8.3 | WT-042916-12084- B | < 1 | | | |
| 22 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012068 | Health Suite | 1 | In health suite | Right | WT-042916-12085- A | 1.6 | WT-042916-12085- B | < 1 | | | |
| 23 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012069 | Classroom | Ground Floor | In room 19 | | WT-042916-12086- A | 1.9 | WT-042916-12086- B | < 1 | | | |
| 24 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012070 | Classroom | 1 | In teachers lounge | | WT-042916-12087- A | < 1 | WT-042916-12087- B | < 1 | | | |
| 25 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012071 | Cooler | 1 | In hallway adjacent to bathroom | | WT-042916-12088- A | < 1 | WT-042916-12088- B | < 1 | | | |
| 26 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012072 | Kitchen | 1 | In kitchen | Left | WT-042916-12089- A | < 1 | WT-042916-12089- B | < 1 | | | |
| 27 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012073 | Kitchen | 1 | In kitchen | Right | WT-042916-12090- A | < 1 | WT-042916-12090- B | < 1 | | | |
| 28 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012074 | Cooler | 1 | In hallway adjacent to room 115 | | WT-042916-12091- A | < 1 | WT-042916-12091- B | < 1 | | | |
| 29 DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012075 | Cooler | 2 | In hallway adjacent to room 215 | | WT-042916-12092- A | < 1 | WT-042916-12092- B | < 1 | | | |

| | | | | | | | | | | | | | | |
|----|---------------------------|-----------|------------|-----------|---|---------------------------------|--------------------|------|--------------------|-----|--|--|--|--|
| 30 | DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012076 | Classroom | 2 | In room 215 | WT-042916-12093- A | 11.7 | WT-042916-12093- B | 11 | | | | |
| 31 | DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012077 | Cooler | 2 | In hallway adjacent to bathroom | WT-042916-12094- A | < 1 | WT-042916-12094- B | < 1 | | | | |
| 32 | DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012078 | Cooler | 2 | In hallway across from room 202 | WT-042916-12095- A | < 1 | WT-042916-12095- B | < 1 | | | | |
| 33 | DUKE ELLINGTON @ MEYER | 5/14/2016 | WS- 012079 | Classroom | 2 | In room 225 | WT-042916-12096- A | 4.3 | WT-042916-12096- B | < 1 | | | | |

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.