



DUNBAR HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	DUNBAR HIGH SCHOOL	WS- 005043	8/22/2016	3	Cooler	In hallway adjacent to room 381	High Left	FT-82016-005043-A	< 1	FT-82016-005043-B	< 1
2	DUNBAR HIGH SCHOOL	WS- 005044	8/22/2016	3	Cooler	In hallway adjacent to room 381	Low Right	FT-82016-005044-A	< 1	FT-82016-005044-B	< 1
3	DUNBAR HIGH SCHOOL	WS- 005088	8/22/2016	4	Cooler	In hallway adjacent to room 481	High Left	FT-82016-005088-A	3	FT-82016-005088-B	< 1
4	DUNBAR HIGH SCHOOL	WS- 005089	8/22/2016	4	Cooler	In hallway adjacent to room 481	Low Right	FT-82016-005089-A	< 1	FT-82016-005089-B	< 1
5	DUNBAR HIGH SCHOOL	WS- 012258	8/22/2016	Basement	Cooler	In hallway adjacent to pool/060	Low Right	FT-82016-012258-A	< 1	FT-82016-012258-B	< 1
6	DUNBAR HIGH SCHOOL	WS- 012259	8/22/2016	Basement	Cooler	In hallway adjacent to pool/060	High Left	FT-82016-012259-A	< 1	FT-82016-012259-B	< 1
7	DUNBAR HIGH SCHOOL	WS- 012260	8/22/2016	1	Cooler	In hallway adjacent to room 162	High Left	FT-82016-012260-A	< 1	FT-82016-012260-B	< 1
8	DUNBAR HIGH SCHOOL	WS- 012261	8/22/2016	1	Cooler	In hallway adjacent to room 162	Low Right	FT-82016-012261-A	< 1	FT-82016-012261-B	< 1
9	DUNBAR HIGH SCHOOL	WS- 012264	8/22/2016	1	Classroom Faucet	In training room 153		FT-82016-012264-A	< 1	FT-82016-012264-B	< 1
10	DUNBAR HIGH SCHOOL	WS- 012265	8/22/2016	1	Food Prep Sink	In kitchen first clockwise from entry door		FT-72016-012265-A	< 1	FT-72016-012265-B	< 1
11	DUNBAR HIGH SCHOOL	WS- 012266	8/22/2016	1	Kitchen	In kitchen second clockwise from entry door		FT-82016-012266-A	< 1	FT-82016-012266-B	< 1
12	DUNBAR HIGH SCHOOL	WS- 012274	8/22/2016	1	Cooler	In hallway adjacent to room 197	High Left	FT-82016-012274-A	< 1	FT-82016-012274-B	< 1
13	DUNBAR HIGH SCHOOL	WS- 012275	8/22/2016	1	Cooler	In hallway adjacent to room 197	Low Right	FT-82016-012275-A	< 1	FT-82016-012275-B	< 1
14	DUNBAR HIGH SCHOOL	WS- 012321	8/22/2016	2	Cooler	In hallway across from room 297	High Left	FT-82016-012321-A	< 1	FT-82016-012321-B	< 1
15	DUNBAR HIGH SCHOOL	WS- 012322	8/22/2016	2	Cooler	In hallway across from room 297	Low Right	FT-82016-012322-A	< 1	FT-82016-012322-B	< 1
16	DUNBAR HIGH SCHOOL	WS- 012326	8/22/2016	2	Cooler	In hallway adjacent to gym 260	High Left	FT-82016-012326-A	< 1	FT-82016-012326-B	< 1
17	DUNBAR HIGH SCHOOL	WS- 012327	8/22/2016	2	Cooler	In hallway adjacent to gym 260	Low Right	FT-82016-012327-A	< 1	FT-82016-012327-B	< 1
18	DUNBAR HIGH SCHOOL	WS- 012328	8/22/2016	2	Cooler	In gym 260	High Left	FT-82016-012328-A	< 1	FT-82016-012328-B	< 1
19	DUNBAR HIGH SCHOOL	WS- 012329	8/22/2016	2	Cooler	In gym 260	Low Right	FT-82016-012329-A	< 1	FT-82016-012329-B	< 1
20	DUNBAR HIGH SCHOOL	WS- 012334	8/22/2016	2	Health Suite	In break room 228 in health suite		FT-82016-012334-A	< 1	FT-82016-012334-B	< 1
21	DUNBAR HIGH SCHOOL	WS- 012336	8/22/2016	2	Health Suite	In dental suite 227 in health suite	Left	FT-82016-012336-A	< 1	FT-82016-012336-B	< 1
22	DUNBAR HIGH SCHOOL	WS- 012337	8/22/2016	2	Health Suite	In lab room 225E in health suite		FT-82016-012337-A	< 1	FT-82016-012337-B	< 1
23	DUNBAR HIGH SCHOOL	WS- 012338	8/22/2016	2	Health Suite	In health suite 225		FT-82016-012338-A	< 1	FT-82016-012338-B	< 1
24	DUNBAR HIGH SCHOOL	WS- 012339	8/22/2016	2	Health Suite	In dental suite 227 in health suite (handwash sink)	Right	FT-82016-012339-A	< 1	FT-82016-012339-B	< 1
25	DUNBAR HIGH SCHOOL	WS- 012340	8/22/2016	2	Health Suite	In exam room 225D in health suite		FT-82016-012340-A	< 1	FT-82016-012340-B	< 1
26	DUNBAR HIGH SCHOOL	WS- 012341	8/22/2016	2	Health Suite	In exam room 225C in health suite		FT-82016-012341-A	< 1	FT-82016-012341-B	< 1
27	DUNBAR HIGH SCHOOL	WS- 012342	8/22/2016	2	Health Suite	In exam room 225A in health suite		FT-82016-012342-A	< 1	FT-82016-012342-B	< 1