



# Dunbar High School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005043	6/1/2020	6/1/2021	3	Cooler	In hallway adjacent to room 381	High Left	WF-06012020-005043	4/23/2021	FT-FY21-042021-005043-A	<1	FT-FY21-042021-005043-B	<1
WS- 005044	6/1/2020	6/1/2021	3	Cooler	In hallway adjacent to room 381	Low Right	WF-06012020-005044	4/23/2021	FT-FY21-042021-005044-A	<1	FT-FY21-042021-005044-B	<1
WS- 005045	6/1/2020	6/1/2021	3	Break Room	In break room 398		WF-06012020-005045	4/23/2021	FT-FY21-042021-005045-A	<1	FT-FY21-042021-005045-B	<1
WS- 005088	6/1/2020	6/1/2021	4	Cooler	In hallway adjacent to room 481	High Left	WF-06012020-005088	4/23/2021	FT-FY21-042021-005088-A	<1	FT-FY21-042021-005088-B	<1
WS- 005089	6/1/2020	6/1/2021	4	Cooler	In hallway adjacent to room 481	Low Right	WF-06012020-005089	4/23/2021	FT-FY21-042021-005089-A	<1	FT-FY21-042021-005089-B	<1
WS- 005090	6/1/2020	6/1/2021	4	Break Room	In break room 498		WF-06012020-005090	4/23/2021	FT-FY21-042021-005090-A	<1	FT-FY21-042021-005090-B	<1
WS- 005096	6/1/2020	6/1/2021	1	Break Room	In break room 117		WF-06012020-005096	4/23/2021	FT-FY21-042021-005096-A	<1	FT-FY21-042021-005096-B	<1
WS- 009164	6/1/2020	6/1/2021	4	Break Room	In break room 482A		WF-06012020-009164	4/23/2021	FT-FY21-042021-009164-A	<1	FT-FY21-042021-009164-B	<1
WS- 009166	6/1/2020	6/1/2021	2	Break Room	In break room in library		WF-06012020-009166	4/23/2021	FT-FY21-042021-009166-A	<1	FT-FY21-042021-009166-B	<1
WS- 012258	6/1/2020	6/1/2021	Basement	Cooler	In hallway adjacent to pool/060	Low Right	WF-06012020-012258	4/23/2021	FT-FY21-042021-012258-A	<1	FT-FY21-042021-012258-B	<1
WS- 012259	6/1/2020	6/1/2021	Basement	Cooler	In hallway adjacent to pool/060	High Left	WF-06012020-012259	4/23/2021	FT-FY21-042021-012259-A	<1	FT-FY21-042021-012259-B	<1
WS- 012260	6/1/2020	6/1/2021	1	Cooler	In hallway adjacent to room 162	High Left	WF-06012020-012260	4/23/2021	FT-FY21-042021-012260-A	<1	FT-FY21-042021-012260-B	<1
WS- 012261	6/1/2020	6/1/2021	1	Cooler	In hallway adjacent to room 162	Low Right	WF-06012020-012261	4/23/2021	FT-FY21-042021-012261-A	<1	FT-FY21-042021-012261-B	<1
WS- 012264	6/1/2020	6/1/2021	1	Classroom Faucet	In athletics training room 153		WF-06012020-012264	4/23/2021	FT-FY21-042021-012264-A	<1	FT-FY21-042021-012264-B	<1
WS- 012273	6/1/2020	6/1/2021	1	Break Room	In break room 198		WF-06012020-012273	4/23/2021	FT-FY21-042021-012273-A	<1	FT-FY21-042021-012273-B	<1
WS- 012275	6/1/2020	6/1/2021	1	Cooler	In hallway adjacent to room 197	Low Right	WF-06012020-012275	4/23/2021	FT-FY21-042021-012275-A	<1	FT-FY21-042021-012275-B	<1
WS- 012321	6/1/2020	6/1/2021	2	Cooler	In hallway across from room 297	High Left	WF-06012020-012321	4/23/2021	FT-FY21-042021-012321-A	<1	FT-FY21-042021-012321-B	<1
WS- 012322	6/1/2020	6/1/2021	2	Cooler	In hallway across from room 297	Low Right	WF-06012020-012322	4/23/2021	FT-FY21-042021-012322-A	<1	FT-FY21-042021-012322-B	<1
WS- 012323	6/1/2020	6/1/2021	2	Break Room	In break room 298		WF-06012020-012323	4/23/2021	FT-FY21-042021-012323-A	<1	FT-FY21-042021-012323-B	<1
WS- 012326	6/1/2020	6/1/2021	2	Cooler	In hallway adjacent to gym 260	High Left	WF-06012020-012326	4/23/2021	FT-FY21-042021-012326-A	<1	FT-FY21-042021-012326-B	<1
WS- 012327	6/1/2020	6/1/2021	2	Cooler	In hallway adjacent to gym 260	Low Right	WF-06012020-012327	4/23/2021	FT-FY21-042021-012327-A	<1	FT-FY21-042021-012327-B	<1
WS- 012328	6/1/2020	6/1/2021	2	Cooler	In gym 260	High Left	WF-06012020-012328	4/23/2021	FT-FY21-042021-012328-A	<1	FT-FY21-042021-012328-B	<1
WS- 012329	6/1/2020	6/1/2021	2	Cooler	In gym 260	Low Right	WF-06012020-012329	4/23/2021	FT-FY21-042021-012329-A	<1	FT-FY21-042021-012329-B	<1
WS- 012330	6/1/2020	6/1/2021	2	Break Room	In break room 251 (gym physical education office)		WF-06012020-012330	4/23/2021	FT-FY21-042021-012330-A	<1	FT-FY21-042021-012330-B	<1
WS- 012334	6/1/2020	6/1/2021	2	Health Suite	In health suite in break room 228		WF-06012020-012334	4/23/2021	FT-FY21-042021-012334-A	<1	FT-FY21-042021-012334-B	<1
WS- 012336	6/1/2020	6/1/2021	2	Health Suite	In health suite in dental suite 227	Left	WF-06012020-012336	4/23/2021	FT-FY21-042021-012336-A	1.1	FT-FY21-042021-012336-B	<1
WS- 012337	6/1/2020	6/1/2021	2	Health Suite	In health suite lab room 225E		WF-06012020-012337	4/23/2021	FT-FY21-042021-012337-A	<1	FT-FY21-042021-012337-B	<1
WS- 012338	6/1/2020	6/1/2021	2	Health Suite	In health suite 227		WF-06012020-012338	4/23/2021	FT-FY21-042021-012338-A	<1	FT-FY21-042021-012338-B	<1
WS- 012339	6/1/2020	6/1/2021	2	Health Suite	In health suite in dental suite 227 (handwash sink)	Right	WF-06012020-012339	4/23/2021	FT-FY21-042021-012339-A	1.2	FT-FY21-042021-012339-B	<1
WS- 012340	6/1/2020	6/1/2021	2	Health Suite	In health suite in exam room 225D		WF-06012020-012340	4/23/2021	FT-FY21-042021-012340-A	<1	FT-FY21-042021-012340-B	<1
WS- 012341	6/1/2020	6/1/2021	2	Health Suite	In health suite in exam room 225C		WF-06012020-012341	4/23/2021	FT-FY21-042021-012341-A	<1	FT-FY21-042021-012341-B	<1
WS- 012342	6/1/2020	6/1/2021	2	Health Suite	In health suite in exam room 225A		WF-06012020-012342	4/23/2021	FT-FY21-042021-012342-A	<1	FT-FY21-042021-012342-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012265	2/12/2021	2/12/2022	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-02122021-012265	4/23/2021	FT-FY21-042021-012265-A	<1	FT-FY21-042021-012265-B	<1
WS- 012266	2/12/2021	2/12/2022	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-02122021-012266	4/23/2021	FT-FY21-042021-012266-A	<1	FT-FY21-042021-012266-B	<1
WS- 012269	2/12/2021	2/12/2022	1	Food Prep Sink	In 121C in kitchen first clockwise from entry door	WF-02122021-012269	4/23/2021	FT-FY21-042021-012269-A	<1	FT-FY21-042021-012269-B	<1
WS- 012272	2/12/2021	2/12/2022	1	Food Prep Sink	In 121C in kitchen fourth clockwise from entry door	WF-02122021-012272	4/23/2021	FT-FY21-042021-012272-A	<1	FT-FY21-042021-012272-B	<1