



# Dunbar HS Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005043	3/24/2025	3/24/2026	3	Cooler	In hallway adjacent to room 381 High Left	WF-03242025-005043	12/5/2025	FT-FY26-12012025-005043-A	<2	FT-FY26-12012025-005043-B	<2
WS-005044	3/24/2025	3/24/2026	3	Cooler	In hallway adjacent to room 381 Low Right	WF-03242025-005044	12/5/2025	FT-FY26-12012025-005044-A	<2	FT-FY26-12012025-005044-B	<2
WS-005045	3/24/2025	3/24/2026	3	Break Room	In break room 398	WF-03242025-005045	12/5/2025	FT-FY26-12012025-005045-A	<2	FT-FY26-12012025-005045-B	<2
WS-005088	3/24/2025	3/24/2026	4	Cooler	In hallway adjacent to room 481 High Left	WF-03242025-005088	12/5/2025	FT-FY26-12012025-005088-A	<2	FT-FY26-12012025-005088-B	<2
WS-005089	3/24/2025	3/24/2026	4	Cooler	In hallway adjacent to room 481 Low Right	WF-03242025-005089	12/5/2025	FT-FY26-12012025-005089-A	<2	FT-FY26-12012025-005089-B	<2
WS-005090	3/24/2025	3/24/2026	4	Break Room	In break room 498	WF-03242025-005090	12/5/2025	FT-FY26-12012025-005090-A	<2	FT-FY26-12012025-005090-B	<2
WS-005096	3/24/2025	3/24/2026	1	Break Room	In break room 117	WF-03242025-005096	12/5/2025	FT-FY26-12012025-005096-A	<2	FT-FY26-12012025-005096-B	<2
WS-007215	3/24/2025	3/24/2026	4	Bottle Filler	In hallway adjacent to room 481	WF-03242025-007215	12/5/2025	FT-FY26-12012025-007215-A	<2	FT-FY26-12012025-007215-B	<2
WS-007256	3/24/2025	3/24/2026	2	Bottle Filler	In hallway across from room 297	WF-03242025-007256	12/5/2025	FT-FY26-12012025-007256-A	<2	FT-FY26-12012025-007256-B	<2
WS-009164	3/24/2025	3/24/2026	4	Break Room	In break room 482A	WF-03242025-009164	12/5/2025	FT-FY26-12012025-009164-A	<2	FT-FY26-12012025-009164-B	<2
WS-009166	3/24/2025	3/24/2026	2	Break Room	In break room in library	WF-03242025-009166	12/5/2025	FT-FY26-12012025-009166-A	<2	FT-FY26-12012025-009166-B	<2
WS-012258	3/24/2025	3/24/2026	Basement	Cooler	In hallway adjacent to pool/060 Low Right	WF-03242025-012258	12/5/2025	FT-FY26-12012025-012258-A	<2	FT-FY26-12012025-012258-B	<2
WS-012259	3/24/2025	3/24/2026	Basement	Cooler	In hallway adjacent to pool/060 High Left	WF-03242025-012259	12/5/2025	FT-FY26-12012025-012259-A	<2	FT-FY26-12012025-012259-B	<2
WS-012260	3/24/2025	3/24/2026	1	Cooler	In hallway adjacent to room 162 High Left	WF-03242025-012260	12/5/2025	FT-FY26-12012025-012260-A	<2	FT-FY26-12012025-012260-B	<2
WS-012261	3/24/2025	3/24/2026	1	Cooler	In hallway adjacent to room 162 Low Right	WF-03242025-012261	12/5/2025	FT-FY26-12012025-012261-A	<2	FT-FY26-12012025-012261-B	<2
WS-012273	3/24/2025	3/24/2026	1	Break Room	In break room 198	WF-03242025-012273	12/5/2025	FT-FY26-12012025-012273-A	<2	FT-FY26-12012025-012273-B	<2
WS-012275	3/24/2025	3/24/2026	1	Cooler	In hallway adjacent to room 197 Low Right	WF-03242025-012275	12/5/2025	FT-FY26-12012025-012275-A	<2	FT-FY26-12012025-012275-B	<2
WS-012321	3/24/2025	3/24/2026	2	Cooler	In hallway across from room 297 High Left	WF-03242025-012321	12/5/2025	FT-FY26-12012025-012321-A	<2	FT-FY26-12012025-012321-B	<2
WS-012322	3/24/2025	3/24/2026	2	Cooler	In hallway across from room 297 Low Right	WF-03242025-012322	12/5/2025	FT-FY26-12012025-012322-A	<2	FT-FY26-12012025-012322-B	<2
WS-012323	3/24/2025	3/24/2026	2	Break Room	In break room 298	WF-03242025-012323	12/5/2025	FT-FY26-12012025-012323-A	<2	FT-FY26-12012025-012323-B	<2
WS-012326	3/24/2025	3/24/2026	2	Cooler	In hallway adjacent to gym 260 High Left	WF-03242025-012326	12/5/2025	FT-FY26-12012025-012326-A	<2	FT-FY26-12012025-012326-B	<2
WS-012327	3/24/2025	3/24/2026	2	Cooler	In hallway adjacent to gym 260 Low Right	WF-03242025-012327	12/5/2025	FT-FY26-12012025-012327-A	<2	FT-FY26-12012025-012327-B	<2
WS-012328	3/24/2025	3/24/2026	2	Cooler	In gym 260 High Left	WF-03242025-012328	12/5/2025	FT-FY26-12012025-012328-A	<2	FT-FY26-12012025-012328-B	<2
WS-012329	3/24/2025	3/24/2026	2	Cooler	In gym 260 Low Right	WF-03242025-012329	12/5/2025	FT-FY26-12012025-012329-A	<2	FT-FY26-12012025-012329-B	<2
WS-012332	3/24/2025	3/24/2026	2	Break Room	In break room 254	WF-03242025-012332	12/5/2025	FT-FY26-12012025-012332-A	<2	FT-FY26-12012025-012332-B	<2
WS-012334	3/24/2025	3/24/2026	2	Health Suite	In health suite in break room 228	WF-03242025-012334	12/5/2025	FT-FY26-12012025-012334-A	<2	FT-FY26-12012025-012334-B	<2
WS-012336	3/24/2025	3/24/2026	2	Health Suite	In health suite in dental suite 227 Left	WF-03242025-012336	12/5/2025	FT-FY26-12012025-012336-A	<2	FT-FY26-12012025-012336-B	<2
WS-012337	3/24/2025	3/24/2026	2	Health Suite	In health suite lab room 225E	WF-03242025-012337	12/5/2025	FT-FY26-12012025-012337-A	<2	FT-FY26-12012025-012337-B	<2
WS-012338	3/24/2025	3/24/2026	2	Health Suite	In health suite 227	WF-03242025-012338	12/5/2025	FT-FY26-12012025-012338-A	<2	FT-FY26-12012025-012338-B	<2
WS-012339	3/24/2025	3/24/2026	2	Health Suite	In health suite in dental suite 227 (handwash sink) Right	WF-03242025-012339	12/5/2025	FT-FY26-12012025-012339-A	<2	FT-FY26-12012025-012339-B	<2
WS-012340	3/24/2025	3/24/2026	2	Health Suite	In health suite in exam room 225D	WF-03242025-012340	12/5/2025	FT-FY26-12012025-012340-A	<2	FT-FY26-12012025-012340-B	<2
WS-012341	3/24/2025	3/24/2026	2	Health Suite	In health suite in exam room 225C	WF-03242025-012341	12/5/2025	FT-FY26-12012025-012341-A	<2	FT-FY26-12012025-012341-B	<2
WS-012342	3/24/2025	3/24/2026	2	Health Suite	In health suite in exam room 225A	WF-03242025-012342	12/5/2025	FT-FY26-12012025-012342-A	<2	FT-FY26-12012025-012342-B	<2

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012265	11/24/2025	11/24/2026	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-11242025-012265	12/5/2025	FT-FY26-12012025-012265-A	<2	FT-FY26-12012025-012265-B	<2
WS- 012266	11/24/2025	11/24/2026	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-11242025-012266	12/5/2025	FT-FY26-12012025-012266-A	<2	FT-FY26-12012025-012266-B	<2
WS- 012269	11/24/2025	11/24/2026	1	Food Prep Sink	In 121C in kitchen first clockwise from entry door	WF-11242025-012269	12/5/2025	FT-FY26-12012025-012269-A	<2	FT-FY26-12012025-012269-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.