



Dunbar HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005043	6/10/2019	6/10/2020	3	Cooler	In hallway adjacent to room 381	High Left	WF-06102019-005043	1/9/2020	FT-FY20-122019-005043-A	<1	FT-FY20-122019-005043-B	<1
WS- 005044	6/10/2019	6/10/2020	3	Cooler	In hallway adjacent to room 381	Low Right	WF-06102019-005044	1/9/2020	FT-FY20-122019-005044-A	<1	FT-FY20-122019-005044-B	<1
WS- 005045	6/10/2019	6/10/2020	3	Break Room	In break room 398		WF-06102019-005045	1/9/2020	FT-FY20-122019-005045-A	<1	FT-FY20-122019-005045-B	<1
WS- 005088	6/10/2019	6/10/2020	4	Cooler	In hallway adjacent to room 481	High Left	WF-06102019-005088	1/9/2020	FT-FY20-122019-005088-A	<1	FT-FY20-122019-005088-B	<1
WS- 005089	11/21/2019	11/21/2020	4	Cooler	In hallway adjacent to room 481	Low Right	WF-11212019-005089	1/9/2020	FT-FY20-122019-005089-A	<1	FT-FY20-122019-005089-B	<1
WS- 005090	11/21/2019	11/21/2020	4	Break Room	In break room 498		WF-11212019-005090	1/9/2020	FT-FY20-122019-005090-A	<1	FT-FY20-122019-005090-B	<1
WS- 005096	6/10/2019	6/10/2020	1	Break Room	In break room 117		WF-06102019-005096	1/9/2020	FT-FY20-122019-005096-A	<1	FT-FY20-122019-005096-B	<1
WS- 009164	6/10/2019	6/10/2020	4	Break Room	In break room 482A		WF-06102019-009164	1/9/2020	FT-FY20-122019-009164-A	<1	FT-FY20-122019-009164-B	<1
WS- 009166	6/10/2019	6/10/2020	2	Break Room	In break room in library		WF-06102019-009166	1/9/2020	FT-FY20-122019-009166-A	<1	FT-FY20-122019-009166-B	<1
WS- 012258	6/10/2019	6/10/2020	Basement	Cooler	In hallway adjacent to pool/060	Low Right	WF-06102019-012258	1/9/2020	FT-FY20-122019-012258-A	<1	FT-FY20-122019-012258-B	<1
WS- 012259	6/10/2019	6/10/2020	Basement	Cooler	In hallway adjacent to pool/060	High Left	WF-06102019-012259	1/9/2020	FT-FY20-122019-012259-A	<1	FT-FY20-122019-012259-B	<1
WS- 012260	11/21/2019	11/21/2020	1	Cooler	In hallway adjacent to room 162	High Left	WF-11212019-012260	1/9/2020	FT-FY20-122019-012260-A	<1	FT-FY20-122019-012260-B	<1
WS- 012261	11/22/2019	11/22/2020	1	Cooler	In hallway adjacent to room 162	Low Right	WF-11222019-012261	1/9/2020	FT-FY20-122019-012261-A	<1	FT-FY20-122019-012261-B	<1
WS- 012264	6/10/2019	6/10/2020	1	Classroom Faucet	In athletics training room 153		WF-06102019-012264	1/9/2020	FT-FY20-122019-012264-A	<1	FT-FY20-122019-012264-B	<1
WS- 012273	6/10/2019	6/10/2020	1	Break Room	In break room 198		WF-06102019-012273	1/9/2020	FT-FY20-122019-012273-A	<1	FT-FY20-122019-012273-B	<1
WS- 012275	6/10/2019	6/10/2020	1	Cooler	In hallway adjacent to room 197	Low Right	WF-06102019-012275	1/9/2020	FT-FY20-122019-012275-A	<1	FT-FY20-122019-012275-B	<1
WS- 012321	6/10/2019	6/10/2020	2	Cooler	In hallway across from room 297	High Left	WF-06102019-012321	1/9/2020	FT-FY20-122019-012321-A	<1	FT-FY20-122019-012321-B	<1
WS- 012322	6/10/2019	6/10/2020	2	Cooler	In hallway across from room 297	Low Right	WF-06102019-012322	1/9/2020	FT-FY20-122019-012322-A	<1	FT-FY20-122019-012322-B	<1
WS- 012323	6/10/2019	6/10/2020	2	Break Room	In break room 298		WF-06102019-012323	1/9/2020	FT-FY20-122019-012323-A	<1	FT-FY20-122019-012323-B	<1
WS- 012326	6/10/2019	6/10/2020	2	Cooler	In hallway adjacent to gym 260	High Left	WF-06102019-012326	1/9/2020	FT-FY20-122019-012326-A	<1	FT-FY20-122019-012326-B	<1
WS- 012327	6/10/2019	6/10/2020	2	Cooler	In hallway adjacent to gym 260	Low Right	WF-06102019-012327	1/9/2020	FT-FY20-122019-012327-A	<1	FT-FY20-122019-012327-B	<1
WS- 012328	6/10/2019	6/10/2020	2	Cooler	In gym 260	High Left	WF-06102019-012328	1/9/2020	FT-FY20-122019-012328-A	<1	FT-FY20-122019-012328-B	<1
WS- 012329	6/10/2019	6/10/2020	2	Cooler	In gym 260	Low Right	WF-06102019-012329	1/9/2020	FT-FY20-122019-012329-A	<1	FT-FY20-122019-012329-B	<1
WS- 012330	6/10/2019	6/10/2020	2	Break Room	In break room 251 (gym physical education office)		WF-06102019-012330	1/9/2020	FT-FY20-122019-012330-A	<1	FT-FY20-122019-012330-B	<1
WS- 012332	6/10/2019	6/10/2020	2	Break Room	In break room 254		WF-06102019-012332	1/9/2020	FT-FY20-122019-012332-A	<1	FT-FY20-122019-012332-B	<1
WS- 012334	6/10/2019	6/10/2020	2	Health Suite	In health suite in break room 228		WF-06102019-012334	1/9/2020	FT-FY20-122019-012334-A	<1	FT-FY20-122019-012334-B	<1
WS- 012336	6/10/2019	6/10/2020	2	Health Suite	In health suite in dental suite 227	Left	WF-06102019-012336	1/9/2020	FT-FY20-122019-012336-A	<1	FT-FY20-122019-012336-B	<1
WS- 012337	6/10/2019	6/10/2020	2	Health Suite	In health suite lab room 225E		WF-06102019-012337	1/9/2020	FT-FY20-122019-012337-A	<1	FT-FY20-122019-012337-B	<1
WS- 012338	6/10/2019	6/10/2020	2	Health Suite	In health suite 227		WF-06102019-012338	1/9/2020	FT-FY20-122019-012338-A	1.2	FT-FY20-122019-012338-B	<1
WS- 012339	6/10/2019	6/10/2020	2	Health Suite	In health suite in dental suite 227 (handwash sink)	Right	WF-06102019-012339	1/9/2020	FT-FY20-122019-012339-A	2	FT-FY20-122019-012339-B	<1
WS- 012340	6/10/2019	6/10/2020	2	Health Suite	In health suite in exam room 225D		WF-06102019-012340	1/9/2020	FT-FY20-122019-012340-A	1.7	FT-FY20-122019-012340-B	<1
WS- 012341	6/10/2019	6/10/2020	2	Health Suite	In health suite in exam room 225C		WF-06102019-012341	1/9/2020	FT-FY20-122019-012341-A	<1	FT-FY20-122019-012341-B	<1
WS- 012342	6/10/2019	6/10/2020	2	Health Suite	In health suite in exam room 225A		WF-06102019-012342	1/9/2020	FT-FY20-122019-012342-A	<1	FT-FY20-122019-012342-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012265	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-07222019-012265	1/9/2020	FT-FY20-122019-012265-A	<1	FT-FY20-122019-012265-B	<1
WS- 012266	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-07222019-012266	1/9/2020	FT-FY20-122019-012266-A	<1	FT-FY20-122019-012266-B	<1
WS- 012269	7/22/2019	7/22/2020	1	Food Prep Sink	In 121C in kitchen first clockwise from entry door	WF-07222019-012269	1/9/2020	FT-FY20-122019-012269-A	<1	FT-FY20-122019-012269-B	<1
WS- 012272	7/22/2019	7/22/2020	1	Food Prep Sink	In 121C in kitchen fourth clockwise from entry door	WF-07222019-012272	1/9/2020	FT-FY20-122019-012272-A	<1	FT-FY20-122019-012272-B	<1