



DUNBAR LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012346	Classroom	3	in class room 385 clockwise sink 4	WT-042916-12363- A	3.1	WT-042916-12363- B	< 1			
2	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012345	Classroom	3	in classroom 385 clockwise sink 3	WT-042916-12362- A	2.4	WT-042916-12362- B	< 1			
3	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012344	Classroom	3	in classroom 385 second sink clockwise	WT-042916-12361- A	< 1	WT-042916-12361- B	< 1			
4	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012343	Classroom	3	in class room 385 clockwise sink 1	WT-042916-12360- A	< 1	WT-042916-12360- B	< 1			
5	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012342	Health Suite	2	in room 225A	WT-042916-12359- A	1.5	WT-042916-12359- B	< 1			
6	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012341	Health Suite	2	in exam room 225C	WT-042916-12358- A	10.4	WT-042916-12358- B	< 1			
7	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012340	Health Suite	2	in health suite exam room 225D	WT-042916-12357- A	10	WT-042916-12357- B	< 1			
8	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012339	Health Suite	2	in health suite dental office 227 hand washing sink	WT-042916-12356- A	12.7	WT-042916-12356- B	< 1			
9	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012338	Health Suite	2	in room 227 hand wash station 1 clockwise	WT-042916-12355- A	4.6	WT-042916-12355- B	1.2			
10	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012337	Health Suite	2	in health suite laboratory room 225E	WT-042916-12354- A	< 1	WT-042916-12354- B	< 1			
11	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012336	Health Suite	2	in room 227 dental suite	WT-042916-12353- A	5.8	WT-042916-12353- B	< 1			
12	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012335	Break Room	2	in health suite break room 228 ice machine	WT-042916-12352- A	< 1	WT-042916-12352- B	< 1			
13	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012334	Break Room	2	in health suite break room 228	WT-042916-12351- A	< 1	WT-042916-12351- B	< 1			
14	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012333	Classroom	2	in class room 244	WT-042916-12350- A	1	WT-042916-12350- B	< 1			
15	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012332	Break Room	2	in room 254	WT-042916-12349- A	< 1	WT-042916-12349- B	< 1			
16	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012331	Break Room	2	in 251A ice maker	WT-042916-12348- A	< 1	WT-042916-12348- B	< 1			
17	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012330	Break Room	2	in room 251	WT-042916-12347- A	< 1	WT-042916-12347- B	< 1			
18	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012329	Cooler	2	in gymnasium 26	Right Low	WT-042916-12346- A	< 1	WT-042916-12346- B	< 1		
19	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012328	Fountain	2	in gymnasium 260	WT-042916-12345- A	< 1	WT-042916-12345- B	< 1			
20	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012327	Cooler	2	in hallway adjusted to the gymnasium 260	Right Low	WT-042916-12344- A	< 1	WT-042916-12344- B	< 1		
21	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012326	Cooler	2	in hallway adjacent to gymnasium 260	Left High	WT-042916-12343- A	< 1	WT-042916-12343- B	< 1		
22	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012325	Classroom	2	in room 221	WT-042916-12342- A	< 1	WT-042916-12342- B	< 1			
23	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012324	Break Room	2	in break room 298 ice maker	WT-042916-12341- A	6.3	WT-042916-12341- B	< 1			
24	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012323	Break Room	2	in break room 298	WT-042916-12340- A	< 1	WT-042916-12340- B	< 1			
25	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012322	Cooler	2	in hallway across to the room 297	Right Low	WT-042916-12339- A	< 1	WT-042916-12339- B	< 1		
26	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012321	Cooler	2	in hallway across to the 297	Left High	WT-042916-12338- A	< 1	WT-042916-12338- B	< 1		
27	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012320	Classroom	2	in science prep 285A ice machine	WT-042916-12337- A	5.7	WT-042916-12337- B	5.8			
28	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012319	Classroom	1	in prep room 282A	WT-042916-12336- A	< 1	WT-042916-12336- B	< 1			
29	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012318	Classroom	2	in class room 282 adjusted to room 282A	WT-042916-12335- A	1.5	WT-042916-12335- B	< 1			
30	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012317	Classroom	1	in classroom 282 seventh sink clockwise	WT-042916-12334- A	1.7	WT-042916-12334- B	< 1			
31	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012316	Classroom	2	in classroom 282 clockwise sink 6	WT-042916-12333- A	1.9	WT-042916-12333- B	< 1			
32	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012315	Classroom	1	in classroom 282 fifth sink clockwise	WT-042916-12332- A	2.7	WT-042916-12332- B	< 1			
33	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012314	Classroom	2	in classroom 282 clockwise sink 4	WT-042916-12331- A	2.5	WT-042916-12331- B	< 1			
34	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012313	Classroom	1	in classroom 282 third sink clockwise	WT-042916-12330- A	3.1	WT-042916-12330- B	< 1			
35	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012312	Classroom	2	in class room 282 clockwise sink 2	WT-042916-12329- A	1.3	WT-042916-12329- B	< 1			
36	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012311	Classroom	2	in class room 282 clockwise sink 1	WT-042916-12328- A	< 1	WT-042916-12328- B	< 1			
37	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012310	Classroom	1	in classroom 284 second sink clockwise	WT-042916-12327- A	1.4	WT-042916-12327- B	< 1			
38	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012309	Classroom	2	in class room 284 clockwise sink 1	WT-042916-12326- A	< 1	WT-042916-12326- B	< 1			
39	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012308	Classroom	2	in prep room 285A	WT-042916-12325- A	1.7	WT-042916-12325- B	< 1			
40	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012307	Classroom	2	in classroom 285 clockwise sink 7	WT-042916-12324- A	2.1	WT-042916-12324- B	< 1			
41	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012306	Classroom	2	in class room 285 clockwise sink 6	WT-042916-12323- A	< 1	WT-042916-12323- B	< 1			
42	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012305	Classroom	2	in classroom 285 clockwise sink 5	WT-042916-12322- A	3.3	WT-042916-12322- B	< 1			
43	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012304	Classroom	1	in classroom 285 fourth sink clockwise	WT-042916-12321- A	2.2	WT-042916-12321- B	< 1			
44	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012303	Classroom	2	in classroom 285 clockwise sink 3	WT-042916-12320- A	1.4	WT-042916-12320- B	< 1			
45	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012302	Classroom	2	in class room 285 clockwise 2	WT-042916-12319- A	2.6	WT-042916-12319- B	< 1			
46	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012301	Classroom	2	in classroom 285 first sink clockwise	WT-042916-12318- A	2	WT-042916-12318- B	< 1			
47	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012300	Classroom	1	in science prep room 184A	Right	WT-042916-12317- A	5.2	WT-042916-12317- B	< 1		
48	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012299	Classroom	1	in class room 185 clockwise 7	WT-042916-12316- A	4	WT-042916-12316- B	< 1			
49	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012298	Classroom	1	in classroom 185 sixth sink clockwise	WT-042916-12315- A	5.7	WT-042916-12315- B	< 1			
50	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012297	Classroom	1	in classroom 185 fifth sink clockwise	WT-042916-12314- A	14.2	WT-042916-12314- B	< 1			
51	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012296	Classroom	1	in class room 185 clockwise sink 5	WT-042916-12313- A	17.6	WT-042916-12313- B	< 1	Filter will be installed and then retested		
52	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012295	Classroom	1	in classroom 185 third sink clockwise	WT-042916-12312- A	7.6	WT-042916-12312- B	< 1			
53	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012294	Classroom	1	in class room 185 clockwise sink 2	WT-042916-12311- A	8.3	WT-042916-12311- B	< 1			



DUNBAR LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
54	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012293	Classroom	1	in class room 185 clockwise sink 1	WT-042916-12310- A	< 1	WT-042916-12310- B	1.6			
55	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012291	Classroom	1	in science prep room 183A	WT-042916-12308- A	3.1	WT-042916-12308- B	< 1			
56	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012290	Classroom	1	in science prep room 184A	WT-042916-12307- A	7	WT-042916-12307- B	< 1			
57	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012289	Classroom	1	in classroom 184 seventh sink clockwise	WT-042916-12306- A	5.7	WT-042916-12306- B	< 1			
58	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012288	Classroom	1	in class room 184 clockwise sink 6	WT-042916-12305- A	3.1	WT-042916-12305- B	< 1			
59	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012287	Classroom	1	in classroom 184 clockwise sink 5	WT-042916-12304- A	< 1	WT-042916-12304- B	< 1			
60	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012286	Classroom	1	in classroom 184 fourth sink clockwise	WT-042916-12303- A	2.2	WT-042916-12303- B	1			
61	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012285	Classroom	1	in classroom 184 clockwise sink 2	WT-042916-12302- A	< 1	WT-042916-12302- B	< 1			
62	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012284	Classroom	1	in class room 184 clockwise sink 3	WT-042916-12301- A	< 1	WT-042916-12301- B	< 1			
63	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012283	Classroom	1	in class room 183 clockwise 7	WT-042916-12300- A	2.2	WT-042916-12300- B	< 1			
64	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012282	Classroom	1	in classroom 183 sixth sink clockwise	WT-042916-12299- A	3.6	WT-042916-12299- B	< 1			
65	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012281	Classroom	1	in classroom 184 first sink clockwise	WT-042916-12298- A	2.6	WT-042916-12298- B	1.9			
66	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012280	Classroom	1	in class room 183 clockwise sink 5	WT-042916-12297- A	1.9	WT-042916-12297- B	< 1			
67	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012279	Classroom	1	in classroom 183 clockwise sink 4	WT-042916-12296- A	2.9	WT-042916-12296- B	< 1			
68	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012278	Classroom	1	in classroom 183 clockwise sink 3	WT-042916-12295- A	6.8	WT-042916-12295- B	5.3			
69	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012277	Classroom	1	in classroom 183 second sink clockwise	WT-042916-12294- A	2.8	WT-042916-12294- B	< 1			
70	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012276	Classroom	1	in classroom 183 first sink clockwise	WT-042916-12293- A	17.4	WT-042916-12293- B	< 1	Filter will be installed and then retested		
71	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012275	Cooler	1	in hallway across 197 Right Low	WT-042916-12292- A	2.5	WT-042916-12292- B	< 1			
72	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012274	Cooler	1	in hallway adjacent to room 197 Left High	WT-042916-12291- A	< 1	WT-042916-12291- B	< 1			
73	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012273	Break Room	1	in break room 198	WT-042916-12290- A	< 1	WT-042916-12290- B	< 1			
74	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012272	Kitchen	1	in dish room 121C fourth sink clockwise	WT-042916-12289- A	< 1	WT-042916-12289- B	< 1			
75	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012271	Kitchen	1	in kitchen clockwise sink 3 room 121C Mid	WT-042916-12288- A	< 1	WT-042916-12288- B	< 1			
76	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012270	Kitchen	1	in kitchen coolwise sink second in room 121c	WT-042916-12287- A	< 1	WT-042916-12287- B	< 1			
77	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012269	Kitchen	1	in dish room 121C first sink clockwise	WT-042916-12286- A	14.9	WT-042916-12286- B	6.9			
78	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012268	Kitchen	1	in kitchen sink 3	WT-042916-12285- A	< 1	WT-042916-12285- B	< 1			
79	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012267	Kitchen	1	in kitchen ice machine	WT-042916-12284- A	< 1	WT-042916-12284- B	< 1			
80	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012266	Kitchen	1	in kitchen second sink	WT-042916-12283- A	< 1	WT-042916-12283- B	< 1			
81	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012265	Kitchen	1	in kitchen first sink	WT-042916-12282- A	< 1	WT-042916-12282- B	< 1			
82	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012264	Classroom	1	in training room 153	WT-042916-12281- A	< 1	WT-042916-12281- B	< 1			
83	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012263	Other	1	in training room 153 ice machine	WT-042916-12280- A	< 1	WT-042916-12280- B	< 1			
84	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012262	Other	1	in concession room 162	WT-042916-12279- A	3.7	WT-042916-12279- B	< 1			
85	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012261	Cooler	1	in hallway adjacent to concession stand room 162 Right Low	WT-042916-12278- A	< 1	WT-042916-12278- B	1.8			
86	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012260	Cooler	1	in hallway adjacent to concession stand 162 Left High	WT-042916-12277- A	< 1	WT-042916-12277- B	< 1			
87	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012259	Cooler	Basement	in hallway adjacent to pool/060	WT-042916-12276- A	< 1	WT-042916-12276- B	< 1			
88	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012258	Cooler	Basement	in hallway adjacent POOL/060 Low	WT-042916-12275- A	< 1	WT-042916-12275- B	< 1			
89	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012257	Other	Basement	in daycare center room 040	WT-042916-12274- A	< 1	WT-042916-12274- B	< 1			
90	DUNBAR HIGH SCHOOL	5/18/2016	WS- 012256	Utility	Basement	in room 037	WT-042916-12273- A	1.9	WT-042916-12273- B	< 1			
91	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005096	Break Room	1	in break room 117	WT-042916-5113- A	< 1	WT-042916-5113- B	< 1			
92	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005095	Break Room	1	in break room 117 ice machine	WT-042916-5112- A	< 1	WT-042916-5112- B	< 1			
93	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005094	Classroom	1	in science prep room 184A	WT-042916-5111- A	< 1	WT-042916-5111- B	< 1			
94	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005093	Classroom	1	in science prep room 183A	WT-042916-5110- A	3.4	WT-042916-5110- B	3			
95	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005092	Break Room	1	in break room 198 ice machine	WT-042916-5109- A	< 1	WT-042916-5109- B	< 1			
96	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005091	Break Room	4	in the break room 489 ice machine	WT-042916-5108- A	< 1	WT-042916-5108- B	< 1			
97	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005090	Break Room	4	in break room 498	WT-042916-5107- A	< 1	WT-042916-5107- B	< 1			
98	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005089	Cooler	4	in hallway across from classroom 497	WT-042916-5106- A	< 1	WT-042916-5106- B	< 1			
99	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005088	Cooler	4	in hallway adjacent to room 479 Left High	WT-042916-5105- A	< 1	WT-042916-5105- B	< 1			
100	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005087	Classroom	4	in class room 484 furthest island from entry door eighth sink clockwise from front left sink	WT-042916-5104- A	27.7	WT-042916-5104- B	< 1	Filter will be installed and then retested		
101	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005086	Classroom	4	in classroom 484 island 2 seventh sink clockwise	WT-042916-5103- A	6.2	WT-042916-5103- B	2.4			
102	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005085	Classroom	4	in classroom 484 island 2 clockwise 6	WT-042916-5102- A	< 1	WT-042916-5102- B	< 1			



DUNBAR LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
103	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005084	Classroom	4	In class room 484 furthest island from entry door fifth sink clockwise from front left sink	WT-042916-5101- A	11.9	WT-042916-5101- B	< 1				
104	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005083	Classroom	4	In classroom 484 island 2 clockwise 4	WT-042916-5100- A	6.3	WT-042916-5100- B	< 1				
105	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005082	Classroom	4	In classroom 484 island 2 third sink clockwise	WT-042916-5099- A	< 1	WT-042916-5099- B	< 1				
106	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005081	Classroom	4	In classroom 484 island 2 second sink clockwise	WT-042916-5098- A	4	WT-042916-5098- B	< 1				
107	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005080	Classroom	4	In classroom 484 island 2 clockwise 1	WT-042916-5097- A	3.6	WT-042916-5097- B	< 1				
108	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005079	Classroom	4	In classroom 484 island 1 clockwise sink 8	WT-042916-5096- A	15.2	WT-042916-5096- B	< 1	Filter will be installed and then retested			
109	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005078	Classroom	4	In class room 484, closest island to entry door sixth sink clockwise from front left sink	WT-042916-5095- A	1.7	WT-042916-5095- B	1.8				
110	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005077	Classroom	4	In class room 484 island 1 clockwise sink 5	WT-042916-5094- A	12.3	WT-042916-5094- B	< 1				
111	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005076	Classroom	4	In classroom 484 island 1 clockwise sink 7	WT-042916-5093- A	6.1	WT-042916-5093- B	< 1				
112	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005075	Classroom	4	In classroom 484 island 1 clockwise sink 4	WT-042916-5092- A	10.2	WT-042916-5092- B	4.4				
113	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005074	Classroom	4	In classroom 484 island 1 third sink clockwise	WT-042916-5091- A	7	WT-042916-5091- B	< 1				
114	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005073	Classroom	4	In classroom 484 island 1 second sink clockwise	WT-042916-5090- A	2.8	WT-042916-5090- B	< 1				
115	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005072	Classroom	4	In classroom 484 island 1 clockwise sink 1	WT-042916-5089- A	2.2	WT-042916-5089- B	< 1				
116	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005071	Classroom	4	In class room 484 clockwise sink 3	WT-042916-5088- A	170	WT-042916-5088- B	< 1	Filter will be installed and then retested			
117	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005070	Classroom	4	In classroom 484 second sink counterclockwise	WT-042916-5087- A	571	WT-042916-5087- B	9.9	Filter will be installed and then retested			
118	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005069	Classroom	4	In classroom 484 counterclockwise sink 1	WT-042916-5086- A	1.3	WT-042916-5086- B	1.2				
119	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005068	Classroom	4	In room 485 A/ ice machine	WT-042916-5085- A	< 1	WT-042916-5085- B	< 1				
120	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005067	Classroom	4	In science prep room 485A Left	WT-042916-5084- A	4.2	WT-042916-5084- B	< 1				
121	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005066	Classroom	5	In science prep room 485A Right	WT-042916-5083- A	5.5	WT-042916-5083- B	< 1				
122	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005065	Classroom	4	In classroom 485 island 2 eighth sink clockwise	WT-042916-5082- A	6.7	WT-042916-5082- B	< 1				
123	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005064	Classroom	4	In classroom 485 island 2 seventh sink clockwise	WT-042916-5081- A	11.7	WT-042916-5081- B	< 1				
124	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005063	Classroom	4	In class room 485 island 2 clockwise 6	WT-042916-5080- A	1.4	WT-042916-5080- B	4				
125	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005062	Classroom	4	In classroom 485 island 2 fifth sink clockwise	WT-042916-5079- A	3.8	WT-042916-5079- B	< 1				
126	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005061	Classroom	4	In room 485 island 2 sink 4	WT-042916-5078- A	8	WT-042916-5078- B	1.6				
127	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005060	Classroom	4	In class room 485 island clockwise sink 3	WT-042916-5077- A	11.8	WT-042916-5077- B	1.7				
128	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005059	Classroom	4	In classroom 485 island 2 second sink clockwise	WT-042916-5076- A	6.7	WT-042916-5076- B	< 1				
129	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005058	Classroom	4	In classroom 485 island 2 third sink clockwise	WT-042916-5075- A	4	WT-042916-5075- B	1.2				
130	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005057	Classroom	4	In class room 485 island 2 sink 7	WT-042916-5074- A	9.7	WT-042916-5074- B	< 1				
131	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005056	Classroom	4	In room 485 island 1 clockwise sink 8	WT-042916-5073- A	2.5	WT-042916-5073- B	< 1				
132	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005055	Classroom	3	In classroom 485 island 1 sixth sink clockwise	WT-042916-5072- A	3.9	WT-042916-5072- B	< 1				
133	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005054	Classroom	4	In room 485 island 1 clockwise sink 5	WT-042916-5071- A	3.3	WT-042916-5071- B	< 1				
134	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005053	Classroom	4	In class room 485 Island 1 sink 4	WT-042916-5070- A	8.3	WT-042916-5070- B	< 1				



DUNBAR LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
135	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005052	Classroom	4	in classroom 485 island 1 second sink clockwise	WT-042916-5069- A	1.2	WT-042916-5069- B	< 1				
136	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005051	Classroom	4	in room 485 island 1 clockwise sink 1	WT-042916-5068- A	12.3	WT-042916-5068- B	< 1				
137	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005050	Classroom	4	in room 485 island 1 clockwise sink 4	WT-042916-5067- A	2.6	WT-042916-5067- B	< 1				
138	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005049	Classroom	4	in class room 485 clockwise sink 3	WT-042916-5066- A	6.8	WT-042916-5066- B	1.2				
139	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005048	Classroom	4	in classroom 485 second sink clockwise	WT-042916-5065- A	8.9	WT-042916-5065- B	< 1				
140	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005047	Classroom	4	in class room 485 clockwise sink 1	WT-042916-5064- A	3.2	WT-042916-5064- B	5.7				
141	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005046	Break Room	3	in break room 398 icemaker	WT-042916-5063- A	< 1	WT-042916-5063- B	< 1				
142	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005045	Break Room	3	in break room 398	WT-042916-5062- A	< 1	WT-042916-5062- B	< 1				
143	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005044	Cooler	3	in hallway across to the 397	WT-042916-5061- A	< 1	WT-042916-5061- B	< 1				
144	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005043	Cooler	3	in hallway adjacent to room 397	WT-042916-5060- A	< 1	WT-042916-5060- B	< 1				
145	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005042	Classroom	3	in class room 385 clockwise sink 7	WT-042916-5059- A	4.2	WT-042916-5059- B	< 1				
146	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005041	Classroom	3	in classroom 384 clockwise sink 6	WT-042916-5058- A	3.4	WT-042916-5058- B	< 1				
147	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005040	Classroom	3	in classroom 384 fifth sink clockwise	WT-042916-5057- A	3.8	WT-042916-5057- B	< 1				
148	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005039	Classroom	3	in class room 385 clockwise sink 4	WT-042916-5056- A	2.5	WT-042916-5056- B	< 1				
149	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005038	Classroom	3	in classroom 384 third sink clockwise	WT-042916-5055- A	1.6	WT-042916-5055- B	< 1				
150	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005037	Classroom	3	in class room 384 clockwise sink 2	WT-042916-5054- A	2.7	WT-042916-5054- B	< 1				
151	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005036	Classroom	3	in classroom 384 first sink clockwise	WT-042916-5053- A	1.8	WT-042916-5053- B	< 1				
152	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005035	Classroom	3	in prep room 384/385A icemaker	WT-042916-5052- A	< 1	WT-042916-5052- B	< 1				
153	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005034	Classroom	3	in class room pepper room 384/	WT-042916-5051- A	4	WT-042916-5051- B	1.3				
154	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005033	Classroom	3	in prep room 384/385A	WT-042916-5050- A	4.7	WT-042916-5050- B	< 1				
155	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005032	Classroom	3	in class room 385 clockwise sink 7	WT-042916-5049- A	< 1	WT-042916-5049- B	< 1				
156	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005031	Classroom	3	in classroom 385 clockwise sink 6	WT-042916-5048- A	6.6	WT-042916-5048- B	< 1				
157	DUNBAR HIGH SCHOOL	5/18/2016	WS- 005030	Classroom	3	in classroom 385 fifth sink clockwise	WT-042916-5047- A	2.6	WT-042916-5047- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.