



EASTERN HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	EASTERN HIGH SCHOOL	WS- 002336	8/19/2016	1	Fountain	In classroom W143 Right	FT-82016-002336-A	< 1	FT-82016-002336-B	< 1
2	EASTERN HIGH SCHOOL	WS- 002345	8/19/2016	1	Fountain	In classroom W143 Left	FT-82016-002345-A	< 1	FT-82016-002345-B	< 1
3	EASTERN HIGH SCHOOL	WS- 008289	8/19/2016	Ground Floor	Fountain	In athletic field adjacent to restroom	FT-82016-008289-A	< 1	FT-82016-008289-B	< 1
4	EASTERN HIGH SCHOOL	WS- 010709	8/19/2016	1	Health Suite	In health suite W130	FT-82016-010709-A	< 1	FT-82016-010709-B	< 1
5	EASTERN HIGH SCHOOL	WS- 010711	8/19/2016	1	Health Suite	In lab room W129 in health suite	FT-82016-010711-A	< 1	FT-82016-010711-B	< 1
6	EASTERN HIGH SCHOOL	WS- 010712	8/19/2016	1	Health Suite	In exam room W128 in health suite	FT-82016-010712-A	< 1	FT-82016-010712-B	< 1
7	EASTERN HIGH SCHOOL	WS- 010713	8/19/2016	1	Health Suite	In health suite W131	FT-82016-010713-A	< 1	FT-82016-010713-B	< 1
8	EASTERN HIGH SCHOOL	WS- 010714	8/19/2016	1	Health Suite	In exam room W134 in health suite	FT-82016-010714-A	< 1	FT-82016-010714-B	< 1
9	EASTERN HIGH SCHOOL	WS- 010716	8/19/2016	1	Cooler	In hallway across from room W130 Low Right	FT-82016-010716-A	< 1	FT-82016-010716-B	< 1
10	EASTERN HIGH SCHOOL	WS- 010717	8/19/2016	1	Bottle Filler	In hallway across from room W130 (bottle filler)	FT-82016-010717-A	< 1	FT-82016-010717-B	< 1
11	EASTERN HIGH SCHOOL	WS- 010718	8/19/2016	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door	FT-72016-010718-A	< 1	FT-72016-010718-B	< 1
12	EASTERN HIGH SCHOOL	WS- 010720	8/19/2016	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door Right	FT-82016-010720-A	< 1	FT-82016-010720-B	< 1
13	EASTERN HIGH SCHOOL	WS- 010721	8/19/2016	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door Left	FT-82016-010721-A	< 1	FT-82016-010721-B	< 1
14	EASTERN HIGH SCHOOL	WS- 010722	8/19/2016	Ground Floor	Cooler	In cafeteria Low Right	FT-82016-010722-A	< 1	FT-82016-010722-B	< 1
15	EASTERN HIGH SCHOOL	WS- 010723	8/19/2016	Ground Floor	Cooler	In cafeteria High Left	FT-82016-010723-A	< 1	FT-82016-010723-B	< 1
16	EASTERN HIGH SCHOOL	WS- 010730	8/19/2016	1	Cooler	In hallway adjacent to room E124	FT-82016-010730-A	< 1	FT-82016-010730-B	< 1
17	EASTERN HIGH SCHOOL	WS- 010766	8/19/2016	1	Cooler	In hallway across from gym High Left	FT-82016-010766-A	< 1	FT-82016-010766-B	< 1
18	EASTERN HIGH SCHOOL	WS- 010767	8/19/2016	1	Cooler	In hallway across from gym Low Right	FT-82016-010767-A	< 1	FT-82016-010767-B	< 1
19	EASTERN HIGH SCHOOL	WS- 010768	8/19/2016	2	Cooler	In hallway across from room E218 Low Left	FT-82016-010768-A	< 1	FT-82016-010768-B	< 1
20	EASTERN HIGH SCHOOL	WS- 010769	8/19/2016	2	Bottle Filler	In hallway across from room E218 (bottle filler) High	FT-82016-010769-A	< 1	FT-82016-010769-B	< 1
21	EASTERN HIGH SCHOOL	WS- 010775	8/19/2016	2	Cooler	In hallway adjacent room E227	FT-82016-010775-A	< 1	FT-82016-010775-B	< 1
22	EASTERN HIGH SCHOOL	WS- 010783	8/19/2016	2	Cooler	In hallway across from room W212 High Left	FT-82016-010783-A	< 1	FT-82016-010783-B	< 1
23	EASTERN HIGH SCHOOL	WS- 010784	8/19/2016	2	Cooler	In hallway across from room W212 Low Right	FT-82016-010784-A	< 1	FT-82016-010784-B	< 1
24	EASTERN HIGH SCHOOL	WS- 010789	8/19/2016	3	Cooler	In hallway across from room E316 Low Right	FT-82016-010789-A	< 1	FT-82016-010789-B	< 1
25	EASTERN HIGH SCHOOL	WS- 010790	8/19/2016	3	Cooler	In hallway across from room E316 High Left	FT-82016-010790-A	< 1	FT-82016-010790-B	< 1
26	EASTERN HIGH SCHOOL	WS- 010793	8/19/2016	3	Cooler	In hallway across from room W311 High Left	FT-82016-010793-A	< 1	FT-82016-010793-B	< 1
27	EASTERN HIGH SCHOOL	WS- 010794	8/19/2016 10/10/2016	2	Cooler	In hallway across from room W311 Low Right	FT-82016-010794-A Re-test A	< 1 < 1	FT-82016-010794-B Re-test B	1.32 < 1
28	EASTERN HIGH SCHOOL	WS- 010838	8/19/2016	4	Cooler	In hallway across from room W411 Low Right	FT-82016-010838-A	< 1	FT-82016-010838-B	< 1
29	EASTERN HIGH SCHOOL	WS- 010839	8/19/2016	4	Cooler	In hallway across from room W411 High Left	FT-82016-010839-A	< 1	FT-82016-010839-B	< 1
30	EASTERN HIGH SCHOOL	WS- 011887	8/19/2016 10/10/2016	4	Cooler	In hallway across from room E415 High Left	FT-82016-011887-A Re-test A	< 1 < 1	FT-82016-011887-B Re-test B	1.13 < 1
31	EASTERN HIGH SCHOOL	WS- 011888	8/19/2016	4	Cooler	In hallway across from room E415 Low Right	FT-82016-011888-A	< 1	FT-82016-011888-B	< 1
32	EASTERN HIGH SCHOOL	WS- 011892	8/19/2016	Ground Floor	Ice Maker	In kitchen (ice maker)	FT-82016-011892-A	< 1	FT-82016-011892-B	< 1
33	EASTERN HIGH SCHOOL	WS- 011893	8/19/2016	Ground Floor	Other	In concessions G106 (sink)	FT-72016-011893-A	< 1	FT-72016-011893-B	< 1