



Eastern High School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002339	3/29/2021	3/29/2022	1	Break Room	In break room W143 Right	WF-03292021-002339	3/24/2022	FT-FY22-02212022-002339-A	<1	FT-FY22-02212022-002339-B	<1
WS-002342	3/29/2021	3/29/2022	1	Break Room	In break room W143 Left	WF-03292021-002342	3/24/2022	FT-FY22-02212022-002342-A	<1	FT-FY22-02212022-002342-B	<1
WS-010709	3/29/2021	3/29/2022	1	Health Suite	In health suite W130	WF-03292021-010709	3/24/2022	FT-FY22-02212022-010709-A	2.4	FT-FY22-02212022-010709-B	2.4
WS-010711	3/29/2021	3/29/2022	1	Health Suite	In health suite in lab room W129	WF-03292021-010711	3/24/2022	FT-FY22-02212022-010711-A	<1	FT-FY22-02212022-010711-B	1.6
WS-010712	3/29/2021	3/29/2022	1	Health Suite	In health suite in exam room W128	WF-03292021-010712	3/24/2022	FT-FY22-02212022-010712-A	<1	FT-FY22-02212022-010712-B	1.0
WS-010713	3/29/2021	3/29/2022	1	Health Suite	In health suite W131	WF-03292021-010713	3/24/2022	FT-FY22-02212022-010713-A	4.9	FT-FY22-02212022-010713-B	1.2
WS-010714	3/29/2021	3/29/2022	1	Health Suite	In health suite in exam room W134	WF-03292021-010714	3/24/2022	FT-FY22-02212022-010714-A	<1	FT-FY22-02212022-010714-B	<1
WS-010716	3/29/2021	3/29/2022	1	Cooler	In hallway across from room W130	WF-03292021-010716	3/24/2022	FT-FY22-02212022-010716-A	<1	FT-FY22-02212022-010716-B	<1
WS-010717	3/29/2021	3/29/2022	1	Bottle Filler	In hallway across from room W130 (bottle filler)	WF-03292021-010717	3/24/2022	FT-FY22-02212022-010717-A	<1	FT-FY22-02212022-010717-B	<1
WS-010722	3/29/2021	3/29/2022	Ground Floor	Cooler	In cafeteria Low Right	WF-03292021-010722	3/24/2022	FT-FY22-02212022-010722-A	<1	FT-FY22-02212022-010722-B	<1
WS-010723	3/29/2021	3/29/2022	Ground Floor	Cooler	In cafeteria High Left	WF-03292021-010723	3/24/2022	FT-FY22-02212022-010723-A	<1	FT-FY22-02212022-010723-B	<1
WS-010727	3/29/2021	3/29/2022	1	Break Room	In break room W110	WF-03292021-010727	3/24/2022	FT-FY22-02212022-010727-A	1.0	FT-FY22-02212022-010727-B	<1
WS-010730	3/29/2021	3/29/2022	1	Cooler	In hallway adjacent to room E124	WF-03292021-010730	3/24/2022	FT-FY22-02212022-010730-A	<1	FT-FY22-02212022-010730-B	<1
WS-010768	3/29/2021	3/29/2022	2	Cooler	In hallway across from room E218	WF-03292021-010768	3/24/2022	FT-FY22-02212022-010768-A	<1	FT-FY22-02212022-010768-B	<1
WS-010769	3/29/2021	3/29/2022	2	Bottle Filler	In hallway across from room E218 (bottle filler)	WF-03292021-010769	3/24/2022	FT-FY22-02212022-010769-A	<1	FT-FY22-02212022-010769-B	<1
WS-010775	3/29/2021	3/29/2022	2	Cooler	In hallway adjacent room E227	WF-03292021-010775	3/24/2022	FT-FY22-02212022-010775-A	<1	FT-FY22-02212022-010775-B	<1
WS-010783	3/29/2021	3/29/2022	2	Cooler	In hallway across from room W212 High Left	WF-03292021-010783	3/24/2022	FT-FY22-02212022-010783-A	<1	FT-FY22-02212022-010783-B	<1
WS-010784	3/29/2021	3/29/2022	2	Cooler	In hallway across from room W212 Low Right	WF-03292021-010784	3/24/2022	FT-FY22-02212022-010784-A	<1	FT-FY22-02212022-010784-B	<1
WS-010785	3/29/2021	3/29/2022	2	Break Room	In break room W209	WF-03292021-010785	3/24/2022	FT-FY22-02212022-010785-A	<1	FT-FY22-02212022-010785-B	<1
WS-010788	3/29/2021	3/29/2022	2	Break Room	In break room E211	WF-03292021-010788	3/24/2022	FT-FY22-02212022-010788-A	<1	FT-FY22-02212022-010788-B	<1
WS-010789	3/29/2021	3/29/2022	3	Cooler	In hallway across from room E316 Low Right	WF-03292021-010789	3/24/2022	FT-FY22-02212022-010789-A	<1	FT-FY22-02212022-010789-B	<1
WS-010790	3/29/2021	3/29/2022	3	Cooler	In hallway across from room E316 High Left	WF-03292021-010790	3/24/2022	FT-FY22-02212022-010790-A	<1	FT-FY22-02212022-010790-B	1.6
WS-010816	3/29/2021	3/29/2022	4	Break Room	In breakroom (former science prep room) W406	WF-03292021-010816	3/24/2022	FT-FY22-02212022-010816-A	<1	FT-FY22-02212022-010816-B	3.2
WS-010839	3/29/2021	3/29/2022	4	Cooler	In hallway across from room W411 High Left	WF-03292021-010839	3/24/2022	FT-FY22-02212022-010839-A	1.3	FT-FY22-02212022-010839-B	1.8
WS-010965	3/29/2021	3/29/2022	Basement	Cooler	In boys locker room	WF-03292021-010965	3/24/2022	FT-FY22-02212022-010965-A	<1	FT-FY22-02212022-010965-B	<1
WS-010966	3/29/2021	3/29/2022	Basement	Cooler	In girls locker room	WF-03292021-010966	3/24/2022	FT-FY22-02212022-010966-A	1.0	FT-FY22-02212022-010966-B	4.2
WS-011887	3/29/2021	3/29/2022	4	Cooler	In hallway across from room E415 High Left	WF-03292021-011887	3/24/2022	FT-FY22-02212022-011887-A	2.5	FT-FY22-02212022-011887-B	1.6
WS-011888	3/29/2021	3/29/2022	4	Cooler	In hallway across from room E415 Low Right	WF-03292021-011888	3/24/2022	FT-FY22-02212022-011888-A	3.2	FT-FY22-02212022-011888-B	<1
WS-011890	9/27/2021	9/27/2022	3	Break Room	In breakroom E307	WF-09272021-011890	3/24/2022	FT-FY22-02212022-011890-A	<1	FT-FY22-02212022-011890-B	2.2
WS-011894	9/27/2021	9/27/2022	4	Break Room	In break room E406	WF-09272021-011894	3/24/2022	FT-FY22-02212022-011894-A	<1	FT-FY22-02212022-011894-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010721	2/10/2022	2/10/2023	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door Left	WF-02102022-010721	3/24/2022	FT-FY22-02212022-010721-A	<1	FT-FY22-02212022-010721-B	<1