



Eastern High School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002339	3/21/2022	3/21/2023	1	Break Room	In break room W143	Right	WF-03212022-002339	2/13/2023	FT-FY23-01262023-002339-A	<1	FT-FY23-01262023-002339-B	<1
WS- 002342	3/21/2022	3/21/2023	1	Break Room	In break room W143	Left	WF-03212022-002342	2/13/2023	FT-FY23-01262023-002342-A	<1	FT-FY23-01262023-002342-B	<1
WS- 010711	3/21/2022	3/21/2023	1	Health Suite	In health suite in lab room W129		WF-03212022-010711	2/13/2023	FT-FY23-01262023-010711-A	<1	FT-FY23-01262023-010711-B	<1
WS- 010712	3/21/2022	3/21/2023	1	Health Suite	In health suite in exam room W128		WF-03212022-010712	2/13/2023	FT-FY23-01262023-010712-A	<1	FT-FY23-01262023-010712-B	<1
WS- 010713	3/21/2022	3/21/2023	1	Health Suite	In health suite W131		WF-03212022-010713	2/13/2023	FT-FY23-01262023-010713-A	<1	FT-FY23-01262023-010713-B	<1
WS- 010714	3/21/2022	3/21/2023	1	Health Suite	In health suite in exam room W134		WF-03212022-010714	2/13/2023	FT-FY23-01262023-010714-A	<1	FT-FY23-01262023-010714-B	<1
WS- 010716	3/21/2022	3/21/2023	1	Cooler	In hallway across from room W130		WF-03212022-010716	2/13/2023	FT-FY23-01262023-010716-A	<1	FT-FY23-01262023-010716-B	<1
WS- 010717	3/21/2022	3/21/2023	1	Bottle Filler	In hallway across from room W130 (bottle filler)		WF-03212022-010717	2/13/2023	FT-FY23-01262023-010717-A	<1	FT-FY23-01262023-010717-B	<1
WS- 010722	3/21/2022	3/21/2023	Ground Floor	Cooler	In cafeteria	Low Right	WF-03212022-010722	2/13/2023	FT-FY23-01262023-010722-A	<1	FT-FY23-01262023-010722-B	<1
WS- 010723	3/21/2022	3/21/2023	Ground Floor	Cooler	In cafeteria	High Left	WF-03212022-010723	2/13/2023	FT-FY23-01262023-010723-A	<1	FT-FY23-01262023-010723-B	<1
WS- 010727	3/21/2022	3/21/2023	1	Break Room	In break room W110		WF-03212022-010727	2/13/2023	FT-FY23-01262023-010727-A	<1	FT-FY23-01262023-010727-B	<1
WS- 010766	3/21/2022	3/21/2023	1	Cooler	In hallway across from gym	High Left	WF-03212022-010766	2/13/2023	FT-FY23-01262023-010766-A	<1	FT-FY23-01262023-010766-B	<1
WS- 010767	3/21/2022	3/21/2023	1	Cooler	In hallway across from gym	Low Right	WF-03212022-010767	2/13/2023	FT-FY23-01262023-010767-A	<1	FT-FY23-01262023-010767-B	<1
WS- 010768	1/26/2023	1/26/2024	2	Cooler	In hallway across from room E218		WF-01262023-010768	2/13/2023	FT-FY23-01262023-010768-A	<1	FT-FY23-01262023-010768-B	<1
WS- 010769	1/26/2023	1/26/2024	2	Bottle Filler	In hallway across from room E218 (bottle filler)		WF-01262023-010769	2/13/2023	FT-FY23-01262023-010769-A	<1	FT-FY23-01262023-010769-B	<1
WS- 010775	3/21/2022	3/21/2023	2	Cooler	In hallway adjacent room E227		WF-03212022-010775	2/13/2023	FT-FY23-01262023-010775-A	<1	FT-FY23-01262023-010775-B	<1
WS- 010785	3/21/2022	3/21/2023	2	Break Room	In break room W209		WF-03212022-010785	2/13/2023	FT-FY23-01262023-010785-A	<1	FT-FY23-01262023-010785-B	<1
WS- 010788	3/21/2022	3/21/2023	2	Break Room	In break room E211		WF-03212022-010788	2/13/2023	FT-FY23-01262023-010788-A	<1	FT-FY23-01262023-010788-B	<1
WS- 010789	3/21/2022	3/21/2023	3	Cooler	In hallway across from room E316	Low Right	WF-03212022-010789	2/13/2023	FT-FY23-01262023-010789-A	<1	FT-FY23-01262023-010789-B	<1
WS- 010790	3/21/2022	3/21/2023	3	Cooler	In hallway across from room E316	High Left	WF-03212022-010790	2/13/2023	FT-FY23-01262023-010790-A	<1	FT-FY23-01262023-010790-B	<1
WS- 010838	3/21/2022	3/21/2023	4	Cooler	In hallway across from room W411	Low Right	WF-03212022-010838	2/13/2023	FT-FY23-01262023-010838-A	<1	FT-FY23-01262023-010838-B	<1
WS- 010839	3/21/2022	3/21/2023	4	Cooler	In hallway across from room W411	High Left	WF-03212022-010839	2/13/2023	FT-FY23-01262023-010839-A	<1	FT-FY23-01262023-010839-B	<1
WS- 011887	3/21/2022	3/21/2023	4	Cooler	In hallway across from room E415	High Left	WF-03212022-011887	2/13/2023	FT-FY23-01262023-011887-A	<1	FT-FY23-01262023-011887-B	<1
WS- 011888	3/21/2022	3/21/2023	4	Cooler	In hallway across from room E415	Low Right	WF-03212022-011888	2/13/2023	FT-FY23-01262023-011888-A	<1	FT-FY23-01262023-011888-B	<1
WS- 011890	9/13/2022	9/13/2023	3	Break Room	In breakroom E307		WF-09132022-011890	2/13/2023	FT-FY23-01262023-011890-A	<1	FT-FY23-01262023-011890-B	<1
WS- 011894	9/13/2022	9/13/2023	4	Break Room	In break room E406		WF-09132022-011894	2/13/2023	FT-FY23-01262023-011894-A	<1	FT-FY23-01262023-011894-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010721	1/18/2023	1/18/2024	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	Left	WF-01182023-010721	2/13/2023	FT-FY23-01262023-010721-A	<1	FT-FY23-01262023-010721-B	<1

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010709	3/21/2022	3/21/2023	1	Health Suite	In health suite W130	WF-03212022-010709	2/13/2023	FT-FY23-01262023-010709-A	15.6	FT-FY23-01262023-010709-B	10.8

First Re-test (After Plumbing Check)

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010709	2/24/2023	2/24/2024	1	Health Suite	In health suite W130	WF-02242023-010709	3/7/2023	FT-FY23-02242023-010709-A	1.9	FT-FY23-02242023-010709-B	<1