



# EASTERN HS LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	EASTERN HIGH SCHOOL	WS- 010785	1/7/2017	2	Break Room	In break room W209	FT-102016-010785-A	< 1	FT-102016-010785-B	< 1
2	EASTERN HIGH SCHOOL	WS- 010727	1/7/2017	1	Break Room	In break room W110	FT-102016-010727-A	< 1	FT-102016-010727-B	< 1
3	EASTERN HIGH SCHOOL	WS- 010816	1/7/2017	4	Break Room	W406	FT-102016-010816-A	< 1	FT-102016-010816-B	< 1
4	EASTERN HIGH SCHOOL	WS- 002342	1/7/2017	1	Combo Faucet	In classroom W143	FT-112016-002342-A	< 1	FT-112016-002342-B	< 1
5	EASTERN HIGH SCHOOL	WS- 002339	1/7/2017	1	Combo Faucet	In classroom W143	FT-112016-002339-A	< 1	FT-112016-002339-B	< 1
6	EASTERN HIGH SCHOOL	WS- 011894	1/7/2017	4	Break Room	In break room E406	FT-112016-011894-A	< 1	FT-112016-011894-B	< 1
7	EASTERN HIGH SCHOOL	WS- 010788	1/7/2017	2	Break Room	In break room E211	FT-112016-010788-A	< 1	FT-112016-010788-B	< 1
8	EASTERN HIGH SCHOOL	WS- 011890	1/7/2017	3	Break Room	In breakroom E307	FT-112016-011890-A	< 1	FT-112016-011890-B	< 1

## First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	EASTERN HIGH SCHOOL	WS- 011894	2/8/2017	4	Break Room	In break room E406	FT-112016-011894-A	3	FT-112016-011894-B	< 1
2	EASTERN HIGH SCHOOL	WS- 011890	2/8/2017	3	Break Room	In breakroom E307	FT-112016-011890-A	3.1	FT-112016-011890-B	< 1

## Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	EASTERN HIGH SCHOOL	WS- 011894	3/30/2017	4	Break Room	In break room E406	FT-112016-011894-A	3.2	FT-112016-011894-B	< 1
2	EASTERN HIGH SCHOOL	WS- 011890	3/30/2017	3	Break Room	In breakroom E307	FT-112016-011890-A	4.8	FT-112016-011890-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb