



Eastern High School Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008280	6/2/2017	6/2/2018	Basement	Ice Maker	In athletics training room G-12	WF-62017-008280	12/15/2017	FT-FY18--62017-008280-A	<1	FT-FY18--62017-008280-B	<1
WS-010709	6/2/2017	6/2/2018	1	Health Suite	In health suite W130	WF-62017-010709	12/15/2017	FT-FY18--62017-010709-A	<1	FT-FY18--62017-010709-B	<1
WS-010714	6/2/2017	6/2/2018	1	Health Suite	In health suite in exam room W134	WF-62017-010714	12/15/2017	FT-FY18--62017-010714-A	<1	FT-FY18--62017-010714-B	<1
WS-010717	6/2/2017	6/2/2018	1	Bottle Filler	In hallway across from room W130 (bottle filler)	WF-62017-010717	12/15/2017	FT-FY18--62017-010717-A	<1	FT-FY18--62017-010717-B	<1
WS-010723	6/2/2017	6/2/2018	Ground Floor	Cooler	In cafeteria	WF-62017-010723	12/15/2017	FT-FY18--62017-010723-A	<1	FT-FY18--62017-010723-B	<1
WS-010727	6/2/2017	6/2/2018	1	Break Room	In break room W110	WF-62017-010727	12/15/2017	FT-FY18--62017-010727-A	<1	FT-FY18--62017-010727-B	<1
WS-010766	6/2/2017	6/2/2018	1	Cooler	In hallway across from gym	WF-62017-010766	12/15/2017	FT-FY18--62017-010766-A	<1	FT-FY18--62017-010766-B	<1
WS-010794	6/2/2017	6/2/2018	3	Cooler	In hallway across from room W311	WF-62017-010794	12/15/2017	FT-FY18--62017-010794-A	<1	FT-FY18--62017-010794-B	<1
WS-010816	6/2/2017	6/2/2018	4	Break Room	In breakroom (former science prep room) W406	WF-62017-010816	12/15/2017	FT-FY18--62017-010816-A	<1	FT-FY18--62017-010816-B	<1
WS-011888	6/2/2017	6/2/2018	4	Cooler	In hallway across from room E415	WF-62017-011888	12/15/2017	FT-FY18--62017-011888-A	<1	FT-FY18--62017-011888-B	<1
WS-011890	6/2/2017	6/2/2018	3	Break Room	In breakroom E307	WF-62017-011890	12/15/2017	FT-FY18--62017-011890-A	<1	FT-FY18--62017-011890-B	<1
WS-011892	6/2/2017	6/2/2018	Ground Floor	Ice Maker	In kitchen (ice maker)	WF-62017-011892	12/15/2017	FT-FY18--62017-011892-A	<1	FT-FY18--62017-011892-B	<1
WS-011893	6/2/2017	6/2/2018	Ground Floor	Break Room	In concessions G106 (sink)	WF-62017-011893	12/15/2017	FT-FY18--62017-011893-A	<1	FT-FY18--62017-011893-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS-010718	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door	12/15/2017	FT-FY18-102017-010718-A	<1	FT-FY18-102017-010718-B	<1			
WS-010720	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	12/15/2017	FT-FY18-102017-010720-A	<1	FT-FY18-102017-010720-B	<1			
WS-010721	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	12/15/2017	FT-FY18-102017-010721-A	<1	FT-FY18-102017-010721-B	<1			