



EASTERN LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	EASTERN HIGH SCHOOL	5/17/2016	WS- 011896	Utility	Ground Floor	In athletic field house hose bib facing east	WT-042916-11913- A	2.5	WT-042916-11913- B	< 1				
2	EASTERN HIGH SCHOOL	5/17/2016	WS- 011895	Break Room	4	In break room 406 ice maker	WT-042916-11912- A	< 1	WT-042916-11912- B	< 1				
3	EASTERN HIGH SCHOOL	5/18/2016	WS- 011894	Break Room	4	In break room 406	WT-042916-11911- A	< 1	WT-042916-11911- B	< 1				
4	EASTERN HIGH SCHOOL	5/17/2016	WS- 011893	Other	Ground Floor	In concessions G106	WT-042916-11910- A	15.9	WT-042916-11910- B	< 1	Filtered	7/1/2016	<1	<1
5	EASTERN HIGH SCHOOL	5/18/2016	WS- 011892	Kitchen	Ground Floor	In kitchen icemaker south wall	WT-042916-11909- A	< 1	WT-042916-11909- B	2.2				
6	EASTERN HIGH SCHOOL	5/17/2016	WS- 011891	Classroom	3	In class room W307 ice maker	WT-042916-11908- A	< 1	WT-042916-11908- B	< 1				
7	EASTERN HIGH SCHOOL	5/17/2016	WS- 011890	Classroom	3	In class room W307	WT-042916-11907- A	< 1	WT-042916-11907- B	< 1				
8	EASTERN HIGH SCHOOL	5/17/2016	WS- 011889	Classroom	4	In class room E416	WT-042916-11906- A	1.8	WT-042916-11906- B	< 1				
9	EASTERN HIGH SCHOOL	5/17/2016	WS- 011888	Cooler	4	In hallway across from E415	WT-042916-11905- A	< 1	WT-042916-11905- B	< 1				
10	EASTERN HIGH SCHOOL	5/17/2016	WS- 011887	Cooler	4	In hallway across room E415	WT-042916-11904- A	< 1	WT-042916-11904- B	< 1				
11	EASTERN HIGH SCHOOL	5/17/2016	WS- 011886	Classroom	4	In classroom E413 west wall	WT-042916-11903- A	6.3	WT-042916-11903- B	< 1				
12	EASTERN HIGH SCHOOL	5/17/2016	WS- 011885	Classroom	4	In classroom E413 West wall	WT-042916-11902- A	8.6	WT-042916-11902- B	< 1				
13	EASTERN HIGH SCHOOL	5/17/2016	WS- 011884	Classroom	4	In classroom E413 north wall first from left	WT-042916-11901- A	26.1	WT-042916-11901- B	< 1	labeled "not for drinking"			
14	EASTERN HIGH SCHOOL	5/17/2016	WS- 011883	Classroom	4	In class room E413 south wall from right well	WT-042916-11900- A	8.3	WT-042916-11900- B	< 1				
15	EASTERN HIGH SCHOOL	5/17/2016	WS- 011882	Classroom	4	In class room E413 south wall from left	WT-042916-11899- A	12.8	WT-042916-11899- B	< 1				
16	EASTERN HIGH SCHOOL	5/17/2016	WS- 010857	Classroom	4	In class room E413 west wall from middle	WT-042916-10874- A	5.9	WT-042916-10874- B	< 1				
17	EASTERN HIGH SCHOOL	5/17/2016	WS- 010856	Classroom	4	In class room E413 west wall from right well	WT-042916-10873- A	< 1	WT-042916-10873- B	< 1				
18	EASTERN HIGH SCHOOL	5/17/2016	WS- 010855	Classroom	4	In class room E413 West wall from right well	WT-042916-10872- A	7.3	WT-042916-10872- B	< 1				
19	EASTERN HIGH SCHOOL	5/17/2016	WS- 010854	Classroom	4	In class room E413 north wall from left well	WT-042916-10871- A	13.7	WT-042916-10871- B	< 1				
20	EASTERN HIGH SCHOOL	5/17/2016	WS- 010853	Classroom	4	In class room E413 north wall from right well	WT-042916-10870- A	11.9	WT-042916-10870- B	< 1				
21	EASTERN HIGH SCHOOL	5/17/2016	WS- 010852	Classroom	4	In class room W409 west wall from right well	WT-042916-10869- A	14.3	WT-042916-10869- B	< 1				
22	EASTERN HIGH SCHOOL	5/17/2016	WS- 010851	Classroom	4	In classroom E411	WT-042916-10868- A	< 1	WT-042916-10868- B	< 1				
23	EASTERN HIGH SCHOOL	5/17/2016	WS- 010850	Classroom	4	In classroom E411 west wall	WT-042916-10867- A	8.1	WT-042916-10867- B	< 1				
24	EASTERN HIGH SCHOOL	5/17/2016	WS- 010849	Classroom	4	In classroom E411	WT-042916-10866- A	< 1	WT-042916-10866- B	< 1				
25	EASTERN HIGH SCHOOL	5/17/2016	WS- 010848	Classroom	4	In classroom e411 west wall first from left	WT-042916-10865- A	4.7	WT-042916-10865- B	< 1				
26	EASTERN HIGH SCHOOL	5/17/2016	WS- 010847	Classroom	4	In classroom E411 west wall second from left	WT-042916-10864- A	5.4	WT-042916-10864- B	< 1				
27	EASTERN HIGH SCHOOL	5/17/2016	WS- 010846	Classroom	4	In classroom E411 west wall third from left	WT-042916-10863- A	6.6	WT-042916-10863- B	< 1				
28	EASTERN HIGH SCHOOL	5/17/2016	WS- 010845	Classroom	4	In classroom E411 west wall last from left	WT-042916-10862- A	12.6	WT-042916-10862- B	< 1				
29	EASTERN HIGH SCHOOL	5/17/2016	WS- 010844	Classroom	4	In classroom E411 north wall	WT-042916-10861- A	1.7	WT-042916-10861- B	< 1				
30	EASTERN HIGH SCHOOL	5/17/2016	WS- 010843	Classroom	4	In classroom E411 north wall	WT-042916-10860- A	8.2	WT-042916-10860- B	3.2				
31	EASTERN HIGH SCHOOL	5/17/2016	WS- 010842	Classroom	4	In classroom E411 north wall	WT-042916-10859- A	48.2	WT-042916-10859- B	1.3	labeled "not for drinking"			
32	EASTERN HIGH SCHOOL	5/17/2016	WS- 010841	Classroom	4	In class room E410	WT-042916-10858- A	56.1	WT-042916-10858- B	6.6	labeled "not for drinking"			
33	EASTERN HIGH SCHOOL	5/17/2016	WS- 010840	Classroom	4	In classroom W412	WT-042916-10857- A	< 1	WT-042916-10857- B	< 1				
34	EASTERN HIGH SCHOOL	5/17/2016	WS- 010839	Cooler	4	In hallway across from W411	WT-042916-10856- A	< 1	WT-042916-10856- B	< 1				
35	EASTERN HIGH SCHOOL	5/17/2016	WS- 010838	Cooler	4	In hallway across from the In class room W411	WT-042916-10855- A	< 1	WT-042916-10855- B	< 1				
36	EASTERN HIGH SCHOOL	5/17/2016	WS- 010837	Classroom	4	In classroom W09	WT-042916-10854- A	7	WT-042916-10854- B	< 1				
37	EASTERN HIGH SCHOOL	5/17/2016	WS- 010836	Classroom	4	In classroom W409 south wall	WT-042916-10853- A	< 1	WT-042916-10853- B	< 1				
38	EASTERN HIGH SCHOOL	5/17/2016	WS- 010835	Classroom	4	In classroom W409 south wall	WT-042916-10852- A	4	WT-042916-10852- B	< 1				
39	EASTERN HIGH SCHOOL	5/17/2016	WS- 010834	Classroom	4	In classroom W409 west wall first from left	WT-042916-10851- A	44.4	WT-042916-10851- B	< 1	labeled "not for drinking"			
40	EASTERN HIGH SCHOOL	5/10/2016	WS- 010833	Classroom	4	In classroom W409 west wall second from left	WT-042916-10850- A	4.9	WT-042916-10850- B	< 1				
41	EASTERN HIGH SCHOOL	5/17/2016	WS- 010832	Classroom	4	In class room W 409 west wall from left well	WT-042916-10849- A	12.9	WT-042916-10849- B	< 1				
42	EASTERN HIGH SCHOOL	5/17/2016	WS- 010830	Classroom	4	In class room w 409 north from left well	WT-042916-10847- A	7.2	WT-042916-10847- B	< 1				



EASTERN LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
43	EASTERN HIGH SCHOOL	5/17/2016	WS- 010829	Classroom	4	In class room W409 north wall left well	WT-042916-10846- A	18.1	WT-042916-10846- B	< 1	labeled "not for drinking"		
44	EASTERN HIGH SCHOOL	5/17/2016	WS- 010828	Classroom	4	In class room W409 North wall right well	WT-042916-10845- A	11.3	WT-042916-10845- B	< 1			
45	EASTERN HIGH SCHOOL	5/17/2016	WS- 010827	Classroom	4	In classroom W407 north wall right well	WT-042916-10844- A	14.7	WT-042916-10844- B	< 1			
46	EASTERN HIGH SCHOOL	5/17/2016	WS- 010826	Classroom	4	In classroom W407 south wall right well	WT-042916-10843- A	< 1	WT-042916-10843- B	< 1			
47	EASTERN HIGH SCHOOL	5/17/2016	WS- 010825	Classroom	4	In classroom W407 south wall left well	WT-042916-10842- A	6.6	WT-042916-10842- B	< 1			
48	EASTERN HIGH SCHOOL	5/17/2016	WS- 010824	Classroom	4	In class room W407 west wall right well	WT-042916-10841- A	< 1	WT-042916-10841- B	< 1			
49	EASTERN HIGH SCHOOL	5/17/2016	WS- 010823	Classroom	4	In class room W407 west wall left well	WT-042916-10840- A	10.7	WT-042916-10840- B	< 1			
50	EASTERN HIGH SCHOOL	5/17/2016	WS- 010822	Classroom	4	In class room W 407 west wall right well	WT-042916-10839- A	< 1	WT-042916-10839- B	< 1			
51	EASTERN HIGH SCHOOL	5/17/2016	WS- 010821	Classroom	4	In class room W407 west wall left well	WT-042916-10838- A	2.2	WT-042916-10838- B	< 1			
52	EASTERN HIGH SCHOOL	5/17/2016	WS- 010820	Classroom	4	In classroom W407 south wall right well	WT-042916-10837- A	1.8	WT-042916-10837- B	< 1			
53	EASTERN HIGH SCHOOL	5/17/2016	WS- 010819	Classroom	4	In classroom W407 south wall left well	WT-042916-10836- A	4.6	WT-042916-10836- B	< 1			
54	EASTERN HIGH SCHOOL	5/17/2016	WS- 010818	Classroom	4	In classroom W407 south wall left well	WT-042916-10835- A	< 1	WT-042916-10835- B	< 1			
55	EASTERN HIGH SCHOOL	5/17/2016	WS- 010817	Classroom	4	In class room W406	WT-042916-10834- A	< 1	WT-042916-10834- B	< 1			
56	EASTERN HIGH SCHOOL	5/17/2016	WS- 010816	Classroom	4	In prep room W406	WT-042916-10833- A	< 1	WT-042916-10833- B	< 1			
57	EASTERN HIGH SCHOOL	5/17/2016	WS- 010815	Classroom	3	In room W306	WT-042916-10832- A	< 1	WT-042916-10832- B	< 1			
58	EASTERN HIGH SCHOOL	5/17/2016	WS- 010814	Classroom	3	In classroom W307 north wall right well	WT-042916-10831- A	1.3	WT-042916-10831- B	< 1			
59	EASTERN HIGH SCHOOL	5/17/2016	WS- 010813	Classroom	3	In classroom W307 north wall right well	WT-042916-10830- A	< 1	WT-042916-10830- B	< 1			
60	EASTERN HIGH SCHOOL	5/17/2016	WS- 010812	Classroom	3	In classroom W307 north wall left well	WT-042916-10829- A	< 1	WT-042916-10829- B	< 1			
61	EASTERN HIGH SCHOOL	5/17/2016	WS- 010811	Classroom	3	In classroom W307 west wall right well	WT-042916-10828- A	< 1	WT-042916-10828- B	< 1			
62	EASTERN HIGH SCHOOL	5/17/2016	WS- 010810	Classroom	3	In classroom W307 west wall right well	WT-042916-10827- A	< 1	WT-042916-10827- B	< 1			
63	EASTERN HIGH SCHOOL	5/17/2016	WS- 010809	Classroom	3	In class room W307 west wall right	WT-042916-10826- A	1.2	WT-042916-10826- B	< 1			
64	EASTERN HIGH SCHOOL	5/17/2016	WS- 010808	Classroom	3	In class room W307 west wall left	WT-042916-10825- A	1.3	WT-042916-10825- B	< 1			
65	EASTERN HIGH SCHOOL	5/17/2016	WS- 010807	Classroom	3	In class room W307 North wall middle	WT-042916-10824- A	< 1	WT-042916-10824- B	< 1			
66	EASTERN HIGH SCHOOL	5/17/2016	WS- 010806	Classroom	3	In class room w307 north wall right	WT-042916-10823- A	2.1	WT-042916-10823- B	< 1			
67	EASTERN HIGH SCHOOL	5/17/2016	WS- 010805	Classroom	3	In class room W 307 north wall left	WT-042916-10822- A	3.1	WT-042916-10822- B	< 1			
68	EASTERN HIGH SCHOOL	5/17/2016	WS- 010804	Classroom	3	In classroom W309 east wall left well	WT-042916-10821- A	< 1	WT-042916-10821- B	< 1			
69	EASTERN HIGH SCHOOL	5/17/2016	WS- 010803	Classroom	3	In classroom W309 west wall left well	WT-042916-10820- A	1.6	WT-042916-10820- B	< 1			
70	EASTERN HIGH SCHOOL	5/17/2016	WS- 010802	Classroom	3	In classroom W309 west wall right well	WT-042916-10819- A	2.4	WT-042916-10819- B	< 1			
71	EASTERN HIGH SCHOOL	5/17/2016	WS- 010801	Classroom	3	In classroom W309 north wall left well	WT-042916-10818- A	1.2	WT-042916-10818- B	< 1			
72	EASTERN HIGH SCHOOL	5/17/2016	WS- 010800	Classroom	3	In classroom W309 north wall left well	WT-042916-10817- A	< 1	WT-042916-10817- B	< 1			
73	EASTERN HIGH SCHOOL	5/17/2016	WS- 010799	Classroom	3	In class room W309 east wall left well	WT-042916-10816- A	< 1	WT-042916-10816- B	< 1			
74	EASTERN HIGH SCHOOL	5/17/2016	WS- 010798	Classroom	3	In class room w309 west wall right well	WT-042916-10815- A	1	WT-042916-10815- B	< 1			
75	EASTERN HIGH SCHOOL	5/17/2016	WS- 010797	Classroom	3	In class room w309 east wall Let well	WT-042916-10814- A	< 1	WT-042916-10814- B	< 1			
76	EASTERN HIGH SCHOOL	5/17/2016	WS- 010796	Classroom	2	In classroom W309 east wall left well	WT-042916-10813- A	1.4	WT-042916-10813- B	< 1			
77	EASTERN HIGH SCHOOL	5/17/2016	WS- 010795	Classroom	2	In classroom W309 east wall right well	WT-042916-10812- A	1.2	WT-042916-10812- B	< 1			
78	EASTERN HIGH SCHOOL	5/17/2016	WS- 010794	Cooler	2	In hallway across from classroom W311	WT-042916-10811- A	< 1	WT-042916-10811- B	< 1			
79	EASTERN HIGH SCHOOL	5/17/2016	WS- 010793	Cooler	3	In hallway across from the W311	WT-042916-10810- A	< 1	WT-042916-10810- B	< 1			
80	EASTERN HIGH SCHOOL	5/17/2016	WS- 010792	Classroom	3	In class room W312	WT-042916-10809- A	2.2	WT-042916-10809- B	< 1			
81	EASTERN HIGH SCHOOL	5/17/2016	WS- 010791	Classroom	3	In class room E 318	WT-042916-10808- A	20.5	WT-042916-10808- B	4.1	labeled "not for drinking"		
82	EASTERN HIGH SCHOOL	5/17/2016	WS- 010790	Cooler	3	In hallway across from E316	WT-042916-10807- A	< 1	WT-042916-10807- B	< 1			
83	EASTERN HIGH SCHOOL	5/17/2016	WS- 010789	Cooler	3	In hallway across from classroom E316	WT-042916-10806- A	< 1	WT-042916-10806- B	< 1			
84	EASTERN HIGH SCHOOL	5/17/2016	WS- 010788	Classroom	2	In class room W211	WT-042916-10805- A	< 1	WT-042916-10805- B	< 1			
85	EASTERN HIGH SCHOOL	5/17/2016	WS- 010787	Classroom	2	In work room W206	WT-042916-10804- A	< 1	WT-042916-10804- B	< 1			
86	EASTERN HIGH SCHOOL	5/17/2016	WS- 010786	Classroom	2	In class room W209 ice maker	WT-042916-10803- A	< 1	WT-042916-10803- B	< 1			
87	EASTERN HIGH SCHOOL	5/17/2016	WS- 010785	Break Room	2	In break room W209A	WT-042916-10802- A	< 1	WT-042916-10802- B	< 1			
88	EASTERN HIGH SCHOOL	5/17/2016	WS- 010784	Cooler	2	In hallway across from classroom W212	WT-042916-10801- A	< 1	WT-042916-10801- B	< 1			
89	EASTERN HIGH SCHOOL	5/17/2016	WS- 010783	Cooler	2	In hallway across from the W212	WT-042916-10800- A	< 1	WT-042916-10800- B	< 1			
90	EASTERN HIGH SCHOOL	5/17/2016	WS- 010782	Classroom	2	In class room W218	WT-042916-10799- A	< 1	WT-042916-10799- B	< 1			
91	EASTERN HIGH SCHOOL	5/17/2016	WS- 010781	Classroom	2	In class room W218	WT-042916-10798- A	< 1	WT-042916-10798- B	< 1			
92	EASTERN HIGH SCHOOL	5/17/2016	WS- 010780	Classroom	2	In classroom W218 left well	WT-042916-10797- A	< 1	WT-042916-10797- B	< 1			
93	EASTERN HIGH SCHOOL	5/17/2016	WS- 010779	Classroom	2	In class room W218 left well	WT-042916-10796- A	< 1	WT-042916-10796- B	< 1			
94	EASTERN HIGH SCHOOL	5/17/2016	WS- 010778	Classroom	2	In classroom E229	WT-042916-10795- A	4.8	WT-042916-10795- B	1.9			
95	EASTERN HIGH SCHOOL	5/17/2016	WS- 010777	Classroom	2	In class room E228	WT-042916-10794- A	1.3	WT-042916-10794- B	< 1			
96	EASTERN HIGH SCHOOL	5/17/2016	WS- 010776	Classroom	2	In class room E227	WT-042916-10793- A	374	WT-042916-10793- B	16.8	labeled "not for drinking"		
97	EASTERN HIGH SCHOOL	5/17/2016	WS- 010775	Cooler	2	In hallway adjacent classroom E227	WT-042916-10792- A	< 1	WT-042916-10792- B	< 1			
98	EASTERN HIGH SCHOOL	5/17/2016	WS- 010774	Classroom	2	In classroom E225 left well	WT-042916-10791- A	< 1	WT-042916-10791- B	< 1			
99	EASTERN HIGH SCHOOL	5/17/2016	WS- 010773	Classroom	2	In classroom E225 left well	WT-042916-10790- A	< 1	WT-042916-10790- B	< 1			



EASTERN LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
100	EASTERN HIGH SCHOOL	5/17/2016	WS-010772	Classroom	2	In class room E225 Left	WT-042916-10789-A	< 1	WT-042916-10789-B	< 1			
101	EASTERN HIGH SCHOOL	5/17/2016	WS-010771	Classroom	2	In class room E225 Right	WT-042916-10788-A	< 1	WT-042916-10788-B	< 1			
102	EASTERN HIGH SCHOOL	5/17/2016	WS-010770	Classroom	2	In classroom E220	WT-042916-10787-A	< 1	WT-042916-10787-B	< 1			
103	EASTERN HIGH SCHOOL	5/17/2016	WS-010769	Cooler	2	In hallway across from classroom E218 bottle refiller High	WT-042916-10786-A	< 1	WT-042916-10786-B	< 1			
104	EASTERN HIGH SCHOOL	5/17/2016	WS-010768	Classroom	2	In hallway across to the E218 Left Low	WT-042916-10785-A	< 1	WT-042916-10785-B	< 1			
105	EASTERN HIGH SCHOOL	5/18/2016	WS-010767	Cooler	1	In hallway across from gym Left Low	WT-042916-10784-A	< 1	WT-042916-10784-B	< 1			
106	EASTERN HIGH SCHOOL	5/17/2016	WS-010766	Cooler	1	In hallway across from gymnasium High	WT-042916-10783-A	< 1	WT-042916-10783-B	< 1			
107	EASTERN HIGH SCHOOL	5/17/2016	WS-010765	Classroom	1	In classroom E116 north wall Right	WT-042916-10782-A	< 1	WT-042916-10782-B	< 1			
108	EASTERN HIGH SCHOOL	5/17/2016	WS-010764	Classroom	1	In classroom E116 north wall Left	WT-042916-10781-A	< 1	WT-042916-10781-B	< 1			
109	EASTERN HIGH SCHOOL	5/17/2016	WS-010763	Classroom	1	In classroom E116 north wall	WT-042916-10780-A	1.4	WT-042916-10780-B	< 1			
110	EASTERN HIGH SCHOOL	5/17/2016	WS-010762	Classroom	1	In class room E 116 east wall Left	WT-042916-10779-A	< 1	WT-042916-10779-B	< 1			
111	EASTERN HIGH SCHOOL	5/17/2016	WS-010761	Classroom	1	In class room E116 Right	WT-042916-10778-A	< 1	WT-042916-10778-B	< 1			
112	EASTERN HIGH SCHOOL	5/17/2016	WS-010760	Classroom	1	In classroom E116 east wall Left	WT-042916-10777-A	< 1	WT-042916-10777-B	< 1			
113	EASTERN HIGH SCHOOL	5/17/2016	WS-010759	Classroom	1	In classroom E116 east wall Right	WT-042916-10776-A	< 1	WT-042916-10776-B	< 1			
114	EASTERN HIGH SCHOOL	5/17/2016	WS-010758	Classroom	1	In class room E116 east wall Left	WT-042916-10775-A	< 1	WT-042916-10775-B	< 1			
115	EASTERN HIGH SCHOOL	5/17/2016	WS-010757	Classroom	1	In classroom E116 east wall Right	WT-042916-10774-A	< 1	WT-042916-10774-B	< 1			
116	EASTERN HIGH SCHOOL	5/17/2016	WS-010756	Classroom	1	In classroom E116 east wall far right Left	WT-042916-10773-A	< 1	WT-042916-10773-B	< 1			
117	EASTERN HIGH SCHOOL	5/17/2016	WS-010755	Classroom	1	In classroom E116 east wall far right Right	WT-042916-10772-A	< 1	WT-042916-10772-B	< 1			
118	EASTERN HIGH SCHOOL	5/17/2016	WS-010754	Classroom	1	In classrooms E116 south wall Mid	WT-042916-10771-A	1.9	WT-042916-10771-B	< 1			
119	EASTERN HIGH SCHOOL	5/17/2016	WS-010753	Classroom	1	In classroom E116 south wall Left	WT-042916-10770-A	< 1	WT-042916-10770-B	< 1			
120	EASTERN HIGH SCHOOL	5/17/2016	WS-010752	Classroom	1	In classroom E116 south wall Right	WT-042916-10769-A	< 1	WT-042916-10769-B	< 1			
121	EASTERN HIGH SCHOOL	5/17/2016	WS-010751	Classroom	1	In classroom E114 south wall Left	WT-042916-10768-A	< 1	WT-042916-10768-B	< 1			
122	EASTERN HIGH SCHOOL	5/17/2016	WS-010750	Classroom	1	In classroom E114 south wall Right	WT-042916-10767-A	6.5	WT-042916-10767-B	< 1			
123	EASTERN HIGH SCHOOL	5/17/2016	WS-010749	Classroom	1	In classroom E114 south wall	WT-042916-10766-A	3.6	WT-042916-10766-B	< 1			
124	EASTERN HIGH SCHOOL	5/17/2016	WS-010748	Classroom	1	In classroom E114 west wall near window Left	WT-042916-10765-A	15.7	WT-042916-10765-B	< 1	labeled "not for drinking"		
125	EASTERN HIGH SCHOOL	5/17/2016	WS-010747	Classroom	1	In classroom E114 west wall near window Right	WT-042916-10764-A	12.1	WT-042916-10764-B	< 1			
126	EASTERN HIGH SCHOOL	5/17/2016	WS-010746	Classroom	1	In classroom E114 west wall	WT-042916-10763-A	12.2	WT-042916-10763-B	< 1			
127	EASTERN HIGH SCHOOL	5/17/2016	WS-010745	Classroom	1	In classroom E114 west wall Right	WT-042916-10762-A	8.4	WT-042916-10762-B	< 1			
128	EASTERN HIGH SCHOOL	5/17/2016	WS-010744	Classroom	1	In classroom E114 north wall	WT-042916-10761-A	1.4	WT-042916-10761-B	< 1			
129	EASTERN HIGH SCHOOL	5/17/2016	WS-010743	Classroom	1	In classroom E114 north wall	WT-042916-10760-A	6.2	WT-042916-10760-B	< 1			
130	EASTERN HIGH SCHOOL	5/17/2016	WS-010742	Classroom	1	In classroom E114 north near entrance Right	WT-042916-10759-A	4.6	WT-042916-10759-B	< 1			
131	EASTERN HIGH SCHOOL	5/17/2016	WS-010741	Classroom	1	In classroom E115 Right	WT-042916-10758-A	9.7	WT-042916-10758-B	2.7			
132	EASTERN HIGH SCHOOL	5/17/2016	WS-010740	Classroom	1	In classroom E115 Left	WT-042916-10757-A	6.8	WT-042916-10757-B	< 1			
133	EASTERN HIGH SCHOOL	5/17/2016	WS-010739	Classroom	1	In classroom E115 north wall near window Right	WT-042916-10756-A	< 1	WT-042916-10756-B	< 1			
134	EASTERN HIGH SCHOOL	5/17/2016	WS-010738	Classroom	1	In classroom E115 north wall near window Left	WT-042916-10755-A	1.1	WT-042916-10755-B	< 1			
135	EASTERN HIGH SCHOOL	5/17/2016	WS-010737	Classroom	1	In classroom E115 north wall Right	WT-042916-10754-A	4	WT-042916-10754-B	< 1			
136	EASTERN HIGH SCHOOL	5/17/2016	WS-010736	Classroom	1	In classroom E115 north wall Left	WT-042916-10753-A	4.3	WT-042916-10753-B	< 1			
137	EASTERN HIGH SCHOOL	5/17/2016	WS-010735	Classroom	1	In classroom E 115 west wall Left	WT-042916-10752-A	3.4	WT-042916-10752-B	< 1			
138	EASTERN HIGH SCHOOL	5/17/2016	WS-010734	Classroom	1	In classroom 115 west wall Right	WT-042916-10751-A	14.1	WT-042916-10751-B	< 1			
139	EASTERN HIGH SCHOOL	5/17/2016	WS-010733	Classroom	Ground Floor	In prep room E112	WT-042916-10750-A	< 1	WT-042916-10750-B	< 1			
140	EASTERN HIGH SCHOOL	5/17/2016	WS-010732	Other	Ground Floor	In Room E112 Ice maker	WT-042916-10749-A	< 1	WT-042916-10749-B	< 1			
141	EASTERN HIGH SCHOOL	5/17/2016	WS-010731	Classroom	Ground Floor	In classroom E 119	WT-042916-10748-A	< 1	WT-042916-10748-B	< 1			
142	EASTERN HIGH SCHOOL	5/17/2016	WS-010730	Cooler	Ground Floor	In hallway between classroom E124 and mechanical closet MC-13	WT-042916-10747-A	< 1	WT-042916-10747-B	< 1			
143	EASTERN HIGH SCHOOL	5/17/2016	WS-010729	Classroom	Ground Floor	In classroom e 120	WT-042916-10746-A	< 1	WT-042916-10746-B	< 1			
144	EASTERN HIGH SCHOOL	5/17/2016	WS-010727	Break Room	Ground Floor	In break room w110	WT-042916-10744-A	< 1	WT-042916-10744-B	< 1			
145	EASTERN HIGH SCHOOL	5/17/2016	WS-010726	Classroom	Ground Floor	In classroom E02 Left	WT-042916-10743-A	< 1	WT-042916-10743-B	< 1			
146	EASTERN HIGH SCHOOL	5/17/2016	WS-010725	Classroom	Ground Floor	In classroom E02 Mid	WT-042916-10742-A	1.5	WT-042916-10742-B	< 1			
147	EASTERN HIGH SCHOOL	5/17/2016	WS-010724	Classroom	Ground Floor	In classroom E02 Right	WT-042916-10741-A	< 1	WT-042916-10741-B	< 1			
148	EASTERN HIGH SCHOOL	5/17/2016	WS-010723	Cooler	Ground Floor	In cafeteria north wall High	WT-042916-10740-A	< 1	WT-042916-10740-B	< 1			
149	EASTERN HIGH SCHOOL	5/17/2016	WS-010722	Cooler	Ground Floor	In cafeteria north wall Low	WT-042916-10739-A	< 1	WT-042916-10739-B	< 1			
150	EASTERN HIGH SCHOOL	5/17/2016	WS-010721	Kitchen	Ground Floor	In kitchen west wall Left	WT-042916-10738-A	< 1	WT-042916-10738-B	< 1			
151	EASTERN HIGH SCHOOL	5/17/2016	WS-010720	Kitchen	Ground Floor	In kitchen west wall Right	WT-042916-10737-A	< 1	WT-042916-10737-B	< 1			
152	EASTERN HIGH SCHOOL	5/17/2016	WS-010719	Kitchen	Ground Floor	In kitchen spray nroccald	WT-042916-10736-A	< 1	WT-042916-10736-B	< 1			
153	EASTERN HIGH SCHOOL	5/17/2016	WS-010718	Kitchen	Ground Floor	In kitchen north wall	WT-042916-10735-A	< 1	WT-042916-10735-B	< 1			
154	EASTERN HIGH SCHOOL	5/17/2016	WS-010717	Cooler	Ground Floor	In hallway across from health clinic W130 bottle refiller	WT-042916-10734-A	< 1	WT-042916-10734-B	< 1			



EASTERN LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
155	EASTERN HIGH SCHOOL	5/17/2016	WS- 010714	Health Suite	Ground Floor	In health clinic exam room W134	WT-042916-10731- A	< 1	WT-042916-10731- B	< 1				
156	EASTERN HIGH SCHOOL	5/17/2016	WS- 010713	Health Suite	Ground Floor	In health clinic in room w131	WT-042916-10730- A	11.8	WT-042916-10730- B	< 1				
157	EASTERN HIGH SCHOOL	5/17/2016	WS- 010712	Health Suite	Ground Floor	In health clinic exam room W128	WT-042916-10729- A	< 1	WT-042916-10729- B	< 1				
158	EASTERN HIGH SCHOOL	5/17/2016	WS- 010711	Health Suite	Ground Floor	In health clinic lab room W129	WT-042916-10728- A	1.1	WT-042916-10728- B	< 1				
159	EASTERN HIGH SCHOOL	5/17/2016	WS- 010710	Health Suite	Ground Floor	In health clinic break ice maker	WT-042916-10727- A	< 1	WT-042916-10727- B	< 1				
160	EASTERN HIGH SCHOOL	5/17/2016	WS- 010709	Health Suite	Ground Floor	In health clinic break area common sink	WT-042916-10726- A	< 1	WT-042916-10726- B	< 1				
161	EASTERN HIGH SCHOOL	5/17/2016	WS- 010708	Utility	Basement	In boiler room west wall	WT-042916-10725- A	6.6	WT-042916-10725- B	3.4				
162	EASTERN HIGH SCHOOL	5/17/2016	WS- 008290	Other	Ground Floor	In athletic field concession stand lower drain	WT-042916-8307- A	< 1	WT-042916-8307- B	< 1				
163	EASTERN HIGH SCHOOL	5/17/2016	WS- 008289	Fountain	Ground Floor	In athletic field outside restroom	WT-042916-8306- A	2	WT-042916-8306- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.