



Eaton Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000838	4/9/2024	4/9/2025	Basement	Bottle Filler	In cafeteria adjacent to restrooms	WF-04092024-000838	10/31/2024	FT-FY25-10082024-000838-A	<2	FT-FY25-10082024-000838-B	<2
WS- 000839	4/9/2024	4/9/2025	Basement	Cooler	In cafeteria adjacent to restrooms High Left	WF-04092024-000839	10/31/2024	FT-FY25-10082024-000839-A	<2	FT-FY25-10082024-000839-B	<2
WS- 000840	4/9/2024	4/9/2025	Basement	Cooler	In cafeteria adjacent to restrooms Low Right	WF-04092024-000840	10/31/2024	FT-FY25-10082024-000840-A	<2	FT-FY25-10082024-000840-B	<2
WS- 000852	4/9/2024	4/9/2025	Basement	Bottle Filler	In gym	WF-04092024-000852	10/31/2024	FT-FY25-10082024-000852-A	<2	FT-FY25-10082024-000852-B	<2
WS- 000857	4/9/2024	4/9/2025	Basement	Cooler	In gym High Left	WF-04092024-000857	10/31/2024	FT-FY25-10082024-000857-A	<2	FT-FY25-10082024-000857-B	<2
WS- 000859	4/9/2024	4/9/2025	Basement	Cooler	In gym Low Right	WF-04092024-000859	10/31/2024	FT-FY25-10082024-000859-A	<2	FT-FY25-10082024-000859-B	<2
WS- 000969	4/9/2024	4/9/2025	1	Combo Fountain	In art room 112	WF-04092024-000969	10/31/2024	FT-FY25-10082024-000969-A	<2	FT-FY25-10082024-000969-B	<2
WS- 000971	4/9/2024	4/9/2025	1	Combo Fountain	In art room 112	WF-04092024-000971	10/31/2024	FT-FY25-10082024-000971-A	<2	FT-FY25-10082024-000971-B	<2
WS- 000973	4/9/2024	4/9/2025	1	Combo Fountain	In room 111	WF-04092024-000973	10/31/2024	FT-FY25-10082024-000973-A	<2	FT-FY25-10082024-000973-B	<2
WS- 000975	4/9/2024	4/9/2025	1	Combo Fountain	In music room 115	WF-04092024-000975	10/31/2024	FT-FY25-10082024-000975-A	<2	FT-FY25-10082024-000975-B	<2
WS- 000976	4/9/2024	4/9/2025	1	Bottle Filler	In hallway adjacent to restrooms	WF-04092024-000976	10/31/2024	FT-FY25-10082024-000976-A	<2	FT-FY25-10082024-000976-B	<2
WS- 000977	4/9/2024	4/9/2025	1	Cooler	In hallway adjacent to restrooms High Left	WF-04092024-000977	10/31/2024	FT-FY25-10082024-000977-A	<2	FT-FY25-10082024-000977-B	<2
WS- 000978	4/9/2024	4/9/2025	1	Cooler	In hallway adjacent to restrooms Low Right	WF-04092024-000978	10/31/2024	FT-FY25-10082024-000978-A	<2	FT-FY25-10082024-000978-B	<2
WS- 000980	4/9/2024	4/9/2025	1	Combo Fountain	In wellness/lactation room 152 (Next to staff lounge)	WF-04092024-000980	10/31/2024	FT-FY25-10082024-000980-A	<2	FT-FY25-10082024-000980-B	<2
WS- 000981	4/9/2024	4/9/2025	1	Bottle Filler	In staff lounge 152	WF-04092024-000981	10/31/2024	FT-FY25-10082024-000981-A	<2	FT-FY25-10082024-000981-B	<2
WS- 000982	4/9/2024	4/9/2025	1	Cooler	In staff lounge 152	WF-04092024-000982	10/31/2024	FT-FY25-10082024-000982-A	<2	FT-FY25-10082024-000982-B	<2
WS- 000983	4/9/2024	4/9/2025	1	Break Room	In staff lounge 152	WF-04092024-000983	10/31/2024	FT-FY25-10082024-000983-A	<2	FT-FY25-10082024-000983-B	<2
WS- 000985	4/9/2024	4/9/2025	1	Combo Fountain	In resource room 148	WF-04092024-000985	10/31/2024	FT-FY25-10082024-000985-A	<2	FT-FY25-10082024-000985-B	<2
WS- 000986	4/9/2024	4/9/2025	1	Health Suite	In treatment room 145	WF-04092024-000986	10/31/2024	FT-FY25-10082024-000986-A	<2	FT-FY25-10082024-000986-B	<2
WS- 000988	4/9/2024	4/9/2025	1	Break Room	In parent resource room 141	WF-04092024-000988	10/31/2024	FT-FY25-10082024-000988-A	<2	FT-FY25-10082024-000988-B	<2
WS- 000989	4/9/2024	4/9/2025	1	Combo Fountain	In parent resource room 141	WF-04092024-000989	10/31/2024	FT-FY25-10082024-000989-A	<2	FT-FY25-10082024-000989-B	<2
WS- 000996	4/9/2024	4/9/2025	1	Combo Fountain	In OT/PT office 174	WF-04092024-000996	10/31/2024	FT-FY25-10082024-000996-A	<2	FT-FY25-10082024-000996-B	<2
WS- 000998	4/9/2024	4/9/2025	1	Combo Fountain	In OT/PT office 172	WF-04092024-000998	10/31/2024	FT-FY25-10082024-000998-A	<2	FT-FY25-10082024-000998-B	<2
WS- 001038	4/9/2024	4/9/2025	1	Combo Fountain	In specials lab 169	WF-04092024-001038	10/31/2024	FT-FY25-10082024-001038-A	<2	FT-FY25-10082024-001038-B	<2
WS- 001039	9/23/2024	9/23/2025	1	Combo Faucet	In classroom 165	WF-09232024-001039	10/31/2024	FT-FY25-10082024-001039-A	<2	FT-FY25-10082024-001039-B	<2
WS- 001042	4/9/2024	4/9/2025	1	Combo Fountain	In classroom 165	WF-04092024-001042	10/31/2024	FT-FY25-10082024-001042-A	<2	FT-FY25-10082024-001042-B	<2
WS- 001043	9/23/2024	9/23/2025	1	Combo Faucet	In classroom 161	WF-09232024-001043	10/31/2024	FT-FY25-10082024-001043-A	<2	FT-FY25-10082024-001043-B	<2
WS- 001044	4/9/2024	4/9/2025	1	Combo Fountain	In classroom 161	WF-04092024-001044	10/31/2024	FT-FY25-10082024-001044-A	<2	FT-FY25-10082024-001044-B	<2
WS- 001046	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 213	WF-04092024-001046	10/31/2024	FT-FY25-10082024-001046-A	<2	FT-FY25-10082024-001046-B	<2
WS- 001086	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 214	WF-04092024-001086	10/31/2024	FT-FY25-10082024-001086-A	<2	FT-FY25-10082024-001086-B	<2
WS- 001088	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 212	WF-04092024-001088	10/31/2024	FT-FY25-10082024-001088-A	<2	FT-FY25-10082024-001088-B	<2
WS- 001090	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 211	WF-04092024-001090	10/31/2024	FT-FY25-10082024-001090-A	<2	FT-FY25-10082024-001090-B	<2
WS- 001091	4/9/2024	4/9/2025	2	Bottle Filler	In hallway adjacent to restrooms	WF-04092024-001091	10/31/2024	FT-FY25-10082024-001091-A	<2	FT-FY25-10082024-001091-B	<2

WS-001092	4/9/2024	4/9/2025	2	Cooler	In hallway adjacent to restrooms	High Left	WF-04092024-001092	10/31/2024	FT-FY25-10082024-001092-A	<2	FT-FY25-10082024-001092-B	<2
WS-001093	4/9/2024	4/9/2025	2	Cooler	In hallway adjacent to restrooms	Low Right	WF-04092024-001093	10/31/2024	FT-FY25-10082024-001093-A	<2	FT-FY25-10082024-001093-B	<2
WS-001095	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 241		WF-04092024-001095	10/31/2024	FT-FY25-10082024-001095-A	<2	FT-FY25-10082024-001095-B	<2
WS-001096	4/9/2024	4/9/2025	2	Break Room	In teacher workroom 239		WF-04092024-001096	10/31/2024	FT-FY25-10082024-001096-A	<2	FT-FY25-10082024-001096-B	<2
WS-001097	4/9/2024	4/9/2025	2	Combo Fountain	In teacher workroom 239		WF-04092024-001097	10/31/2024	FT-FY25-10082024-001097-A	<2	FT-FY25-10082024-001097-B	<2
WS-001099	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 238		WF-04092024-001099	10/31/2024	FT-FY25-10082024-001099-A	<2	FT-FY25-10082024-001099-B	<2
WS-001101	4/9/2024	4/9/2025	2	Combo Fountain	In resource room 237		WF-04092024-001101	10/31/2024	FT-FY25-10082024-001101-A	<2	FT-FY25-10082024-001101-B	<2
WS-001103	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 235		WF-04092024-001103	10/31/2024	FT-FY25-10082024-001103-A	<2	FT-FY25-10082024-001103-B	<2
WS-001105	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 233		WF-04092024-001105	10/31/2024	FT-FY25-10082024-001105-A	<2	FT-FY25-10082024-001105-B	<2
WS-001107	4/9/2024	4/9/2025	2	Combo Fountain	In library office/workroom 202		WF-04092024-001107	10/31/2024	FT-FY25-10082024-001107-A	<2	FT-FY25-10082024-001107-B	<2
WS-001108	9/23/2024	9/23/2025	2	Combo Faucet	In classroom 272		WF-09232024-001108	10/31/2024	FT-FY25-10082024-001108-A	<2	FT-FY25-10082024-001108-B	<2
WS-001109	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 272		WF-04092024-001109	10/31/2024	FT-FY25-10082024-001109-A	<2	FT-FY25-10082024-001109-B	<2
WS-001112	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 269		WF-04092024-001112	10/31/2024	FT-FY25-10082024-001112-A	<2	FT-FY25-10082024-001112-B	<2
WS-001113	9/23/2024	9/23/2025	2	Combo Faucet	In classroom 265		WF-09232024-001113	10/31/2024	FT-FY25-10082024-001113-A	<2	FT-FY25-10082024-001113-B	<2
WS-001114	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 265		WF-04092024-001114	10/31/2024	FT-FY25-10082024-001114-A	<2	FT-FY25-10082024-001114-B	<2
WS-001115	9/23/2024	9/23/2025	2	Combo Faucet	In classroom 261		WF-09232024-001115	10/31/2024	FT-FY25-10082024-001115-A	<2	FT-FY25-10082024-001115-B	<2
WS-001116	4/9/2024	4/9/2025	2	Combo Fountain	In classroom 261		WF-04092024-001116	10/31/2024	FT-FY25-10082024-001116-A	<2	FT-FY25-10082024-001116-B	<2
WS-001118	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 314		WF-04092024-001118	10/31/2024	FT-FY25-10082024-001118-A	<2	FT-FY25-10082024-001118-B	<2
WS-001122	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 311		WF-04092024-001122	10/31/2024	FT-FY25-10082024-001122-A	<2	FT-FY25-10082024-001122-B	<2
WS-001123	4/9/2024	4/9/2025	3	Bottle Filler	In hallway adjacent to restroom		WF-04092024-001123	10/31/2024	FT-FY25-10082024-001123-A	<2	FT-FY25-10082024-001123-B	<2
WS-001124	4/9/2024	4/9/2025	3	Cooler	In hallway adjacent to restroom	High Left	WF-04092024-001124	10/31/2024	FT-FY25-10082024-001124-A	<2	FT-FY25-10082024-001124-B	<2
WS-001125	4/9/2024	4/9/2025	3	Cooler	In hallway adjacent to restroom	Low Right	WF-04092024-001125	10/31/2024	FT-FY25-10082024-001125-A	<2	FT-FY25-10082024-001125-B	<2
WS-001127	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 315		WF-04092024-001127	10/31/2024	FT-FY25-10082024-001127-A	<2	FT-FY25-10082024-001127-B	<2
WS-001129	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 306		WF-04092024-001129	10/31/2024	FT-FY25-10082024-001129-A	<2	FT-FY25-10082024-001129-B	<2
WS-001142	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 341		WF-04092024-001142	10/31/2024	FT-FY25-10082024-001142-A	<2	FT-FY25-10082024-001142-B	<2
WS-001143	4/9/2024	4/9/2025	3	Break Room	In teacher workroom 339		WF-04092024-001143	10/31/2024	FT-FY25-10082024-001143-A	<2	FT-FY25-10082024-001143-B	<2
WS-001144	4/9/2024	4/9/2025	3	Combo Fountain	In teacher workroom 339		WF-04092024-001144	10/31/2024	FT-FY25-10082024-001144-A	2.4	FT-FY25-10082024-001144-B	<2
WS-001146	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 338		WF-04092024-001146	10/31/2024	FT-FY25-10082024-001146-A	<2	FT-FY25-10082024-001146-B	<2
WS-001148	4/9/2024	4/9/2025	3	Combo Fountain	In resource room 337		WF-04092024-001148	10/31/2024	FT-FY25-10082024-001148-A	<2	FT-FY25-10082024-001148-B	<2
WS-001218	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 335		WF-04092024-001218	10/31/2024	FT-FY25-10082024-001218-A	<2	FT-FY25-10082024-001218-B	<2
WS-001224	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 333		WF-04092024-001224	10/31/2024	FT-FY25-10082024-001224-A	<2	FT-FY25-10082024-001224-B	<2
WS-001226	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 372		WF-04092024-001226	10/31/2024	FT-FY25-10082024-001226-A	<2	FT-FY25-10082024-001226-B	<2
WS-001228	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 369		WF-04092024-001228	10/31/2024	FT-FY25-10082024-001228-A	<2	FT-FY25-10082024-001228-B	<2
WS-001230	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 365		WF-04092024-001230	10/31/2024	FT-FY25-10082024-001230-A	<2	FT-FY25-10082024-001230-B	<2
WS-001232	4/9/2024	4/9/2025	3	Combo Fountain	In classroom 361		WF-04092024-001232	10/31/2024	FT-FY25-10082024-001232-A	<2	FT-FY25-10082024-001232-B	<2
WS-001234	4/9/2024	4/9/2025	3	Combo Fountain	In makerspace 316		WF-04092024-001234	10/31/2024	FT-FY25-10082024-001234-A	<2	FT-FY25-10082024-001234-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000842	11/20/2023	11/20/2024	Basement	Food Prep Sink	In kitchen 2nd clockwise from entry	WF-11202023-000842	10/31/2024	FT-FY25-10082024-000842-A	<2	FT-FY25-10082024-000842-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000987	4/9/2024	4/9/2025	1	Combo Fountain	In treatment room 145	WF-04092024-000987	10/31/2024	FT-FY25-10082024-000987-A	8.3	FT-FY25-10082024-000987-B	<2
WS- 001111	9/23/2024	9/23/2025	2	Combo Faucet	In classroom 269	WF-09232024-001111	10/31/2024	FT-FY25-10082024-001111-A	17.1	FT-FY25-10082024-001111-B	<2

First Re-Test (After Plumbing Check)

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000987	11/6/2024	11/6/2025	1	Combo Fountain	In treatment room 145	WF-11062024-000987	11/15/2024	FT-FY25-11072024-000987-A	3.8	FT-FY25-11072024-000987-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001111	11/6/2024	11/6/2025	2	Combo Faucet	In classroom 269	WF-11062024-001111	11/15/2024	FT-FY25-11072024-001111-A	28.0	FT-FY25-11072024-001111-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.