



# EATON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	EATON ELEMENTARY	WS- 008665	8/22/2016	1	Cooler	In hallway adjacent to room 119	FT-72016-008665-A	< 1	FT-72016-008665-B	< 1
2	EATON ELEMENTARY	WS- 008673	8/22/2016	1	Classroom Faucet	In classroom 111 Right	FT-72016-008673-A	< 1	FT-72016-008673-B	< 1
3	EATON ELEMENTARY	WS- 008675	8/22/2016	1	Cooler	In main lobby Low Left	FT-72016-008675-A	< 1	FT-72016-008675-B	< 1
4	EATON ELEMENTARY	WS- 008676	8/22/2016	1	Cooler	In main lobby High Right	FT-72016-008676-A	< 1	FT-72016-008676-B	< 1
5	EATON ELEMENTARY	WS- 008677	8/22/2016	1	Health Suite	In health suite 102D	FT-72016-008677-A	< 1	FT-72016-008677-B	< 1
6	EATON ELEMENTARY	WS- 008679	8/22/2016	1	Other	In health suite 102D (portable water dispenser)	FT-72016-008679-A	< 1	FT-72016-008679-B	< 1
7	EATON ELEMENTARY	WS- 008685	8/22/2016	1	Food Prep Sink	In kitchen Left	FT-72016-008685-A	< 1	FT-72016-008685-B	< 1
8	EATON ELEMENTARY	WS- 008686	8/22/2016	1	Food Prep Sink	In kitchen Right	FT-72016-008686-A	< 1	FT-72016-008686-B	< 1
9	EATON ELEMENTARY	WS- 008687	8/22/2016	1	Ice Maker	In kitchen (ice maker)	FT-72016-008687-A	< 1	FT-72016-008687-B	< 1
10	EATON ELEMENTARY	WS- 008688	8/22/2016	2	Cooler	In hallway adjacent to room 218	FT-72016-008688-A	< 1	FT-72016-008688-B	< 1
11	EATON ELEMENTARY	WS- 008692	8/22/2016	2	Cooler	In hallway adjacent to room 209	FT-72016-008692-A	< 1	FT-72016-008692-B	< 1
12	EATON ELEMENTARY	WS- 008693	8/22/2016	2	Cooler	In classroom 209B	FT-72016-008693-A	< 1	FT-72016-008693-B	< 1
13	EATON ELEMENTARY	WS- 008697	8/22/2016	3	Cooler	In lobby adjacent to room 303	FT-72016-008697-A	< 1	FT-72016-008697-B	< 1
14	EATON ELEMENTARY	WS- 008701	8/22/2016	3	Cooler	In lobby adjacent to room 313	FT-72016-008701-A	< 1	FT-72016-008701-B	< 1