



EATON LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 EATON ELEMENTARY	5/12/2016	WS- 008664	Utility	Basement	Boiler room (water source)	WT-042916-8681- A	2	WT-042916-8681- B	< 1				
2 EATON ELEMENTARY	5/12/2016	WS- 008665	Cooler	1	In hallway adjacent to room 119	WT-042916-8682- A	< 1	WT-042916-8682- B	< 1				
3 EATON ELEMENTARY	5/12/2016	WS- 008666	Classroom	1	In classroom 119	WT-042916-8683- A	< 1	WT-042916-8683- B	< 1				
4 EATON ELEMENTARY	5/12/2016	WS- 008667	Classroom	1	In classroom 119	WT-042916-8684- A	4	WT-042916-8684- B	1				
5 EATON ELEMENTARY	5/12/2016	WS- 008668	Break Room	1	In classroom 119b	WT-042916-8685- A	< 1	WT-042916-8685- B	< 1				
6 EATON ELEMENTARY	5/12/2016	WS- 008669	Classroom	1	In classroom 120A	WT-042916-8686- A	< 1	WT-042916-8686- B	< 1				
7 EATON ELEMENTARY	5/12/2016	WS- 008670	Classroom	1	In classroom 120	WT-042916-8687- A	< 1	WT-042916-8687- B	< 1				
8 EATON ELEMENTARY	5/12/2016	WS- 008671	Classroom	1	In classroom 111	WT-042916-8688- A	< 1	WT-042916-8688- B	< 1				
9 EATON ELEMENTARY	5/12/2016	WS- 008672	Classroom	1	In classroom 111	WT-042916-8689- A	1	WT-042916-8689- B	4				
10 EATON ELEMENTARY	5/12/2016	WS- 008673	Classroom	1	In classroom 111	WT-042916-8690- A	70	WT-042916-8690- B	1	Filter will be installed and then retested			
11 EATON ELEMENTARY	5/12/2016	WS- 008674	Classroom	1	In classroom 113	WT-042916-8691- A	< 1	WT-042916-8691- B	< 1				
12 EATON ELEMENTARY	5/12/2016	WS- 008675	Cooler	1	In main lobby	WT-042916-8692- A	< 1	WT-042916-8692- B	< 1				
13 EATON ELEMENTARY	5/12/2016	WS- 008676	Cooler	1	In main lobby	WT-042916-8693- A	< 1	WT-042916-8693- B	< 1				
14 EATON ELEMENTARY	5/12/2016	WS- 008677	Health Suite	1	In health suite	WT-042916-8694- A	< 1	WT-042916-8694- B	< 1				
15 EATON ELEMENTARY	5/12/2016	WS- 008678	Health Suite	1	In health suit 102b	WT-042916-8695- A	3	WT-042916-8695- B	< 1				
16 EATON ELEMENTARY	5/12/2016	WS- 008679	Other	1	In health suite (cold/hot water dispenser)	WT-042916-8696- A	< 1	WT-042916-8696- B	< 1				
17 EATON ELEMENTARY	5/12/2016	WS- 008680	Other	1	In health suite (ice maker)	WT-042916-8697- A	< 1	WT-042916-8697- B	< 1				
18 EATON ELEMENTARY	5/12/2016	WS- 008681	Break Room	1	In classroom 104	WT-042916-8698- A	< 1	WT-042916-8698- B	< 1				
19 EATON ELEMENTARY	5/12/2016	WS- 008682	Break Room	1	In break room 104b	WT-042916-8699- A	< 1	WT-042916-8699- B	< 1				
20 EATON ELEMENTARY	5/12/2016	WS- 008683	Other	1	In room 104B (cold water dispenser)	WT-042916-8700- A	< 1	WT-042916-8700- B	< 1				
21 EATON ELEMENTARY	5/12/2016	WS- 008684	Classroom	1	In classroom 105	WT-042916-8701- A	< 1	WT-042916-8701- B	< 1				
22 EATON ELEMENTARY	5/12/2016	WS- 008685	Kitchen	1	In kitchen	WT-042916-8702- A	< 1	WT-042916-8702- B	< 1				
23 EATON ELEMENTARY	5/12/2016	WS- 008686	Kitchen	1	In kitchen	WT-042916-8703- A	< 1	WT-042916-8703- B	< 1				
24 EATON ELEMENTARY	5/12/2016	WS- 008687	Other	1	In kitchen (ice maker)	WT-042916-8704- A	< 1	WT-042916-8704- B	< 1				
25 EATON ELEMENTARY	5/12/2016	WS- 008688	Cooler	1	In hallway adjacent to room 218	WT-042916-8705- A	< 1	WT-042916-8705- B	< 1				
26 EATON ELEMENTARY	5/12/2016	WS- 008689	Classroom	2	In classroom 218	WT-042916-8706- A	1	WT-042916-8706- B	< 1				
27 EATON ELEMENTARY	5/12/2016	WS- 008690	Classroom	2	In classroom 224	WT-042916-8707- A	< 1	WT-042916-8707- B	< 1				
28 EATON ELEMENTARY	5/12/2016	WS- 008691	Break Room	2	In library office	WT-042916-8708- A	4	WT-042916-8708- B	< 1				
29 EATON ELEMENTARY	5/12/2016	WS- 008692	Fountain	2	In hallway adjacent to room 209	WT-042916-8709- A	< 1	WT-042916-8709- B	< 1				
30 EATON ELEMENTARY	5/12/2016	WS- 008693	Cooler	2	In classroom 209B	WT-042916-8710- A	< 1	WT-042916-8710- B	< 1				
31 EATON ELEMENTARY	5/12/2016	WS- 008694	Classroom	2	In classroom 209b	WT-042916-8711- A	2	WT-042916-8711- B	< 1				
32 EATON ELEMENTARY	5/12/2016	WS- 008695	Classroom	2	In classroom 206	WT-042916-8712- A	1	WT-042916-8712- B	< 1				
33 EATON ELEMENTARY	5/12/2016	WS- 008696	Classroom	2	In classroom 207	WT-042916-8713- A	14	WT-042916-8713- B	< 1				
34 EATON ELEMENTARY	5/12/2016	WS- 008697	Fountain	3	In lobby adjacent to room 303	WT-042916-8714- A	< 1	WT-042916-8714- B	< 1				
35 EATON ELEMENTARY	5/12/2016	WS- 008698	Classroom	3	In classroom 303	WT-042916-8715- A	2	WT-042916-8715- B	< 1				
36 EATON ELEMENTARY	5/12/2016	WS- 008699	Classroom	3	In art room	WT-042916-8716- A	5	WT-042916-8716- B	< 1				
37 EATON ELEMENTARY	5/12/2016	WS- 008701	Cooler	3	In lobby adjacent room 313	WT-042916-8718- A	< 1	WT-042916-8718- B	< 1				
38 EATON ELEMENTARY	5/12/2016	WS- 008702	Classroom	3	In classroom 313	WT-042916-8719- A	1	WT-042916-8719- B	< 1				
39 EATON ELEMENTARY	5/12/2016	WS- 008703	Classroom	3	In classroom 319	WT-042916-8720- A	< 1	WT-042916-8720- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.