



Eaton ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008665	4/12/2018	4/12/2019	1	Cooler	In hallway adjacent to room 119	WF-04122018-008665	12/6/2018	FT-FY19-112018-008665-A	<1	FT-FY19-112018-008665-B	<1
WS- 008666	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 119 Right	WF-10082018-008666	12/6/2018	FT-FY19-112018-008666-A	<1	FT-FY19-112018-008666-B	<1
WS- 008667	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 119 Left	WF-10082018-008667	12/6/2018	FT-FY19-112018-008667-A	<1	FT-FY19-112018-008667-B	<1
WS- 008668	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 119B in room 119	WF-10082018-008668	12/6/2018	FT-FY19-112018-008668-A	<1	FT-FY19-112018-008668-B	<1
WS- 008669	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 120 Left	WF-10082018-008669	12/6/2018	FT-FY19-112018-008669-A	<1	FT-FY19-112018-008669-B	<1
WS- 008670	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 120 Right	WF-10082018-008670	12/6/2018	FT-FY19-112018-008670-A	<1	FT-FY19-112018-008670-B	<1
WS- 008671	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 111 Left	WF-10082018-008671	12/6/2018	FT-FY19-112018-008671-A	<1	FT-FY19-112018-008671-B	<1
WS- 008672	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 111 Mid	WF-10082018-008672	12/6/2018	FT-FY19-112018-008672-A	<1	FT-FY19-112018-008672-B	<1
WS- 008673	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 111 Right	WF-10082018-008673	12/6/2018	FT-FY19-112018-008673-A	<1	FT-FY19-112018-008673-B	<1
WS- 008674	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 113	WF-10082018-008674	12/6/2018	FT-FY19-112018-008674-A	<1	FT-FY19-112018-008674-B	<1
WS- 008675	4/12/2018	4/12/2019	1	Cooler	In main lobby Low Left	WF-04122018-008675	12/6/2018	FT-FY19-112018-008675-A	<1	FT-FY19-112018-008675-B	<1
WS- 008676	4/12/2018	4/12/2019	1	Cooler	In main lobby High Right	WF-04122018-008676	12/6/2018	FT-FY19-112018-008676-A	<1	FT-FY19-112018-008676-B	<1
WS- 008677	4/12/2018	4/12/2019	1	Health Suite	In health suite 102D	WF-04122018-008677	12/6/2018	FT-FY19-112018-008677-A	<1	FT-FY19-112018-008677-B	<1
WS- 008681	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 104	WF-10082018-008681	12/6/2018	FT-FY19-112018-008681-A	<1	FT-FY19-112018-008681-B	<1
WS- 008682	10/8/2018	10/8/2019	1	Classroom Faucet	In classroom 104 in room 104B	WF-10082018-008682	12/6/2018	FT-FY19-112018-008682-A	<1	FT-FY19-112018-008682-B	<1
WS- 008687	4/12/2018	4/12/2019	1	Ice Maker	In kitchen (ice maker)	WF-04122018-008687	12/6/2018	FT-FY19-112018-008687-A	<1	FT-FY19-112018-008687-B	<1
WS- 008688	4/12/2018	4/12/2019	2	Cooler	In hallway adjacent to room 218	WF-04122018-008688	12/6/2018	FT-FY19-112018-008688-A	<1	FT-FY19-112018-008688-B	<1
WS- 008691	4/12/2018	4/12/2019	2	Break Room	In library office	WF-04122018-008691	12/6/2018	FT-FY19-112018-008691-A	<1	FT-FY19-112018-008691-B	<1
WS- 008692	4/12/2018	4/12/2019	2	Cooler	In hallway adjacent to room 209	WF-04122018-008692	12/6/2018	FT-FY19-112018-008692-A	<1	FT-FY19-112018-008692-B	<1
WS- 008693	4/12/2018	4/12/2019	2	Cooler	In classroom 209B	WF-04122018-008693	12/6/2018	FT-FY19-112018-008693-A	<1	FT-FY19-112018-008693-B	<1
WS- 008697	4/12/2018	4/12/2019	3	Cooler	In lobby adjacent to room 303	WF-04122018-008697	12/6/2018	FT-FY19-112018-008697-A	<1	FT-FY19-112018-008697-B	<1
WS- 008701	4/12/2018	4/12/2019	3	Cooler	In lobby adjacent to room 313	WF-04122018-008701	12/6/2018	FT-FY19-112018-008701-A	<1	FT-FY19-112018-008701-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008685	1	Food Prep Sink	In kitchen Left	12/6/2018	FT-FY19-112018-008685-A	<1	FT-FY19-112018-008685-B	<1	
WS- 008686	1	Food Prep Sink	In kitchen Right	12/6/2018	FT-FY19-112018-008686-A	<1	FT-FY19-112018-008686-B	<1	