



# Edgewood Recreation Center Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008900	4/16/2024	4/16/2025	1	Break Room	In multipurpose room 119	WF-04162024-008900	5/10/2024	FT-FY24-04242024-008900-A	<1	FT-FY24-04242024-008900-B	<1
WS- 008901	11/29/2023	11/29/2024	1	Food Prep Sink	In kitchen 112	WF-11292023-008901	5/10/2024	FT-FY24-04242024-008901-A	<1	FT-FY24-04242024-008901-B	<1
WS- 008902	4/16/2024	4/16/2025	1	Bottle Filler	In hallway adjacent to family restroom	WF-04162024-008902	5/10/2024	FT-FY24-04242024-008902-A	<1	FT-FY24-04242024-008902-B	<1
WS- 008903	4/16/2024	4/16/2025	1	Cooler	In hallway adjacent to family restroom High Left	WF-04162024-008903	5/10/2024	FT-FY24-04242024-008903-A	<1	FT-FY24-04242024-008903-B	<1
WS- 008904	4/16/2024	4/16/2025	1	Cooler	In hallway adjacent to family restroom Low Right	WF-04162024-008904	5/10/2024	FT-FY24-04242024-008904-A	<1	FT-FY24-04242024-008904-B	<1
WS- 008905	4/16/2024	4/16/2025	1	Bottle Filler	In gym	WF-04162024-008905	5/10/2024	FT-FY24-04242024-008905-A	<1	FT-FY24-04242024-008905-B	<1
WS- 008906	4/16/2024	4/16/2025	1	Cooler	In gym High Left	WF-04162024-008906	5/10/2024	FT-FY24-04242024-008906-A	<1	FT-FY24-04242024-008906-B	<1
WS- 008907	4/16/2024	4/16/2025	1	Cooler	In gym Low Right	WF-04162024-008907	5/10/2024	FT-FY24-04242024-008907-A	<1	FT-FY24-04242024-008907-B	<1
WS- 008908	4/16/2024	4/16/2025	2	Bottle Filler	In fitness center 203	WF-04162024-008908	5/10/2024	FT-FY24-04242024-008908-A	<1	FT-FY24-04242024-008908-B	<1
WS- 008909	4/16/2024	4/16/2025	2	Cooler	In fitness center 203 High Left	WF-04162024-008909	5/10/2024	FT-FY24-04242024-008909-A	<1	FT-FY24-04242024-008909-B	<1
WS- 008910	4/16/2024	4/16/2025	2	Cooler	In fitness center 203 Low Right	WF-04162024-008910	5/10/2024	FT-FY24-04242024-008910-A	<1	FT-FY24-04242024-008910-B	<1