



# Eliot Hine (Maury Annex) Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001050	12/12/2017	12/12/2018	Ground Floor	Cooler	POD C, in hallway adjacent to C102	Left High	WF-122017-001050	12/26/2017	FT-FY18-122017-001050-A	<1	FT-FY18-122017-001050-B	<1
WS-001051	12/12/2017	12/12/2018	Ground Floor	Cooler	POD C, in hallway adjacent to C102	Right Low	WF-122017-001051	12/26/2017	FT-FY18-122017-001051-A	<1	FT-FY18-122017-001051-B	<1
WS-001052	12/12/2017	12/12/2018	Ground Floor	Cooler	POD C, in hallway adjacent to C102	Left High	WF-122017-001052	12/26/2017	FT-FY18-122017-001052-A	<1	FT-FY18-122017-001052-B	<1
WS-001053	12/12/2017	12/12/2018	Ground Floor	Cooler	POD C, in hallway adjacent to C102	Right Low	WF-122017-001053	12/26/2017	FT-FY18-122017-001053-A	<1	FT-FY18-122017-001053-B	<1
WS-001054	12/12/2017	12/12/2018	Ground Floor	Cooler	POD A, in hallway adjacent to A109	Left High	WF-122017-001054	12/26/2017	FT-FY18-122017-001054-A	<1	FT-FY18-122017-001054-B	<1
WS-001055	12/12/2017	12/12/2018	Ground Floor	Cooler	POD A, in hallway adjacent to A109	Right Low	WF-122017-001055	12/26/2017	FT-FY18-122017-001055-A	<1	FT-FY18-122017-001055-B	<1
WS-001056	12/12/2017	12/12/2018	Ground Floor	Cooler	POD A, in hallway adjacent to A109	Left High	WF-122017-001056	12/26/2017	FT-FY18-122017-001056-A	<1	FT-FY18-122017-001056-B	<1
WS-001057	12/12/2017	12/12/2018	Ground Floor	Cooler	POD A, in hallway adjacent to A109	Right Low	WF-122017-001057	12/26/2017	FT-FY18-122017-001057-A	<1	FT-FY18-122017-001057-B	<1
WS-001058	12/12/2017	12/12/2018	Ground Floor	Cooler	POD B, in hallway adjacent to B107	Left High	WF-122017-001058	12/26/2017	FT-FY18-122017-001058-A	<1	FT-FY18-122017-001058-B	<1
WS-001059	12/12/2017	12/12/2018	Ground Floor	Cooler	POD B, in hallway adjacent to B107	Right Low	WF-122017-001059	12/26/2017	FT-FY18-122017-001059-A	<1	FT-FY18-122017-001059-B	<1
WS-001060	12/12/2017	12/12/2018	Ground Floor	Cooler	POD B, in hallway adjacent to B107	Left High	WF-122017-001060	12/26/2017	FT-FY18-122017-001060-A	<1	FT-FY18-122017-001060-B	<1
WS-001061	12/12/2017	12/12/2018	Ground Floor	Cooler	POD B, in hallway adjacent to B107	Right Low	WF-122017-001061	12/26/2017	FT-FY18-122017-001061-A	<1	FT-FY18-122017-001061-B	<1
WS-001062	12/12/2017	12/12/2018	Ground Floor	Cooler	POD D, in hallway adjacent to D109	Left High	WF-122017-001062	12/26/2017	FT-FY18-122017-001062-A	<1	FT-FY18-122017-001062-B	<1
WS-001063	12/12/2017	12/12/2018	Ground Floor	Cooler	POD D, in hallway adjacent to D109	Right Low	WF-122017-001063	12/26/2017	FT-FY18-122017-001063-A	<1	FT-FY18-122017-001063-B	<1
WS-001064	12/12/2017	12/12/2018	Ground Floor	Cooler	POD D, in hallway adjacent to D109	Left High	WF-122017-001064	12/26/2017	FT-FY18-122017-001064-A	<1	FT-FY18-122017-001064-B	<1
WS-001065	12/12/2017	12/12/2018	Ground Floor	Cooler	POD D, in hallway adjacent to D109	Right Low	WF-122017-001065	12/26/2017	FT-FY18-122017-001065-A	<1	FT-FY18-122017-001065-B	<1
WS-001066	12/18/2017	12/18/2018	Ground Floor	Health	POD D, in Health Suite		WF-122017-001066	12/26/2017	FT-FY18-122017-001066-A	<1	FT-FY18-122017-001066-B	<1
WS-001067	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C100 in bathroom		WF-12018-001067	1/5/2018	FT-FY18-012018-001067-A	<1	FT-FY18-012018-001067-B	<1
WS-001068	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C108 in bathroom		WF-12018-001068	1/5/2018	FT-FY18-012018-001068-A	<1	FT-FY18-012018-001068-B	<1
WS-001069	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C101 in bathroom		WF-12018-001069	1/5/2018	FT-FY18-012018-001069-A	<1	FT-FY18-012018-001069-B	<1
WS-001070	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C107 in bathroom		WF-12018-001070	1/5/2018	FT-FY18-012018-001070-A	<1	FT-FY18-012018-001070-B	<1
WS-001071	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C102 in bathroom		WF-12018-001071	1/5/2018	FT-FY18-012018-001071-A	<1	FT-FY18-012018-001071-B	<1
WS-001072	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C106 in bathroom		WF-12018-001072	1/5/2018	FT-FY18-012018-001072-A	<1	FT-FY18-012018-001072-B	<1
WS-001074	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C105 in bathroom		WF-12018-001074	1/5/2018	FT-FY18-012018-001074-A	<1	FT-FY18-012018-001074-B	<1
WS-001075	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C104 in bathroom		WF-12018-001075	1/5/2018	FT-FY18-012018-001075-A	<1	FT-FY18-012018-001075-B	<1
WS-009675	5/17/2017	5/17/2018	Basement	Cooler	In multi-purpose room		WF-52017-009675	1/5/2018	FT-FY18-052017-009675-A	<1	FT-FY18-052017-009675-B	<1

Greater than 5 ppb - Devices Requiring Remediation												
WS-001073	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C103 in bathroom		WF-12018-001073	1/5/2018	FT-FY18-012018-001073-A	14	FT-FY18-012018-001073-B	8.7

## First Re-Test (After Plumbing Check)

### FY18 Filter Test

Greater than 5 ppb - Devices Requiring Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001073	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C103 in bathroom		WF-12018-001073	1/17/2018	FT-FY18-012018-001073-A	12	FT-FY18-012018-001073-B	5.5

## Second Re-Test (After Device Replacement)

### FY18 Filter Test

Below Actionable Level - Device will be Returned to Service												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001073	1/2/2018	1/2/2019	Ground Floor	Bathroom	POD C, in classroom C103 in bathroom		WF-12018-001073	1/23/2018	FT-FY18-012018-001073-A	2	FT-FY18-012018-001073-B	1.9