



Eliot Hine (Maury Annex) Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001050	12/12/17	12/12/18	1	Cooler	POD C, in hallway adjacent to C102 Left High	WF-122017-001050	12/26/17	FT-FY18-122017-001050-A	<1	FT-FY18-122017-001050-B	<1
WS-001051	12/12/17	12/12/18	1	Cooler	POD C, in hallway adjacent to C102 Right Low	WF-122017-001051	12/26/17	FT-FY18-122017-001051-A	<1	FT-FY18-122017-001051-B	<1
WS-001052	12/12/17	12/12/18	1	Cooler	POD C, in hallway adjacent to C102 Left High	WF-122017-001052	12/26/17	FT-FY18-122017-001052-A	<1	FT-FY18-122017-001052-B	<1
WS-001053	12/12/17	12/12/18	1	Cooler	POD C, in hallway adjacent to C102 Right Low	WF-122017-001053	12/26/17	FT-FY18-122017-001053-A	<1	FT-FY18-122017-001053-B	<1
WS-001054	12/12/17	12/12/18	1	Cooler	POD A, in hallway adjacent to A109 Left High	WF-122017-001054	12/26/17	FT-FY18-122017-001054-A	<1	FT-FY18-122017-001054-B	<1
WS-001055	12/12/17	12/12/18	1	Cooler	POD A, in hallway adjacent to A109 Right Low	WF-122017-001055	12/26/17	FT-FY18-122017-001055-A	<1	FT-FY18-122017-001055-B	<1
WS-001056	12/12/17	12/12/18	1	Cooler	POD A, in hallway adjacent to A109 Left High	WF-122017-001056	12/26/17	FT-FY18-122017-001056-A	<1	FT-FY18-122017-001056-B	<1
WS-001057	12/12/17	12/12/18	1	Cooler	POD A, in hallway adjacent to A109 Right Low	WF-122017-001057	12/26/17	FT-FY18-122017-001057-A	<1	FT-FY18-122017-001057-B	<1
WS-001058	12/12/17	12/12/18	1	Cooler	POD B, in hallway adjacent to B107 Left High	WF-122017-001058	12/26/17	FT-FY18-122017-001058-A	<1	FT-FY18-122017-001058-B	<1
WS-001059	12/12/17	12/12/18	1	Cooler	POD B, in hallway adjacent to B107 Right Low	WF-122017-001059	12/26/17	FT-FY18-122017-001059-A	<1	FT-FY18-122017-001059-B	<1
WS-001060	12/12/17	12/12/18	1	Cooler	POD B, in hallway adjacent to B107 Left High	WF-122017-001060	12/26/17	FT-FY18-122017-001060-A	<1	FT-FY18-122017-001060-B	<1
WS-001061	12/12/17	12/12/18	1	Cooler	POD B, in hallway adjacent to B107 Right Low	WF-122017-001061	12/26/17	FT-FY18-122017-001061-A	<1	FT-FY18-122017-001061-B	<1
WS-001062	12/12/17	12/12/18	1	Cooler	POD D, in hallway adjacent to D109 Left High	WF-122017-001062	12/26/17	FT-FY18-122017-001062-A	<1	FT-FY18-122017-001062-B	<1
WS-001063	12/12/17	12/12/18	1	Cooler	POD D, in hallway adjacent to D109 Right Low	WF-122017-001063	12/26/17	FT-FY18-122017-001063-A	<1	FT-FY18-122017-001063-B	<1
WS-001064	12/12/17	12/12/18	1	Cooler	POD D, in hallway adjacent to D109 Left High	WF-122017-001064	12/26/17	FT-FY18-122017-001064-A	<1	FT-FY18-122017-001064-B	<1
WS-001065	12/12/17	12/12/18	1	Cooler	POD D, in hallway adjacent to D109 Right Low	WF-122017-001065	12/26/17	FT-FY18-122017-001065-A	<1	FT-FY18-122017-001065-B	<1
WS-001066	12/18/17	12/18/18	1	Health Suite	Pod D Health Suite	WF-122017-001066	12/26/17	FT-FY18-122017-001066-A	<1	FT-FY18-122017-001066-B	<1