



Eliot Hine (Maury Annex) Lead Water Test Results



FY18 Filter Test

| Less than 5 ppb - Devices Requiring No Remediation | | | | | | | | | | | | | |
|----------------------------------------------------|-----------------------|------------------------|--------------|--------------|--------------------------------------|-------|------|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| RECORD ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-001050 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD C, in hallway adjacent to C102 | Left | High | WF-122017-001050 | 12/26/17 | FT-FY18-122017-001050-A | <1 | FT-FY18-122017-001050-B | <1 |
| WS-001051 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD C, in hallway adjacent to C102 | Right | Low | WF-122017-001051 | 12/26/17 | FT-FY18-122017-001051-A | <1 | FT-FY18-122017-001051-B | <1 |
| WS-001052 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD C, in hallway adjacent to C102 | Left | High | WF-122017-001052 | 12/26/17 | FT-FY18-122017-001052-A | <1 | FT-FY18-122017-001052-B | <1 |
| WS-001053 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD C, in hallway adjacent to C102 | Right | Low | WF-122017-001053 | 12/26/17 | FT-FY18-122017-001053-A | <1 | FT-FY18-122017-001053-B | <1 |
| WS-001054 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD A, in hallway adjacent to A109 | Left | High | WF-122017-001054 | 12/26/17 | FT-FY18-122017-001054-A | <1 | FT-FY18-122017-001054-B | <1 |
| WS-001055 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD A, in hallway adjacent to A109 | Right | Low | WF-122017-001055 | 12/26/17 | FT-FY18-122017-001055-A | <1 | FT-FY18-122017-001055-B | <1 |
| WS-001056 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD A, in hallway adjacent to A109 | Left | High | WF-122017-001056 | 12/26/17 | FT-FY18-122017-001056-A | <1 | FT-FY18-122017-001056-B | <1 |
| WS-001057 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD A, in hallway adjacent to A109 | Right | Low | WF-122017-001057 | 12/26/17 | FT-FY18-122017-001057-A | <1 | FT-FY18-122017-001057-B | <1 |
| WS-001058 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD B, in hallway adjacent to B107 | Left | High | WF-122017-001058 | 12/26/17 | FT-FY18-122017-001058-A | <1 | FT-FY18-122017-001058-B | <1 |
| WS-001059 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD B, in hallway adjacent to B107 | Right | Low | WF-122017-001059 | 12/26/17 | FT-FY18-122017-001059-A | <1 | FT-FY18-122017-001059-B | <1 |
| WS-001060 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD B, in hallway adjacent to B107 | Left | High | WF-122017-001060 | 12/26/17 | FT-FY18-122017-001060-A | <1 | FT-FY18-122017-001060-B | <1 |
| WS-001061 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD B, in hallway adjacent to B107 | Right | Low | WF-122017-001061 | 12/26/17 | FT-FY18-122017-001061-A | <1 | FT-FY18-122017-001061-B | <1 |
| WS-001062 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD D, in hallway adjacent to D109 | Left | High | WF-122017-001062 | 12/26/17 | FT-FY18-122017-001062-A | <1 | FT-FY18-122017-001062-B | <1 |
| WS-001063 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD D, in hallway adjacent to D109 | Right | Low | WF-122017-001063 | 12/26/17 | FT-FY18-122017-001063-A | <1 | FT-FY18-122017-001063-B | <1 |
| WS-001064 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD D, in hallway adjacent to D109 | Left | High | WF-122017-001064 | 12/26/17 | FT-FY18-122017-001064-A | <1 | FT-FY18-122017-001064-B | <1 |
| WS-001065 | 12/12/17 | 12/12/18 | Ground Floor | Cooler | POD D, in hallway adjacent to D109 | Right | Low | WF-122017-001065 | 12/26/17 | FT-FY18-122017-001065-A | <1 | FT-FY18-122017-001065-B | <1 |
| WS-001066 | 12/18/17 | 12/18/18 | Ground Floor | Health Suite | POD D, in Health Suite | | | WF-122017-001066 | 12/26/17 | FT-FY18-122017-001066-A | <1 | FT-FY18-122017-001066-B | <1 |
| WS-001067 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C100 in bathroom | | | WF-12018-001067 | 1/5/18 | FT-FY18-012018-001067-A | <1 | FT-FY18-012018-001067-B | <1 |
| WS-001068 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C108 in bathroom | | | WF-12018-001068 | 1/5/18 | FT-FY18-012018-001068-A | <1 | FT-FY18-012018-001068-B | <1 |
| WS-001069 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C101 in bathroom | | | WF-12018-001069 | 1/5/18 | FT-FY18-012018-001069-A | <1 | FT-FY18-012018-001069-B | <1 |
| WS-001070 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C107 in bathroom | | | WF-12018-001070 | 1/5/18 | FT-FY18-012018-001070-A | <1 | FT-FY18-012018-001070-B | <1 |
| WS-001071 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C102 in bathroom | | | WF-12018-001071 | 1/5/18 | FT-FY18-012018-001071-A | <1 | FT-FY18-012018-001071-B | <1 |
| WS-001072 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C106 in bathroom | | | WF-12018-001072 | 1/5/18 | FT-FY18-012018-001072-A | <1 | FT-FY18-012018-001072-B | <1 |
| WS-001074 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C105 in bathroom | | | WF-12018-001074 | 1/5/18 | FT-FY18-012018-001074-A | <1 | FT-FY18-012018-001074-B | <1 |
| WS-001075 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C104 in bathroom | | | WF-12018-001075 | 1/5/18 | FT-FY18-012018-001075-A | <1 | FT-FY18-012018-001075-B | <1 |
| WS-009675 | 5/17/17 | 5/17/18 | Basement | Cooler | In multi-purpose room | | | WF-52017-009675 | 1/5/18 | FT-FY18-052017-009675-A | <1 | FT-FY18-052017-009675-B | <1 |
| Greater than 5 ppb - Devices Requiring Remediation | | | | | | | | | | | | | |
| WS-001073 | 1/2/18 | 1/2/19 | Ground Floor | Bathroom | POD C, in classroom C103 in bathroom | | | WF-12018-001073 | 1/5/18 | FT-FY18-012018-001073-A | 14 | FT-FY18-012018-001073-B | 8.7 |