



ELIOT-HINE MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	ELIOT MIDDLE SCHOOL	WS- 009669	8/19/2016	Basement	Cooler	In cafeteria	FT-82016-009669-A	< 1	FT-82016-009669-B	< 1
2	ELIOT MIDDLE SCHOOL	WS- 009670	8/19/2016	Basement	Cooler	In teacher's dining room B-26	FT-82016-009670-A	< 1	FT-82016-009670-B	< 1
3	ELIOT MIDDLE SCHOOL	WS- 009671	8/19/2016	Basement	Food Prep Sink	In kitchen adjacent to restroom	FT-82016-009671-A	< 1	FT-82016-009671-B	< 1
4	ELIOT MIDDLE SCHOOL	WS- 009674	8/19/2016	Basement	Cooler	In hallway adjacent to storage room B-48	FT-82016-009674-A	< 1	FT-82016-009674-B	< 1
5	ELIOT MIDDLE SCHOOL	WS- 009675	8/19/2016	Basement	Cooler	In multi-purpose room	FT-82016-009675-A	< 1	FT-82016-009675-B	< 1
6	ELIOT MIDDLE SCHOOL	WS- 009676	8/19/2016	1	Cooler	In hallway adjacent to office 1-152	FT-82016-009676-A	< 1	FT-82016-009676-B	< 1
7	ELIOT MIDDLE SCHOOL	WS- 009677	8/19/2016	1	Cooler	In hallway adjacent to classroom 1-166	FT-82016-009677-A	< 1	FT-82016-009677-B	< 1
8	ELIOT MIDDLE SCHOOL	WS- 009678	8/19/2016	1	Cooler	In hallway across from classroom 1-077	FT-82016-009678-A	< 1	FT-82016-009678-B	< 1
9	ELIOT MIDDLE SCHOOL	WS- 009679	8/19/2016	1	Cooler	In hallway adjacent to classroom 1-070	FT-82016-009679-A	< 1	FT-82016-009679-B	< 1
10	ELIOT MIDDLE SCHOOL	WS- 009680	8/19/2016	1	Health Suite	In restroom in health suite	FT-82016-009680-A	< 1	FT-82016-009680-B	< 1
11	ELIOT MIDDLE SCHOOL	WS- 009681	8/19/2016	1	Cooler	In hallway across from principal's office 1-099	FT-82016-009681-A	< 1	FT-82016-009681-B	< 1
12	ELIOT MIDDLE SCHOOL	WS- 009682	8/19/2016	2	Cooler	In hallway adjacent to computer lab 2-198	FT-82016-009682-A	< 1	FT-82016-009682-B	< 1
13	ELIOT MIDDLE SCHOOL	WS- 009683	8/19/2016	2	Cooler	In hallway adjacent to classroom 2-206	FT-82016-009683-A	< 1	FT-82016-009683-B	< 1
14	ELIOT MIDDLE SCHOOL	WS- 009684	8/19/2016	2	Cooler	In hallway adjacent to classroom 2-210	FT-82016-009684-A	< 1	FT-82016-009684-B	< 1
15	ELIOT MIDDLE SCHOOL	WS- 009685	8/19/2016	2	Cooler	In hallway adjacent to classroom 2-224	FT-82016-009685-A	< 1	FT-82016-009685-B	< 1
16	ELIOT MIDDLE SCHOOL	WS- 009686	8/19/2016	3	Cooler	In hallway adjacent to classroom 3-266	FT-82016-009686-A	< 1	FT-82016-009686-B	< 1
17	ELIOT MIDDLE SCHOOL	WS- 009687	8/19/2016	3	Cooler	In hallway adjacent to classroom 3-262	FT-82016-009687-A	< 1	FT-82016-009687-B	< 1
18	ELIOT MIDDLE SCHOOL	WS- 009688	8/19/2016	3	Cooler	In hallway adjacent to staff resource room 3-255	FT-82016-009688-A	< 1	FT-82016-009688-B	< 1
19	ELIOT MIDDLE SCHOOL	WS- 009689	8/19/2016	3	Cooler	In hallway adjacent to classroom 3-277	FT-82016-009689-A	< 1	FT-82016-009689-B	< 1
20	ELIOT MIDDLE SCHOOL	WS- 009690	8/19/2016	Basement	Cooler	In cafeteria adjacent to boiler room stairwell	FT-82016-009690-A	< 1	FT-82016-009690-B	< 1
21	ELIOT MIDDLE SCHOOL	WS- 009691	8/19/2016	2	Cooler	In hallway adjacent to room 2-171	FT-82016-009691-A	< 1	FT-82016-009691-B	< 1
22	ELIOT MIDDLE SCHOOL	WS- 009692	8/19/2016	2	Classroom Faucet	In art room 2-189 third clockwise from entry door	FT-72016-009692-A	< 1	FT-72016-009692-B	< 1
23	ELIOT MIDDLE SCHOOL	WS- 009699	8/19/2016	1	Cooler	In gym across from boys' locker room	FT-82016-009699-A	< 1	FT-82016-009699-B	< 1
24	ELIOT MIDDLE SCHOOL	WS- 009700	8/19/2016	3	Cooler	In girls' locker room	FT-72016-009700-A	< 1	FT-72016-009700-B	< 1