



Eliot-Hine Middle School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015505	6/1/2021	6/1/2022	Ground Floor	Break Room	In room G23	WF-06012021-015505	2/22/2022	FT-FY22-02032022-015505-A	<1	FT-FY22-02032022-015505-B	<1
WS-015506	6/1/2021	6/1/2022	Ground Floor	Bottle Filler	In cafeteria	WF-06012021-015506	2/22/2022	FT-FY22-02032022-015506-A	<1	FT-FY22-02032022-015506-B	<1
WS-015507	6/1/2021	6/1/2022	Ground Floor	Cooler	In cafeteria High Left	WF-06012021-015507	2/22/2022	FT-FY22-02032022-015507-A	<1	FT-FY22-02032022-015507-B	<1
WS-015508	6/1/2021	6/1/2022	Ground Floor	Cooler	In cafeteria Low Right	WF-06012021-015508	2/22/2022	FT-FY22-02032022-015508-A	<1	FT-FY22-02032022-015508-B	<1
WS-015511	6/1/2021	6/1/2022	Ground Floor	Bottle Filler	In hallway adjacent to room G66 Left	WF-06012021-015511	2/22/2022	FT-FY22-02032022-015511-A	<1	FT-FY22-02032022-015511-B	<1
WS-015512	6/1/2021	6/1/2022	Ground Floor	Cooler	In hallway adjacent to room G66 Left	WF-06012021-015512	2/22/2022	FT-FY22-02032022-015512-A	<1	FT-FY22-02032022-015512-B	<1
WS-015513	6/1/2021	6/1/2022	Ground Floor	Bottle Filler	In hallway adjacent to room G66 Mid	WF-06012021-015513	2/22/2022	FT-FY22-02032022-015513-A	<1	FT-FY22-02032022-015513-B	<1
WS-015514	6/1/2021	6/1/2022	Ground Floor	Cooler	In hallway adjacent to room G66 Mid	WF-06012021-015514	2/22/2022	FT-FY22-02032022-015514-A	<1	FT-FY22-02032022-015514-B	<1
WS-015515	6/1/2021	6/1/2022	Ground Floor	Bottle Filler	In hallway adjacent to room G66 Right	WF-06012021-015515	2/22/2022	FT-FY22-02032022-015515-A	<1	FT-FY22-02032022-015515-B	<1
WS-015516	6/1/2021	6/1/2022	Ground Floor	Cooler	In hallway adjacent to room G66 Right	WF-06012021-015516	2/22/2022	FT-FY22-02032022-015516-A	<1	FT-FY22-02032022-015516-B	<1
WS-015528	6/1/2021	6/1/2022	1	Health Suite	Inside health suite 130 in room 132	WF-06012021-015528	2/22/2022	FT-FY22-02032022-015528-A	<1	FT-FY22-02032022-015528-B	<1
WS-015529	6/1/2021	6/1/2022	1	Bottle Filler	In hallway adjacent to room 130	WF-06012021-015529	2/22/2022	FT-FY22-02032022-015529-A	<1	FT-FY22-02032022-015529-B	<1
WS-015530	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to room 130 High Left	WF-06012021-015530	2/22/2022	FT-FY22-02032022-015530-A	<1	FT-FY22-02032022-015530-B	<1
WS-015531	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to room 130 Low Right	WF-06012021-015531	2/22/2022	FT-FY22-02032022-015531-A	<1	FT-FY22-02032022-015531-B	<1
WS-015532	6/1/2021	6/1/2022	1	Break Room	In room 120	WF-06012021-015532	2/22/2022	FT-FY22-02032022-015532-A	<1	FT-FY22-02032022-015532-B	<1
WS-015533	6/1/2021	6/1/2022	1	Bottle Filler	In hallway adjacent to room 120	WF-06012021-015533	2/22/2022	FT-FY22-02032022-015533-A	<1	FT-FY22-02032022-015533-B	<1
WS-015534	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to room 120 High Left	WF-06012021-015534	2/22/2022	FT-FY22-02032022-015534-A	<1	FT-FY22-02032022-015534-B	<1
WS-015535	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to room 120 Low Right	WF-06012021-015535	2/22/2022	FT-FY22-02032022-015535-A	<1	FT-FY22-02032022-015535-B	<1
WS-015538	6/1/2021	6/1/2022	1	Bottle Filler	In hallway adjacent to stairwell outside of gym	WF-06012021-015538	2/22/2022	FT-FY22-02032022-015538-A	<1	FT-FY22-02032022-015538-B	<1
WS-015539	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to stairwell outside of gym High Left	WF-06012021-015539	2/22/2022	FT-FY22-02032022-015539-A	<1	FT-FY22-02032022-015539-B	<1
WS-015540	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to stairwell outside of gym Low Right	WF-06012021-015540	2/22/2022	FT-FY22-02032022-015540-A	<1	FT-FY22-02032022-015540-B	<1
WS-015541	6/1/2021	6/1/2022	1	Bottle Filler	In gym	WF-06012021-015541	2/22/2022	FT-FY22-02032022-015541-A	<1	FT-FY22-02032022-015541-B	<1
WS-015542	6/1/2021	6/1/2022	1	Cooler	In gym High Left	WF-06012021-015542	2/22/2022	FT-FY22-02032022-015542-A	<1	FT-FY22-02032022-015542-B	<1
WS-015543	6/1/2021	6/1/2022	1	Cooler	In gym Low Right	WF-06012021-015543	2/22/2022	FT-FY22-02032022-015543-A	<1	FT-FY22-02032022-015543-B	<1
WS-015547	6/1/2021	6/1/2022	1	Combo Fountain	In room 134	WF-06012021-015547	2/22/2022	FT-FY22-02032022-015547-A	<1	FT-FY22-02032022-015547-B	<1
WS-015548	6/1/2021	6/1/2022	1	Bottle Filler	In hallway adjacent to room 134	WF-06012021-015548	2/22/2022	FT-FY22-02032022-015548-A	<1	FT-FY22-02032022-015548-B	<1
WS-015549	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to room 134 High Left	WF-06012021-015549	2/22/2022	FT-FY22-02032022-015549-A	<1	FT-FY22-02032022-015549-B	<1
WS-015550	6/1/2021	6/1/2022	1	Cooler	In hallway adjacent to room 134 Low Right	WF-06012021-015550	2/22/2022	FT-FY22-02032022-015550-A	<1	FT-FY22-02032022-015550-B	<1
WS-015551	6/1/2021	6/1/2022	2	Bottle Filler	In hallway across from 245	WF-06012021-015551	2/22/2022	FT-FY22-02032022-015551-A	<1	FT-FY22-02032022-015551-B	<1
WS-015552	6/1/2021	6/1/2022	2	Cooler	In hallway across from 245 High Left	WF-06012021-015552	2/22/2022	FT-FY22-02032022-015552-A	<1	FT-FY22-02032022-015552-B	<1
WS-015553	6/1/2021	6/1/2022	2	Cooler	In hallway across from 245 Low Right	WF-06012021-015553	2/22/2022	FT-FY22-02032022-015553-A	<1	FT-FY22-02032022-015553-B	<1
WS-015554	6/1/2021	6/1/2022	2	Break Room	In room 242	WF-06012021-015554	2/22/2022	FT-FY22-02032022-015554-A	<1	FT-FY22-02032022-015554-B	<1
WS-015557	6/1/2021	6/1/2022	2	Break Room	Inside room 211 in room 211A	WF-06012021-015557	2/22/2022	FT-FY22-02032022-015557-A	3.2	FT-FY22-02032022-015557-B	<1
WS-015560	6/1/2021	6/1/2022	2	Health Suite	In room 212	WF-06012021-015560	2/22/2022	FT-FY22-02032022-015560-A	<1	FT-FY22-02032022-015560-B	<1
WS-015561	6/1/2021	6/1/2022	2	Bottle Filler	In hallway adjacent to room 216	WF-06012021-015561	2/22/2022	FT-FY22-02032022-015561-A	<1	FT-FY22-02032022-015561-B	<1

WS-015562	6/1/2021	6/1/2022	2	Cooler	In hallway adjacent to room 216	High Left	WF-06012021-015562	2/22/2022	FT-FY22-02032022-015562-A	<1	FT-FY22-02032022-015562-B	<1
WS-015563	6/1/2021	6/1/2022	2	Cooler	In hallway adjacent to room 216	Low Right	WF-06012021-015563	2/22/2022	FT-FY22-02032022-015563-A	<1	FT-FY22-02032022-015563-B	<1
WS-015564	6/1/2021	6/1/2022	2	Cooler	In hallway adjacent to room 263	Low Left	WF-06012021-015564	2/22/2022	FT-FY22-02032022-015564-A	<1	FT-FY22-02032022-015564-B	<1
WS-015565	6/1/2021	6/1/2022	2	Cooler	In hallway adjacent to room 263	High Right	WF-06012021-015565	2/22/2022	FT-FY22-02032022-015565-A	<1	FT-FY22-02032022-015565-B	<1
WS-015567	6/1/2021	6/1/2022	2	Combo Fountain	In room 236		WF-06012021-015567	2/22/2022	FT-FY22-02032022-015567-A	<1	FT-FY22-02032022-015567-B	<1
WS-015568	6/1/2021	6/1/2022	2	Break Room	In room 234 between 236 and 232		WF-06012021-015568	2/22/2022	FT-FY22-02032022-015568-A	<1	FT-FY22-02032022-015568-B	<1
WS-015571	6/1/2021	6/1/2022	2	Bottle Filler	In hallway adjacent to room 232		WF-06012021-015571	2/22/2022	FT-FY22-02032022-015571-A	<1	FT-FY22-02032022-015571-B	<1
WS-015572	6/1/2021	6/1/2022	2	Cooler	In hallway adjacent to room 232	High Left	WF-06012021-015572	2/22/2022	FT-FY22-02032022-015572-A	<1	FT-FY22-02032022-015572-B	<1
WS-015573	6/1/2021	6/1/2022	2	Cooler	In hallway adjacent to room 232	Low Right	WF-06012021-015573	2/22/2022	FT-FY22-02032022-015573-A	<1	FT-FY22-02032022-015573-B	<1
WS-015591	6/1/2021	6/1/2022	3	Break Room	In room 328		WF-06012021-015591	2/22/2022	FT-FY22-02032022-015591-A	<1	FT-FY22-02032022-015591-B	<1
WS-015592	6/1/2021	6/1/2022	3	Bottle Filler	In hallway adjacent to room 318		WF-06012021-015592	2/22/2022	FT-FY22-02032022-015592-A	<1	FT-FY22-02032022-015592-B	<1
WS-015593	6/1/2021	6/1/2022	3	Cooler	In hallway adjacent to room 318	High Left	WF-06012021-015593	2/22/2022	FT-FY22-02032022-015593-A	<1	FT-FY22-02032022-015593-B	<1
WS-015594	6/1/2021	6/1/2022	3	Cooler	In hallway adjacent to room 318	Low Right	WF-06012021-015594	2/22/2022	FT-FY22-02032022-015594-A	<1	FT-FY22-02032022-015594-B	<1
WS-015595	6/1/2021	6/1/2022	3	Bottle Filler	In hallway adjacent to room 334		WF-06012021-015595	2/22/2022	FT-FY22-02032022-015595-A	<1	FT-FY22-02032022-015595-B	<1
WS-015596	6/1/2021	6/1/2022	3	Cooler	In hallway adjacent to room 334	High Left	WF-06012021-015596	2/22/2022	FT-FY22-02032022-015596-A	<1	FT-FY22-02032022-015596-B	<1
WS-015597	6/1/2021	6/1/2022	3	Cooler	In hallway adjacent to room 334	Low Right	WF-06012021-015597	2/22/2022	FT-FY22-02032022-015597-A	<1	FT-FY22-02032022-015597-B	<1
WS-015598	6/1/2021	6/1/2022	3	Break Room	In room 330		WF-06012021-015598	2/22/2022	FT-FY22-02032022-015598-A	2.0	FT-FY22-02032022-015598-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015524	3/10/2021	3/10/2022	Ground Floor	Food Prep Sink	In kitchen seventh clockwise from entry	WF-03102021-015524	2/22/2022	FT-FY22-02032022-015524-A	<1	FT-FY22-02032022-015524-B	<1