



# Eliot Hine Middle School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015505	5/23/2022	5/23/2023	Ground Floor	Break Room	In room G23	WF-05232022-015505	1/30/2023	FT-FY23-01102023-015505-A	<1	FT-FY23-01102023-015505-B	<1	
WS-015506	5/23/2022	5/23/2023	Ground Floor	Bottle Filler	In cafeteria	WF-05232022-015506	1/30/2023	FT-FY23-01102023-015506-A	<1	FT-FY23-01102023-015506-B	<1	
WS-015507	5/23/2022	5/23/2023	Ground Floor	Cooler	In cafeteria	High Left	WF-05232022-015507	1/30/2023	FT-FY23-01102023-015507-A	<1	FT-FY23-01102023-015507-B	<1
WS-015508	5/23/2022	5/23/2023	Ground Floor	Cooler	In cafeteria	Low Right	WF-05232022-015508	1/30/2023	FT-FY23-01102023-015508-A	<1	FT-FY23-01102023-015508-B	<1
WS-015511	5/23/2022	5/23/2023	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Left	WF-05232022-015511	1/30/2023	FT-FY23-01102023-015511-A	<1	FT-FY23-01102023-015511-B	<1
WS-015512	5/23/2022	5/23/2023	Ground Floor	Cooler	In hallway adjacent to room G66	Left	WF-05232022-015512	1/30/2023	FT-FY23-01102023-015512-A	<1	FT-FY23-01102023-015512-B	<1
WS-015513	5/23/2022	5/23/2023	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Mid	WF-05232022-015513	1/30/2023	FT-FY23-01102023-015513-A	<1	FT-FY23-01102023-015513-B	<1
WS-015514	5/23/2022	5/23/2023	Ground Floor	Cooler	In hallway adjacent to room G66	Mid	WF-05232022-015514	1/30/2023	FT-FY23-01102023-015514-A	<1	FT-FY23-01102023-015514-B	<1
WS-015515	5/23/2022	5/23/2023	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Right	WF-05232022-015515	1/30/2023	FT-FY23-01102023-015515-A	<1	FT-FY23-01102023-015515-B	<1
WS-015516	5/23/2022	5/23/2023	Ground Floor	Cooler	In hallway adjacent to room G66	Right	WF-05232022-015516	1/30/2023	FT-FY23-01102023-015516-A	<1	FT-FY23-01102023-015516-B	<1
WS-015528	5/23/2022	5/23/2023	1	Health Suite	Inside heath suite 130 in room 132		WF-05232022-015528	1/30/2023	FT-FY23-01102023-015528-A	<1	FT-FY23-01102023-015528-B	<1
WS-015529	5/23/2022	5/23/2023	1	Bottle Filler	In hallway adjacent to room 130		WF-05232022-015529	1/30/2023	FT-FY23-01102023-015529-A	<1	FT-FY23-01102023-015529-B	<1
WS-015530	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to room 130	High Left	WF-05232022-015530	1/30/2023	FT-FY23-01102023-015530-A	<1	FT-FY23-01102023-015530-B	<1
WS-015531	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to room 130	Low Right	WF-05232022-015531	1/30/2023	FT-FY23-01102023-015531-A	<1	FT-FY23-01102023-015531-B	<1
WS-015532	5/23/2022	5/23/2023	1	Break Room	In room 120		WF-05232022-015532	1/30/2023	FT-FY23-01102023-015532-A	<1	FT-FY23-01102023-015532-B	<1
WS-015533	5/23/2022	5/23/2023	1	Bottle Filler	In hallway adjacent to room 120		WF-05232022-015533	1/30/2023	FT-FY23-01102023-015533-A	<1	FT-FY23-01102023-015533-B	<1
WS-015534	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to room 120	High Left	WF-05232022-015534	1/30/2023	FT-FY23-01102023-015534-A	<1	FT-FY23-01102023-015534-B	<1
WS-015535	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to room 120	Low Right	WF-05232022-015535	1/30/2023	FT-FY23-01102023-015535-A	<1	FT-FY23-01102023-015535-B	<1
WS-015538	5/23/2022	5/23/2023	1	Bottle Filler	In hallway adjacent to stairwell outside of gym		WF-05232022-015538	1/30/2023	FT-FY23-01102023-015538-A	<1	FT-FY23-01102023-015538-B	<1
WS-015539	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to stairwell outside of gym	High Left	WF-05232022-015539	1/30/2023	FT-FY23-01102023-015539-A	<1	FT-FY23-01102023-015539-B	<1
WS-015540	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to stairwell outside of gym	Low Right	WF-05232022-015540	1/30/2023	FT-FY23-01102023-015540-A	<1	FT-FY23-01102023-015540-B	<1
WS-015541	5/23/2022	5/23/2023	1	Bottle Filler	In gym		WF-05232022-015541	1/30/2023	FT-FY23-01102023-015541-A	<1	FT-FY23-01102023-015541-B	<1
WS-015542	5/23/2022	5/23/2023	1	Cooler	In gym	High Left	WF-05232022-015542	1/30/2023	FT-FY23-01102023-015542-A	<1	FT-FY23-01102023-015542-B	<1
WS-015543	5/23/2022	5/23/2023	1	Cooler	In gym	Low Right	WF-05232022-015543	1/30/2023	FT-FY23-01102023-015543-A	<1	FT-FY23-01102023-015543-B	<1
WS-015547	5/23/2022	5/23/2023	1	Combo Fountain	In room 134		WF-05232022-015547	1/30/2023	FT-FY23-01102023-015547-A	<1	FT-FY23-01102023-015547-B	<1
WS-015548	5/23/2022	5/23/2023	1	Bottle Filler	In hallway adjacent to room 134		WF-05232022-015548	1/30/2023	FT-FY23-01102023-015548-A	<1	FT-FY23-01102023-015548-B	<1
WS-015549	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to room 134	High Left	WF-05232022-015549	1/30/2023	FT-FY23-01102023-015549-A	<1	FT-FY23-01102023-015549-B	<1
WS-015550	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to room 134	Low Right	WF-05232022-015550	1/30/2023	FT-FY23-01102023-015550-A	<1	FT-FY23-01102023-015550-B	<1
WS-015554	5/23/2022	5/23/2023	2	Break Room	In room 242		WF-05232022-015554	1/30/2023	FT-FY23-01102023-015554-A	<1	FT-FY23-01102023-015554-B	<1
WS-015557	5/23/2022	5/23/2023	2	Break Room	Inside room 211 in room 211A		WF-05232022-015557	1/30/2023	FT-FY23-01102023-015557-A	<1	FT-FY23-01102023-015557-B	<1
WS-015560	5/23/2022	5/23/2023	2	Health Suite	In room 212		WF-05232022-015560	1/30/2023	FT-FY23-01102023-015560-A	<1	FT-FY23-01102023-015560-B	<1
WS-015561	5/23/2022	5/23/2023	2	Bottle Filler	In hallway adjacent to room 216		WF-05232022-015561	1/30/2023	FT-FY23-01102023-015561-A	<1	FT-FY23-01102023-015561-B	<1
WS-015562	5/23/2022	5/23/2023	2	Cooler	In hallway adjacent to room 216	High Left	WF-05232022-015562	1/30/2023	FT-FY23-01102023-015562-A	<1	FT-FY23-01102023-015562-B	<1
WS-015563	5/23/2022	5/23/2023	2	Cooler	In hallway adjacent to room 216	Low Right	WF-05232022-015563	1/30/2023	FT-FY23-01102023-015563-A	<1	FT-FY23-01102023-015563-B	<1
WS-015564	7/18/2022	7/18/2023	2	Cooler	In hallway adjacent to room 263	Low Left	WF-07182022-015564	1/30/2023	FT-FY23-01102023-015564-A	<1	FT-FY23-01102023-015564-B	<1

WS-015565	5/23/2022	5/23/2023	2	Cooler	In hallway adjacent to room 263	High Right	WF-05232022-015565	1/30/2023	FT-FY23-01102023-015565-A	<1	FT-FY23-01102023-015565-B	<1
WS-015567	5/23/2022	5/23/2023	2	Combo Fountain	In room 236		WF-05232022-015567	1/30/2023	FT-FY23-01102023-015567-A	<1	FT-FY23-01102023-015567-B	<1
WS-015568	5/23/2022	5/23/2023	2	Break Room	In room 234 between 236 and 232		WF-05232022-015568	1/30/2023	FT-FY23-01102023-015568-A	<1	FT-FY23-01102023-015568-B	<1
WS-015591	5/23/2022	5/23/2023	3	Break Room	In room 328		WF-05232022-015591	1/30/2023	FT-FY23-01102023-015591-A	<1	FT-FY23-01102023-015591-B	<1
WS-015592	5/23/2022	5/23/2023	3	Bottle Filler	In hallway adjacent to room 318		WF-05232022-015592	1/30/2023	FT-FY23-01102023-015592-A	<1	FT-FY23-01102023-015592-B	<1
WS-015593	5/23/2022	5/23/2023	3	Cooler	In hallway adjacent to room 318	High Left	WF-05232022-015593	1/30/2023	FT-FY23-01102023-015593-A	<1	FT-FY23-01102023-015593-B	<1
WS-015594	5/23/2022	5/23/2023	3	Cooler	In hallway adjacent to room 318	Low Right	WF-05232022-015594	1/30/2023	FT-FY23-01102023-015594-A	<1	FT-FY23-01102023-015594-B	<1
WS-015595	5/23/2022	5/23/2023	3	Bottle Filler	In hallway adjacent to room 334		WF-05232022-015595	1/30/2023	FT-FY23-01102023-015595-A	<1	FT-FY23-01102023-015595-B	<1
WS-015596	5/23/2022	5/23/2023	3	Cooler	In hallway adjacent to room 334	High Left	WF-05232022-015596	1/30/2023	FT-FY23-01102023-015596-A	<1	FT-FY23-01102023-015596-B	<1
WS-015597	5/23/2022	5/23/2023	3	Cooler	In hallway adjacent to room 334	Low Right	WF-05232022-015597	1/30/2023	FT-FY23-01102023-015597-A	<1	FT-FY23-01102023-015597-B	<1
WS-015598	5/23/2022	5/23/2023	3	Break Room	In room 330		WF-05232022-015598	1/30/2023	FT-FY23-01102023-015598-A	<1	FT-FY23-01102023-015598-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015524	2/22/2022	2/22/2023	Ground Floor	Food Prep Sink	In kitchen seventh clockwise from entry	WF-02222022-015524	1/30/2023	FT-FY23-01102023-015524-A	<1	FT-FY23-01102023-015524-B	<1