



Eliot-Hine MS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001050	3/26/2019	3/26/2020	Ground Floor	Cooler	POD C, in hallway adjacent to C102 High Left	WF-03262019-001050	1/7/2020	FT-FY20-122019-001050-A	<1	FT-FY20-122019-001050-B	<1
WS-001051	3/26/2019	3/26/2020	Ground Floor	Cooler	POD C, in hallway adjacent to C102 Low Right	WF-03262019-001051	1/7/2020	FT-FY20-122019-001051-A	<1	FT-FY20-122019-001051-B	<1
WS-001052	3/26/2019	3/26/2020	Ground Floor	Cooler	POD C, in hallway adjacent to C102 High Left	WF-03262019-001052	1/7/2020	FT-FY20-122019-001052-A	<1	FT-FY20-122019-001052-B	<1
WS-001053	3/26/2019	3/26/2020	Ground Floor	Cooler	POD C, in hallway adjacent to C102 Low Right	WF-03262019-001053	1/7/2020	FT-FY20-122019-001053-A	<1	FT-FY20-122019-001053-B	<1
WS-001054	3/26/2019	3/26/2020	Ground Floor	Cooler	POD A, in hallway adjacent to A109 High Left	WF-03262019-001054	1/7/2020	FT-FY20-122019-001054-A	<1	FT-FY20-122019-001054-B	<1
WS-001055	3/26/2019	3/26/2020	Ground Floor	Cooler	POD A, in hallway adjacent to A109 Low Right	WF-03262019-001055	1/7/2020	FT-FY20-122019-001055-A	<1	FT-FY20-122019-001055-B	<1
WS-001056	3/26/2019	3/26/2020	Ground Floor	Cooler	POD A, in hallway adjacent to A109 High Left	WF-03262019-001056	1/7/2020	FT-FY20-122019-001056-A	<1	FT-FY20-122019-001056-B	<1
WS-001057	3/26/2019	3/26/2020	Ground Floor	Cooler	POD A, in hallway adjacent to A109 Low Right	WF-03262019-001057	1/7/2020	FT-FY20-122019-001057-A	<1	FT-FY20-122019-001057-B	<1
WS-001058	3/26/2019	3/26/2020	Ground Floor	Cooler	POD B, in hallway adjacent to B107 High Left	WF-03262019-001058	1/7/2020	FT-FY20-122019-001058-A	<1	FT-FY20-122019-001058-B	<1
WS-001059	3/26/2019	3/26/2020	Ground Floor	Cooler	POD B, in hallway adjacent to B107 Low Right	WF-03262019-001059	1/7/2020	FT-FY20-122019-001059-A	<1	FT-FY20-122019-001059-B	<1
WS-001060	3/26/2019	3/26/2020	Ground Floor	Cooler	POD B, in hallway adjacent to B107 High Left	WF-03262019-001060	1/7/2020	FT-FY20-122019-001060-A	<1	FT-FY20-122019-001060-B	<1
WS-001061	3/26/2019	3/26/2020	Ground Floor	Cooler	POD B, in hallway adjacent to B107 Low Right	WF-03262019-001061	1/7/2020	FT-FY20-122019-001061-A	<1	FT-FY20-122019-001061-B	<1
WS-001062	3/26/2019	3/26/2020	Ground Floor	Cooler	POD D, in hallway adjacent to D109 High Left	WF-03262019-001062	1/7/2020	FT-FY20-122019-001062-A	<1	FT-FY20-122019-001062-B	<1
WS-001063	3/26/2019	3/26/2020	Ground Floor	Cooler	POD D, in hallway adjacent to D109 Low Right	WF-03262019-001063	1/7/2020	FT-FY20-122019-001063-A	<1	FT-FY20-122019-001063-B	<1
WS-001064	3/26/2019	3/26/2020	Ground Floor	Cooler	POD D, in hallway adjacent to D109 High Left	WF-03262019-001064	1/7/2020	FT-FY20-122019-001064-A	<1	FT-FY20-122019-001064-B	<1
WS-001065	3/26/2019	3/26/2020	Ground Floor	Cooler	POD D, in hallway adjacent to D109 Low Right	WF-03262019-001065	1/7/2020	FT-FY20-122019-001065-A	<1	FT-FY20-122019-001065-B	<1
WS-001066	3/26/2019	3/26/2020	Ground Floor	Health Suite	POD A, in Health Suite bathroom	WF-03262019-001066	1/7/2020	FT-FY20-122019-001066-A	<1	FT-FY20-122019-001066-B	<1
WS-001076	3/26/2019	3/26/2020	Ground Floor	Fountain	In multi-purpose room High Left	WF-03262019-001076	1/7/2020	FT-FY20-122019-001076-A	<1	FT-FY20-122019-001076-B	<1
WS-001077	3/26/2019	3/26/2020	Ground Floor	Fountain	In multi-purpose room Low Right	WF-03262019-001077	1/7/2020	FT-FY20-122019-001077-A	<1	FT-FY20-122019-001077-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001080	7/25/2019	7/25/2020	Ground Floor	Food Prep Sink	In kitchen	WF-07252019-001080	1/7/2020	FT-FY20-122019-001080-A	<1	FT-FY20-122019-001080-B	<1