



# Eliot Hine Middle School Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009674	5/17/2017	5/17/2018	Basement	Cooler	In hallway adjacent to storage room B-48	WF-52017-009674	12/14/2017	FT-FY18-52017-009674-A	<1	FT-FY18-52017-009674-B	<1
WS- 009684	5/17/2017	5/17/2018	2	Cooler	In hallway adjacent to classroom 2-210	WF-52017-009684	12/14/2017	FT-FY18-52017-009684-A	<1	FT-FY18-52017-009684-B	<1
WS- 009687	5/17/2017	5/17/2018	3	Cooler	In hallway adjacent to classroom 3-262	WF-52017-009687	12/14/2017	FT-FY18-52017-009687-A	<1	FT-FY18-52017-009687-B	<1
WS- 009688	5/17/2017	5/17/2018	3	Cooler	In hallway adjacent to staff resource room 3-255	WF-52017-009688	12/14/2017	FT-FY18-52017-009688-A	<1	FT-FY18-52017-009688-B	<1
WS- 009691	5/17/2017	5/17/2018	2	Cooler	In hallway adjacent to room 2-171	WF-52017-009691	12/14/2017	FT-FY18-52017-009691-A	<1	FT-FY18-52017-009691-B	<1
WS- 009699	5/17/2017	5/17/2018	1	Cooler	In gym across from boys' locker room	WF-52017-009699	12/14/2017	FT-FY18-52017-009699-A	<1	FT-FY18-52017-009699-B	<1
WS- 009700	5/17/2017	5/17/2018	3	Cooler	In girls' locker room	WF-52017-009700	12/14/2017	FT-FY18-52017-009700-A	<1	FT-FY18-52017-009700-B	<1
WS- 009669	5/17/2017	5/17/2018	Basement	Cooler	In cafeteria	WF-52017-009669	12/14/2017	FT-FY18-52017-009669-A	<1	FT-FY18-52017-009669-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009671	Basement	Food Prep Sink	In kitchen adjacent to restroom	12/14/2017	FT-FY18-102017-009671-A	<1	FT-FY18-102017-009671-B	<1	