* * * DGS

ELIOT-HINE LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009668	Utility	Basement	In boiler room	WT-042916-9685- A	1.9	WT-042916-9685- B	3.7				
2 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009669	Cooler	Basement	In basement in cafeteria	WT-042916-9686- A	< 1	WT-042916-9686- B	< 1				
3 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009670	Cooler	Basement	In basement in teacher's dining room B-26	WT-042916-9687- A	< 1	WT-042916-9687- B	< 1				
	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009671	Kitchen	Basement	In basement in kitchen adjacent to restroom	WT-042916-9688- A	< 1	WT-042916-9688- B	< 1				
	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009672	Kitchen	Basement	In basement in kitchen across restroom Left	WT-042916-9689- A	< 1	WT-042916-9689- B	< 1				
6 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009673	Kitchen	Basement	In basement in kitchen across restroom Right	WT-042916-9690- A	< 1	WT-042916-9690- B	< 1				
7 6	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009674	Cooler	Basement	In basement adjacent to storage room B-48	WT-042916-9691- A	< 1	WT-042916-9691- B	< 1				
	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009675	Cooler	Basement	In basement in multi-use room	WT-042916-9692- A	< 1	WT-042916-9691- B WT-042916-9692- B	< 1				
0		3/13/2010	W3-009075	Coolei	basement	in basement in multi-use room	W1-042310-3032- A	< 1	W1-042310-3032-B	< 1				
9 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009676	Cooler	1	In first floor hallway adjacent to office 1-152	WT-042916-9693- A	< 1	WT-042916-9693- B	< 1				
10 5		E /12 /2016	N/C 000C77	Contan		In first floor hallway adjacent to classroom 1-	WT 042046 0604 A		WT 042046 0604 D					
10 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009677	Cooler	1	166 In first floor hallway across to classroom 1-	WT-042916-9694- A	< 1	WT-042916-9694- B	< 1				
11 0	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009678	Cooler	1	077	WT-042916-9695- A	< 1	WT-042916-9695- B	< 1				
11 0	ELIOT-HINE MIDDLE SCHOOL	5/15/2010	W3-009078	Cooler	1	In first floor hallway adjacent to classroom 1-	W1-042910-9095- A	< 1	W1-042910-9095- B	<1 <1				
12 F	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009679	Cooler	1	070	WT-042916-9696- A	< 1	WT-042916-9696- B	< 1				
	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS-009680	Health Suite	1	In health suite in bathroom	WT-042916-9697- A	< 1	WT-042916-9697- B	< 1				
13 -		5/15/2010	115 005000	ficaltin balte	-	In first floor hallway across from principal's	W1012510 5057 11		11 012510 5057 8					
14 F	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009681	Cooler	1	office 1-099	WT-042916-9698- A	< 1	WT-042916-9698- B	< 1				
		0, 00, 0000				In second floor hallway adjacent to								
15 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009682	Cooler	2	computer lab 2-198	WT-042916-9699- A	< 1	WT-042916-9699- B	< 1				
						In second floor hallway adjacent to								
16 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009683	Cooler	2	classroom 2-206	WT-042916-9700- A	< 1	WT-042916-9700- B	< 1				
						In second floor hallway adjacent to								
17 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009684	Cooler	2	classroom 2-210	WT-042916-9701- A	< 1	WT-042916-9701- B	< 1				
						In second floor hallway adjacent to								
18 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009685	Cooler	2	classroom 2-224	WT-042916-9702- A	< 1	WT-042916-9702- B	< 1				
						In third floor hallway adjacent to classroom								
19 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009686	Cooler	3	3-266	WT-042916-9703- A	< 1	WT-042916-9703- B	< 1				
						In third floor hallway adjacent to classroom								
20 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009687	Cooler	3	3-262	WT-042916-9704- A	< 1	WT-042916-9704- B	< 1				
						In third floor hallway adjacent to staff								
21 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009688	Cooler	3	resource room 3-255	WT-042916-9705- A	< 1	WT-042916-9705- B	< 1				
						In third floor hallway adjacent to classroom								
22 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009689	Cooler	3	3-277	WT-042916-9706- A	< 1	WT-042916-9706- B	< 1				
		- / - /			_									
23 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009690	Cooler	Basement	In cafeteria adjacent to boiler room stairs	WT-042916-9707- A	< 1	WT-042916-9707- B	< 1				
245		5/13/2016	N/C 000C01	Contan	2	In second floor hallway adjacent to room 2- 171	WT 042046 0700 A		WT 042046 0700 D					
24 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009691	Cooler	2	In art room 2-189 clockwise from window	WT-042916-9708- A	< 1	WT-042916-9708- B	< 1	labeled "not			
25 F	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009692	Classroom	2	(3)	WT-042916-9709- A	77	WT-042916-9709- B	2.1	for drinking"			
25 0		5/15/2010	W3 005052	classiconii	2	In art room 2-189 clockwise from window	WT 042510 5705 A		W1 042510 5705 B	2.1	Tor uninking			
26 F	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009693	Classroom	2	(2)	WT-042916-9710- A	7	WT-042916-9710- B	1.7				
20 2		5/15/2010	115 005055	classiconi	-	In art room 2-189 clockwise from window	W1012510 5/10 //	,	W1 012510 5/10 B	1.7				
27 F	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009694	Classroom	2	(1)	WT-042916-9711- A	5.5	WT-042916-9711- B	2.1				
		0, 00, 0000			_			0.0						
28 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009695	Classroom	2	In room 2-188 clockwise from window (1)	WT-042916-9712- A	5.1	WT-042916-9712- B	< 1			1	
								-			1		1	
29 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009696	Classroom	2	In room 2-188 clockwise from window (2)	WT-042916-9713- A	2.9	WT-042916-9713- B	< 1				
30 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009697	Classroom	2	In room 2-188 clockwise from window (3)	WT-042916-9714- A	3.9	WT-042916-9714- B	< 1				
Τ														
31 E	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009698	Classroom	2	In room 2-188 clockwise from window (4)	WT-042916-9715- A	2.7	WT-042916-9715- B	< 1				
				1		In first floor gymnasium across from male							1	
-	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009699	Cooler	1	locker room	WT-042916-9716- A	< 1	WT-042916-9716- B	< 1				
221	LIOT-HINE MIDDLE SCHOOL	5/13/2016	WS- 009700	Cooler	3	In third floor girls locker room	WT-042916-9717- A	19	WT-042916-9717- B	23	Filtered	7/1/2016	<1	<1

	DGS	ELIOT-HINE LEAD WATER TEST RESULTS							16th, 2016	ele	ev★t	e			
ĺ	Building Location	Sample Collected	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.