



Eliot-Hine Middle School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015505	5/15/2023	5/15/2024	Ground Floor	Break Room	In room G23	WF-05152023-015505	1/4/2024	FT-FY24-11012023-015505-A	<1	FT-FY24-11012023-015505-B	<1	
WS-015506	5/15/2023	5/15/2024	Ground Floor	Bottle Filler	In cafeteria	WF-05152023-015506	1/4/2024	FT-FY24-11012023-015506-A	<1	FT-FY24-11012023-015506-B	<1	
WS-015507	5/15/2023	5/15/2024	Ground Floor	Cooler	In cafeteria	High Left	WF-05152023-015507	1/4/2024	FT-FY24-11012023-015507-A	<1	FT-FY24-11012023-015507-B	<1
WS-015508	5/15/2023	5/15/2024	Ground Floor	Cooler	In cafeteria	Low Right	WF-05152023-015508	1/4/2024	FT-FY24-11012023-015508-A	<1	FT-FY24-11012023-015508-B	<1
WS-015511	5/15/2023	5/15/2024	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Left	WF-05152023-015511	1/4/2024	FT-FY24-11012023-015511-A	<1	FT-FY24-11012023-015511-B	<1
WS-015512	5/15/2023	5/15/2024	Ground Floor	Cooler	In hallway adjacent to room G66	Left	WF-05152023-015512	1/4/2024	FT-FY24-11012023-015512-A	<1	FT-FY24-11012023-015512-B	<1
WS-015513	5/15/2023	5/15/2024	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Mid	WF-05152023-015513	1/4/2024	FT-FY24-11012023-015513-A	<1	FT-FY24-11012023-015513-B	<1
WS-015514	5/15/2023	5/15/2024	Ground Floor	Cooler	In hallway adjacent to room G66	Mid	WF-05152023-015514	1/4/2024	FT-FY24-11012023-015514-A	<1	FT-FY24-11012023-015514-B	<1
WS-015515	5/15/2023	5/15/2024	Ground Floor	Bottle Filler	In hallway adjacent to room G66	Right	WF-05152023-015515	1/4/2024	FT-FY24-11012023-015515-A	<1	FT-FY24-11012023-015515-B	<1
WS-015516	5/15/2023	5/15/2024	Ground Floor	Cooler	In hallway adjacent to room G66	Right	WF-05152023-015516	1/4/2024	FT-FY24-11012023-015516-A	<1	FT-FY24-11012023-015516-B	<1
WS-015528	5/15/2023	5/15/2024	1	Health Suite	inside heath suite 130 in room 132		WF-05152023-015528	1/4/2024	FT-FY24-11012023-015528-A	<1	FT-FY24-11012023-015528-B	<1
WS-015532	5/15/2023	5/15/2024	1	Break Room	In room 120		WF-05152023-015532	1/4/2024	FT-FY24-11012023-015532-A	<1	FT-FY24-11012023-015532-B	<1
WS-015533	5/15/2023	5/15/2024	1	Bottle Filler	In hallway adjacent to room 120		WF-05152023-015533	1/4/2024	FT-FY24-11012023-015533-A	<1	FT-FY24-11012023-015533-B	<1
WS-015534	5/15/2023	5/15/2024	1	Cooler	In hallway adjacent to room 120	High Left	WF-05152023-015534	1/4/2024	FT-FY24-11012023-015534-A	<1	FT-FY24-11012023-015534-B	<1
WS-015535	5/15/2023	5/15/2024	1	Cooler	In hallway adjacent to room 120	Low Right	WF-05152023-015535	1/4/2024	FT-FY24-11012023-015535-A	<1	FT-FY24-11012023-015535-B	<1
WS-015541	5/15/2023	5/15/2024	1	Bottle Filler	In gym		WF-05152023-015541	1/4/2024	FT-FY24-11012023-015541-A	<1	FT-FY24-11012023-015541-B	<1
WS-015542	5/15/2023	5/15/2024	1	Cooler	In gym	High Left	WF-05152023-015542	1/4/2024	FT-FY24-11012023-015542-A	<1	FT-FY24-11012023-015542-B	<1
WS-015543	5/15/2023	5/15/2024	1	Cooler	In gym	Low Right	WF-05152023-015543	1/4/2024	FT-FY24-11012023-015543-A	<1	FT-FY24-11012023-015543-B	<1
WS-015547	5/15/2023	5/15/2024	1	Combo Fountain	In room 134		WF-05152023-015547	1/4/2024	FT-FY24-11012023-015547-A	<1	FT-FY24-11012023-015547-B	<1
WS-015551	5/15/2023	5/15/2024	2	Bottle Filler	In hallway across from 245		WF-05152023-015551	1/4/2024	FT-FY24-11012023-015551-A	<1	FT-FY24-11012023-015551-B	<1
WS-015552	5/15/2023	5/15/2024	2	Cooler	In hallway across from 245	High Left	WF-05152023-015552	1/4/2024	FT-FY24-11012023-015552-A	<1	FT-FY24-11012023-015552-B	<1
WS-015553	5/15/2023	5/15/2024	2	Cooler	In hallway across from 245	Low Right	WF-05152023-015553	1/4/2024	FT-FY24-11012023-015553-A	<1	FT-FY24-11012023-015553-B	<1
WS-015554	5/15/2023	5/15/2024	2	Break Room	In room 242		WF-05152023-015554	1/4/2024	FT-FY24-11012023-015554-A	<1	FT-FY24-11012023-015554-B	<1
WS-015557	5/15/2023	5/15/2024	2	Break Room	inside room 211 in room 211A		WF-05152023-015557	1/4/2024	FT-FY24-11012023-015557-A	1.3	FT-FY24-11012023-015557-B	1.2
WS-015560	5/15/2023	5/15/2024	2	Health Suite	In room 212		WF-05152023-015560	1/4/2024	FT-FY24-11012023-015560-A	<1	FT-FY24-11012023-015560-B	<1
WS-015561	5/15/2023	5/15/2024	2	Bottle Filler	In hallway adjacent to room 216		WF-05152023-015561	1/4/2024	FT-FY24-11012023-015561-A	<1	FT-FY24-11012023-015561-B	<1
WS-015562	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room 216	High Left	WF-05152023-015562	1/4/2024	FT-FY24-11012023-015562-A	<1	FT-FY24-11012023-015562-B	1.5
WS-015563	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room 216	Low Right	WF-05152023-015563	1/4/2024	FT-FY24-11012023-015563-A	<1	FT-FY24-11012023-015563-B	<1
WS-015564	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room 263	Low Left	WF-05152023-015564	1/4/2024	FT-FY24-11012023-015564-A	<1	FT-FY24-11012023-015564-B	<1
WS-015565	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room 263	High Right	WF-05152023-015565	1/4/2024	FT-FY24-11012023-015565-A	<1	FT-FY24-11012023-015565-B	<1
WS-015567	5/15/2023	5/15/2024	2	Combo Fountain	In room 236		WF-05152023-015567	1/4/2024	FT-FY24-11012023-015567-A	<1	FT-FY24-11012023-015567-B	<1
WS-015568	5/15/2023	5/15/2024	2	Break Room	In room 234 between 236 and 232		WF-05152023-015568	1/4/2024	FT-FY24-11012023-015568-A	<1	FT-FY24-11012023-015568-B	<1
WS-015570	5/15/2023	5/15/2024	2	Combo Fountain	In room 232		WF-05152023-015570	1/4/2024	FT-FY24-11012023-015570-A	<1	FT-FY24-11012023-015570-B	<1
WS-015571	5/15/2023	5/15/2024	2	Bottle Filler	In hallway adjacent to room 232		WF-05152023-015571	1/4/2024	FT-FY24-11012023-015571-A	<1	FT-FY24-11012023-015571-B	<1
WS-015572	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room 232	High Left	WF-05152023-015572	1/4/2024	FT-FY24-11012023-015572-A	<1	FT-FY24-11012023-015572-B	<1

WS-015573	5/15/2023	5/15/2024	2	Cooler	In hallway adjacent to room 232	Low Right	WF-05152023-015573	1/4/2024	FT-FY24-11012023-015573-A	<1	FT-FY24-11012023-015573-B	<1
WS-015591	5/15/2023	5/15/2024	3	Break Room	In room 328		WF-05152023-015591	1/4/2024	FT-FY24-11012023-015591-A	<1	FT-FY24-11012023-015591-B	<1
WS-015592	5/15/2023	5/15/2024	3	Bottle Filler	In hallway adjacent to room 318		WF-05152023-015592	1/4/2024	FT-FY24-11012023-015592-A	<1	FT-FY24-11012023-015592-B	<1
WS-015593	5/15/2023	5/15/2024	3	Cooler	In hallway adjacent to room 318	High Left	WF-05152023-015593	1/4/2024	FT-FY24-11012023-015593-A	<1	FT-FY24-11012023-015593-B	<1
WS-015594	5/15/2023	5/15/2024	3	Cooler	In hallway adjacent to room 318	Low Right	WF-05152023-015594	1/4/2024	FT-FY24-11012023-015594-A	<1	FT-FY24-11012023-015594-B	<1
WS-015595	5/15/2023	5/15/2024	3	Bottle Filler	In hallway adjacent to room 334		WF-05152023-015595	1/4/2024	FT-FY24-11012023-015595-A	<1	FT-FY24-11012023-015595-B	<1
WS-015596	5/15/2023	5/15/2024	3	Cooler	In hallway adjacent to room 334	High Left	WF-05152023-015596	1/4/2024	FT-FY24-11012023-015596-A	<1	FT-FY24-11012023-015596-B	<1
WS-015597	5/15/2023	5/15/2024	3	Cooler	In hallway adjacent to room 334	Low Right	WF-05152023-015597	1/4/2024	FT-FY24-11012023-015597-A	<1	FT-FY24-11012023-015597-B	<1
WS-015598	5/15/2023	5/15/2024	3	Break Room	In room 330		WF-05152023-015598	1/4/2024	FT-FY24-11012023-015598-A	<1	FT-FY24-11012023-015598-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015524	1/24/2023	1/24/2024	Ground Floor	Food Prep Sink	In kitchen seventh clockwise from entry	WF-01242023-015524	1/4/2024	FT-FY24-11012023-015524-A	<1	FT-FY24-11012023-015524-B	<1