



Emery RC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005480	4/10/2019	4/10/2020	1	Food Prep Sink	In pantry room 114	WF-04102019-005480	2/14/2020	FT-FY20-012020-005480-A	<1	FT-FY20-012020-005480-B	<1
WS- 005485	4/10/2019	4/10/2020	2	Cooler	In hallway across from elevator High Left	WF-04102019-005485	2/14/2020	FT-FY20-012020-005485-A	<1	FT-FY20-012020-005485-B	<1
WS- 005486	4/10/2019	4/10/2020	2	Cooler	In hallway across from elevator Low Right	WF-04102019-005486	2/14/2020	FT-FY20-012020-005486-A	<1	FT-FY20-012020-005486-B	<1
WS- 005491	4/10/2019	4/10/2020	1	Cooler	In hallway adjacent to gym 115 High Left	WF-04102019-005491	2/14/2020	FT-FY20-012020-005491-A	<1	FT-FY20-012020-005491-B	<1
WS- 005492	4/10/2019	4/10/2020	1	Cooler	In hallway adjacent to gym 116 Low Right	WF-04102019-005492	2/14/2020	FT-FY20-012020-005492-A	<1	FT-FY20-012020-005492-B	<1