



EMERY REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	EMERY REC CTR	WS- 005480	9/20/2016	1	Food Prep Sink	In pantry room 114	FT-82016-005480-A	< 1	FT-82016-005480-B	< 1
2	EMERY REC CTR	WS- 005485	9/20/2016	2	Cooler	In hallway across from elevator High	FT-82016-005485-A	< 1	FT-82016-005485-B	< 1
3	EMERY REC CTR	WS- 005486	9/20/2016	2	Cooler	In hallway across from elevator Low	FT-82016-005486-A	< 1	FT-82016-005486-B	< 1
4	EMERY REC CTR	WS- 005491	9/20/2016	1	Cooler	In hallway adjacent to gym 115 High	FT-82016-005491-A	< 1	FT-82016-005491-B	< 1
5	EMERY REC CTR	WS- 005492	9/20/2016	1	Cooler	In hallway adjacent to gym 116 Low	FT-82016-005492-A	< 1	FT-82016-005492-B	< 1