



# Excel Academy Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013900	8/7/2018	8/7/2019	Basement	Cooler	In hallway across from room 021	WF-08072018-013900	8/20/2018	FT-FY19-082018-013900-A	< 1	FT-FY19-082018-013900-B	< 1
WS-013901	8/7/2018	8/7/2019	Basement	Cooler	In classroom 021	WF-08072018-013901	8/20/2018	FT-FY19-082018-013901-A	< 1	FT-FY19-082018-013901-B	< 1
WS-013903	8/7/2018	8/7/2019	Basement	Cooler	In classroom 019	WF-08072018-013903	8/20/2018	FT-FY19-082018-013903-A	< 1	FT-FY19-082018-013903-B	< 1
WS-013904	8/7/2018	8/7/2019	Basement	Cooler	In classroom 015	WF-08072018-013904	8/20/2018	FT-FY19-082018-013904-A	< 1	FT-FY19-082018-013904-B	< 1
WS-013905	8/7/2018	8/7/2019	Basement	Cooler	In hallway across from fire control room #B06	WF-08072018-013905	8/20/2018	FT-FY19-082018-013905-A	1.5	FT-FY19-082018-013905-B	< 1
WS-013906	8/7/2018	8/7/2019	Basement	Bottle Filler	In cafeteria	WF-08072018-013906	8/20/2018	FT-FY19-082018-013906-A	< 1	FT-FY19-082018-013906-B	< 1
WS-013907	8/7/2018	8/7/2019	Basement	Cooler	In cafeteria	WF-08072018-013907	8/20/2018	FT-FY19-082018-013907-A	1.2	FT-FY19-082018-013907-B	< 1
WS-013915	8/7/2018	8/7/2019	Basement	Cooler	In hallway adjacent to classroom 003	WF-08072018-013915	8/20/2018	FT-FY19-082018-013915-A	< 1	FT-FY19-082018-013915-B	< 1
WS-013916	8/7/2018	8/7/2019	Basement	Cooler	In classroom 001	WF-08072018-013916	8/20/2018	FT-FY19-082018-013916-A	< 1	FT-FY19-082018-013916-B	< 1
WS-013917	8/7/2018	8/7/2019	1	Bathroom	In classroom 123	WF-08072018-013917	8/20/2018	FT-FY19-082018-013917-A	< 1	FT-FY19-082018-013917-B	< 1
WS-013918	8/7/2018	8/7/2019	1	Bathroom	In classroom 121	WF-08072018-013918	8/20/2018	FT-FY19-082018-013918-A	< 1	FT-FY19-082018-013918-B	< 1
WS-013919	8/7/2018	8/7/2019	1	Bathroom	In classroom 120	WF-08072018-013919	8/20/2018	FT-FY19-082018-013919-A	< 1	FT-FY19-082018-013919-B	< 1
WS-013920	8/7/2018	8/7/2019	1	Bathroom	In classroom 118	WF-08072018-013920	8/20/2018	FT-FY19-082018-013920-A	< 1	FT-FY19-082018-013920-B	< 1
WS-013921	8/7/2018	8/7/2019	1	Bathroom	In classroom 119	Left WF-08072018-013921	8/20/2018	FT-FY19-082018-013921-A	< 1	FT-FY19-082018-013921-B	< 1
WS-013923	8/7/2018	8/7/2019	1	Bathroom	In classroom 115	WF-08072018-013923	8/20/2018	FT-FY19-082018-013923-A	1.3	FT-FY19-082018-013923-B	< 1
WS-013924	8/7/2018	8/7/2019	1	Bathroom	In classroom 113	WF-08072018-013924	8/20/2018	FT-FY19-082018-013924-A	< 1	FT-FY19-082018-013924-B	< 1
WS-013925	8/7/2018	8/7/2019	1	Bathroom	In classroom 116	WF-08072018-013925	8/20/2018	FT-FY19-082018-013925-A	< 1	FT-FY19-082018-013925-B	< 1
WS-013926	8/7/2018	8/7/2019	1	Bathroom	In classroom 114	WF-08072018-013926	8/20/2018	FT-FY19-082018-013926-A	< 1	FT-FY19-082018-013926-B	< 1
WS-013927	8/7/2018	8/7/2019	1	Cooler	In hallway adjacent to room 111	WF-08072018-013927	8/20/2018	FT-FY19-082018-013927-A	< 1	FT-FY19-082018-013927-B	< 1
WS-013928	8/7/2018	8/7/2019	1	Cooler	In hallway adjacent to storage room 105	WF-08072018-013928	8/20/2018	FT-FY19-082018-013928-A	< 1	FT-FY19-082018-013928-B	< 1
WS-013929	8/7/2018	8/7/2019	1	Break Room	In staff lounge across from room 123	WF-08072018-013929	8/20/2018	FT-FY19-082018-013929-A	< 1	FT-FY19-082018-013929-B	< 1
WS-013930	8/7/2018	8/7/2019	2	Cooler	In hallway adjacent to faculty restroom T-16	WF-08072018-013930	8/20/2018	FT-FY19-082018-013930-A	< 1	FT-FY19-082018-013930-B	< 1
WS-013931	8/7/2018	8/7/2019	2	Health Suite	In health suite exam room 212A	WF-08072018-013931	8/20/2018	FT-FY19-082018-013931-A	< 1	FT-FY19-082018-013931-B	< 1
WS-013932	8/7/2018	8/7/2019	2	Health Suite	In health suite toilet room 212B	WF-08072018-013932	8/20/2018	FT-FY19-082018-013932-A	< 1	FT-FY19-082018-013932-B	< 1
WS-013933	8/7/2018	8/7/2019	2	Cooler	In hallway adjacent to janitor closet 211	WF-08072018-013933	8/20/2018	FT-FY19-082018-013933-A	< 1	FT-FY19-082018-013933-B	< 1
WS-013934	8/7/2018	8/7/2019	2	Cooler	In hallway adjacent to storage room 205	WF-08072018-013934	8/20/2018	FT-FY19-082018-013934-A	< 1	FT-FY19-082018-013934-B	< 1
WS-013935	8/7/2018	8/7/2019	3	Break Room	In staff lounge across from room 325	WF-08072018-013935	8/20/2018	FT-FY19-082018-013935-A	< 1	FT-FY19-082018-013935-B	< 1
WS-013936	8/7/2018	8/7/2019	3	Cooler	In hallway adjacent to teacher restroom T-17	WF-08072018-013936	8/20/2018	FT-FY19-082018-013936-A	< 1	FT-FY19-082018-013936-B	< 1
WS-013937	8/7/2018	8/7/2019	3	Cooler	In hallway across from room 308	WF-08072018-013937	8/20/2018	FT-FY19-082018-013937-A	< 1	FT-FY19-082018-013937-B	< 1
WS-013938	8/7/2018	8/7/2019	3	Cooler	In hallway across from room 306	WF-08072018-013938	8/20/2018	FT-FY19-082018-013938-A	< 1	FT-FY19-082018-013938-B	< 1
WS-013939	8/7/2018	8/7/2019	1	Cooler	In hallway adjacent to faculty restroom T-5	WF-08072018-013939	8/20/2018	FT-FY19-082018-013939-A	< 1	FT-FY19-082018-013939-B	< 1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013910	Basement	Food Prep Sink	In kitchen	8/20/2018	FT-FY19-082018-013910-A	< 1	FT-FY19-082018-013910-B	< 1