



# Excel Academy Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013917	10/5/2021	10/5/2022	1	Bathroom	In classroom 123	WF-10052021-013917	2/11/2022	FT-FY22-01182022-013917-A	1.0	FT-FY22-01182022-013917-B	2.7
WS-013918	10/5/2021	10/5/2022	1	Bathroom	In classroom 121	WF-10052021-013918	2/11/2022	FT-FY22-01182022-013918-A	<1	FT-FY22-01182022-013918-B	<1
WS-013919	10/5/2021	10/5/2022	1	Bathroom	In classroom 120	WF-10052021-013919	2/11/2022	FT-FY22-01182022-013919-A	<1	FT-FY22-01182022-013919-B	<1
WS-013920	10/5/2021	10/5/2022	1	Bathroom	In classroom 118	WF-10052021-013920	2/11/2022	FT-FY22-01182022-013920-A	<1	FT-FY22-01182022-013920-B	2.2
WS-013921	10/5/2021	10/5/2022	1	Bathroom	In classroom 119 Left	WF-10052021-013921	2/11/2022	FT-FY22-01182022-013921-A	<1	FT-FY22-01182022-013921-B	<1
WS-013923	10/5/2021	10/5/2022	1	Bathroom	In classroom 115	WF-10052021-013923	2/11/2022	FT-FY22-01182022-013923-A	<1	FT-FY22-01182022-013923-B	<1
WS-013924	10/5/2021	10/5/2022	1	Bathroom	In classroom 113	WF-10052021-013924	2/11/2022	FT-FY22-01182022-013924-A	<1	FT-FY22-01182022-013924-B	<1
WS-013925	10/5/2021	10/5/2022	1	Bathroom	In classroom 116	WF-10052021-013925	2/11/2022	FT-FY22-01182022-013925-A	<1	FT-FY22-01182022-013925-B	<1
WS-013926	10/5/2021	10/5/2022	1	Bathroom	In classroom 114	WF-10052021-013926	2/11/2022	FT-FY22-01182022-013926-A	<1	FT-FY22-01182022-013926-B	<1
WS-013927	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room 111	WF-03012021-013927	2/11/2022	FT-FY22-01182022-013927-A	<1	FT-FY22-01182022-013927-B	<1
WS-013928	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to storage room 105	WF-03012021-013928	2/11/2022	FT-FY22-01182022-013928-A	<1	FT-FY22-01182022-013928-B	<1
WS-013929	3/1/2021	3/1/2022	1	Break Room	In staff lounge across from room 123	WF-03012021-013929	2/11/2022	FT-FY22-01182022-013929-A	<1	FT-FY22-01182022-013929-B	<1
WS-013930	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to faculty restroom T-16	WF-03012021-013930	2/11/2022	FT-FY22-01182022-013930-A	<1	FT-FY22-01182022-013930-B	<1
WS-013931	3/1/2021	3/1/2022	2	Health Suite	In health suite exam room 212A	WF-03012021-013931	2/11/2022	FT-FY22-01182022-013931-A	<1	FT-FY22-01182022-013931-B	<1
WS-013932	3/1/2021	3/1/2022	2	Health Suite	In health suite toilet room 212B	WF-03012021-013932	2/11/2022	FT-FY22-01182022-013932-A	<1	FT-FY22-01182022-013932-B	<1
WS-013933	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to janitor closet 211	WF-03012021-013933	2/11/2022	FT-FY22-01182022-013933-A	<1	FT-FY22-01182022-013933-B	<1
WS-013934	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to storage room 205	WF-03012021-013934	2/11/2022	FT-FY22-01182022-013934-A	<1	FT-FY22-01182022-013934-B	<1
WS-013935	3/1/2021	3/1/2022	3	Break Room	In staff lounge across from room 325	WF-03012021-013935	2/11/2022	FT-FY22-01182022-013935-A	<1	FT-FY22-01182022-013935-B	<1
WS-013937	3/1/2021	3/1/2022	3	Cooler	In hallway across from room 308	WF-03012021-013937	2/11/2022	FT-FY22-01182022-013937-A	<1	FT-FY22-01182022-013937-B	<1
WS-013939	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to faculty restroom T-5	WF-03012021-013939	2/11/2022	FT-FY22-01182022-013939-A	<1	FT-FY22-01182022-013939-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013910	2/19/2021	2/19/2022	Basement	Food Prep Sink	In kitchen	WF-02192021-013910	2/11/2022	FT-FY22-01182022-013910-A	<1	FT-FY22-01182022-013910-B	<1