



Excel Academy Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013906	2/22/2024	2/22/2025	Basement	Bottle Filler	In cafeteria	WF-02222024-013906	1/30/2025	FT-FY25-12262024-013906-A	<2	FT-FY25-12262024-013906-B	<2
WS-013917	9/16/2024	9/16/2025	1	Bathroom	In classroom 123	WF-09162024-013917	1/30/2025	FT-FY25-12262024-013917-A	<2	FT-FY25-12262024-013917-B	<2
WS-013918	9/16/2024	9/16/2025	1	Bathroom	In classroom 121	WF-09162024-013918	1/30/2025	FT-FY25-12262024-013918-A	<2	FT-FY25-12262024-013918-B	<2
WS-013921	9/16/2024	9/16/2025	1	Bathroom	In classroom 119 Left	WF-09162024-013921	1/30/2025	FT-FY25-12262024-013921-A	<2	FT-FY25-12262024-013921-B	<2
WS-013923	9/16/2024	9/16/2025	1	Bathroom	In classroom 115	WF-09162024-013923	1/30/2025	FT-FY25-12262024-013923-A	<2	FT-FY25-12262024-013923-B	<2
WS-013924	9/16/2024	9/16/2025	1	Bathroom	In classroom 113	WF-09162024-013924	1/30/2025	FT-FY25-12262024-013924-A	<2	FT-FY25-12262024-013924-B	<2
WS-013925	9/16/2024	9/16/2025	1	Bathroom	In classroom 116	WF-09162024-013925	1/30/2025	FT-FY25-12262024-013925-A	<2	FT-FY25-12262024-013925-B	<2
WS-013926	9/16/2024	9/16/2025	1	Bathroom	In classroom 114	WF-09162024-013926	1/30/2025	FT-FY25-12262024-013926-A	<2	FT-FY25-12262024-013926-B	<2
WS-013927	2/22/2024	2/22/2025	1	Cooler	In hallway adjacent to room 111	WF-02222024-013927	1/30/2025	FT-FY25-12262024-013927-A	<2	FT-FY25-12262024-013927-B	<2
WS-013928	2/22/2024	2/22/2025	1	Cooler	In hallway adjacent to storage room 105	WF-02222024-013928	1/30/2025	FT-FY25-12262024-013928-A	<2	FT-FY25-12262024-013928-B	<2
WS-013929	2/22/2024	2/22/2025	1	Break Room	In staff lounge across from room 123	WF-02222024-013929	1/30/2025	FT-FY25-12262024-013929-A	<2	FT-FY25-12262024-013929-B	<2
WS-013930	2/22/2024	2/22/2025	2	Cooler	In hallway adjacent to faculty restroom T-16	WF-02222024-013930	1/30/2025	FT-FY25-12262024-013930-A	<2	FT-FY25-12262024-013930-B	<2
WS-013931	2/22/2024	2/22/2025	2	Health Suite	In health suite exam room 212A	WF-02222024-013931	1/30/2025	FT-FY25-12262024-013931-A	<2	FT-FY25-12262024-013931-B	<2
WS-013932	2/22/2024	2/22/2025	2	Health Suite	In health suite toilet room 212B	WF-02222024-013932	1/30/2025	FT-FY25-12262024-013932-A	<2	FT-FY25-12262024-013932-B	<2
WS-013933	2/22/2024	2/22/2025	2	Cooler	In hallway adjacent to janitor closet 211	WF-02222024-013933	1/30/2025	FT-FY25-12262024-013933-A	<2	FT-FY25-12262024-013933-B	<2
WS-013934	2/22/2024	2/22/2025	2	Cooler	In hallway adjacent to storage room 205	WF-02222024-013934	1/30/2025	FT-FY25-12262024-013934-A	<2	FT-FY25-12262024-013934-B	<2
WS-013935	2/22/2024	2/22/2025	3	Break Room	In staff lounge across from room 325	WF-02222024-013935	1/30/2025	FT-FY25-12262024-013935-A	<2	FT-FY25-12262024-013935-B	<2
WS-013936	2/22/2024	2/22/2025	3	Cooler	In hallway adjacent to teacher restroom T-17	WF-02222024-013936	1/30/2025	FT-FY25-12262024-013936-A	<2	FT-FY25-12262024-013936-B	<2
WS-013937	2/22/2024	2/22/2025	3	Cooler	In hallway across from room 308	WF-02222024-013937	1/30/2025	FT-FY25-12262024-013937-A	<2	FT-FY25-12262024-013937-B	<2
WS-013938	2/22/2024	2/22/2025	3	Cooler	In hallway across from room 306	WF-02222024-013938	1/30/2025	FT-FY25-12262024-013938-A	<2	FT-FY25-12262024-013938-B	<2
WS-013939	2/22/2024	2/22/2025	1	Cooler	In hallway adjacent to faculty restroom T-5	WF-02222024-013939	1/30/2025	FT-FY25-12262024-013939-A	<2	FT-FY25-12262024-013939-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013910	11/18/2024	11/18/2025	Basement	Food Prep Sink	In kitchen	WF-11182024-013910	1/30/2025	FT-FY25-12262024-013910-A	<2	FT-FY25-12262024-013910-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.