



Excel Academy Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013906	9/10/2025	9/10/2026	Basement	Bottle Filler	In cafeteria	WF-09102025-013906	10/22/2025	FT-FY26-09302025-013906-A	<2	FT-FY26-09302025-013906-B	<2
WS-013907	9/10/2025	9/10/2026	Basement	Cooler	In cafeteria	WF-09102025-013907	10/22/2025	FT-FY26-09302025-013907-A	<2	FT-FY26-09302025-013907-B	<2
WS-013917	9/8/2025	9/8/2026	1	Bathroom	In classroom 123	WF-09082025-013917	10/22/2025	FT-FY26-09302025-013917-A	<2	FT-FY26-09302025-013917-B	<2
WS-013918	9/8/2025	9/8/2026	1	Bathroom	In classroom 121	WF-09082025-013918	10/22/2025	FT-FY26-09302025-013918-A	<2	FT-FY26-09302025-013918-B	<2
WS-013921	9/8/2025	9/8/2026	1	Bathroom	In classroom 119 Left	WF-09082025-013921	10/22/2025	FT-FY26-09302025-013921-A	2.7	FT-FY26-09302025-013921-B	<2
WS-013923	9/8/2025	9/8/2026	1	Bathroom	In classroom 115	WF-09082025-013923	10/22/2025	FT-FY26-09302025-013923-A	<2	FT-FY26-09302025-013923-B	<2
WS-013924	9/8/2025	9/8/2026	1	Bathroom	In classroom 113	WF-09082025-013924	10/22/2025	FT-FY26-09302025-013924-A	<2	FT-FY26-09302025-013924-B	<2
WS-013925	9/8/2025	9/8/2026	1	Bathroom	In classroom 116	WF-09082025-013925	10/22/2025	FT-FY26-09302025-013925-A	<2	FT-FY26-09302025-013925-B	<2
WS-013926	9/8/2025	9/8/2026	1	Bathroom	In classroom 114	WF-09082025-013926	10/22/2025	FT-FY26-09302025-013926-A	<2	FT-FY26-09302025-013926-B	<2
WS-013927	2/11/2025	2/11/2026	1	Cooler	In hallway adjacent to room 111	WF-02112025-013927	10/22/2025	FT-FY26-09302025-013927-A	<2	FT-FY26-09302025-013927-B	<2
WS-013928	2/11/2025	2/11/2026	1	Cooler	In hallway adjacent to storage room 105	WF-02112025-013928	10/22/2025	FT-FY26-09302025-013928-A	<2	FT-FY26-09302025-013928-B	<2
WS-013929	2/11/2025	2/11/2026	1	Break Room	In staff lounge across from room 123	WF-02112025-013929	10/22/2025	FT-FY26-09302025-013929-A	<2	FT-FY26-09302025-013929-B	<2
WS-013931	2/11/2025	2/11/2026	2	Health Suite	In health suite exam room 212A	WF-02112025-013931	10/22/2025	FT-FY26-09302025-013931-A	<2	FT-FY26-09302025-013931-B	<2
WS-013932	2/11/2025	2/11/2026	2	Health Suite	In health suite toilet room 212B	WF-02112025-013932	10/22/2025	FT-FY26-09302025-013932-A	<2	FT-FY26-09302025-013932-B	<2
WS-013934	2/11/2025	2/11/2026	2	Cooler	In hallway adjacent to storage room 205	WF-02112025-013934	10/22/2025	FT-FY26-09302025-013934-A	<2	FT-FY26-09302025-013934-B	<2
WS-013935	2/11/2025	2/11/2026	3	Break Room	In staff lounge across from room 325	WF-02112025-013935	10/22/2025	FT-FY26-09302025-013935-A	<2	FT-FY26-09302025-013935-B	<2
WS-013936	2/11/2025	2/11/2026	3	Cooler	In hallway adjacent to teacher restroom T-17	WF-02112025-013936	10/22/2025	FT-FY26-09302025-013936-A	<2	FT-FY26-09302025-013936-B	<2
WS-013937	2/11/2025	2/11/2026	3	Cooler	In hallway across from room 308	WF-02112025-013937	10/22/2025	FT-FY26-09302025-013937-A	<2	FT-FY26-09302025-013937-B	<2
WS-013938	2/11/2025	2/11/2026	3	Cooler	In hallway across from room 306	WF-02112025-013938	10/22/2025	FT-FY26-09302025-013938-A	<2	FT-FY26-09302025-013938-B	<2
WS-013939	2/11/2025	2/11/2026	1	Cooler	In hallway adjacent to faculty restroom T-5	WF-02112025-013939	10/22/2025	FT-FY26-09302025-013939-A	<2	FT-FY26-09302025-013939-B	<2
WS-013940	9/11/2025	9/11/2026	Basement	Cooler	In hallway adjacent to B13	WF-09112025-013940	10/22/2025	FT-FY26-09302025-013940-A	<2	FT-FY26-09302025-013940-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013910	11/18/2024	11/18/2025	Basement	Food Prep Sink	In kitchen	WF-11182024-013910	10/22/2025	FT-FY26-09302025-013910-A	<2	FT-FY26-09302025-013910-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.