



Excel Academy Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013906	3/19/2019	3/19/2020	Basement	Bottle Filler	In cafeteria	WF-03192019-013906	10/21/2019	FT-FY20-102019-013906-A	<1	FT-FY20-102019-013906-B	<1
WS-013907	3/19/2019	3/19/2020	Basement	Cooler	In cafeteria	WF-03192019-013907	10/21/2019	FT-FY20-102019-013907-A	<1	FT-FY20-102019-013907-B	<1
WS-013917	10/30/2018	10/30/2019	1	Bathroom	In classroom 123	WF-10302018-013917	10/21/2019	FT-FY20-102019-013917-A	3.2	FT-FY20-102019-013917-B	<1
WS-013918	10/30/2018	10/30/2019	1	Bathroom	In classroom 121	WF-10302018-013918	10/21/2019	FT-FY20-102019-013918-A	2.1	FT-FY20-102019-013918-B	<1
WS-013919	10/30/2018	10/30/2019	1	Bathroom	In classroom 120	WF-10302018-013919	10/21/2019	FT-FY20-102019-013919-A	4.7	FT-FY20-102019-013919-B	<1
WS-013920	10/30/2018	10/30/2019	1	Bathroom	In classroom 118	WF-10302018-013920	10/21/2019	FT-FY20-102019-013920-A	<1	FT-FY20-102019-013920-B	<1
WS-013921	10/30/2018	10/30/2019	1	Bathroom	In classroom 119	Left WF-10302018-013921	10/21/2019	FT-FY20-102019-013921-A	1.3	FT-FY20-102019-013921-B	<1
WS-013923	10/30/2018	10/30/2019	1	Bathroom	In classroom 115	WF-10302018-013923	10/21/2019	FT-FY20-102019-013923-A	<1	FT-FY20-102019-013923-B	<1
WS-013924	10/30/2018	10/30/2019	1	Bathroom	In classroom 113	WF-10302018-013924	10/21/2019	FT-FY20-102019-013924-A	<1	FT-FY20-102019-013924-B	<1
WS-013925	10/30/2018	10/30/2019	1	Bathroom	In classroom 116	WF-10302018-013925	10/21/2019	FT-FY20-102019-013925-A	<1	FT-FY20-102019-013925-B	<1
WS-013926	10/30/2018	10/30/2019	1	Bathroom	In classroom 114	WF-10302018-013926	10/21/2019	FT-FY20-102019-013926-A	<1	FT-FY20-102019-013926-B	<1
WS-013927	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to room 111	WF-03192019-013927	10/21/2019	FT-FY20-102019-013927-A	<1	FT-FY20-102019-013927-B	<1
WS-013928	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to storage room 105	WF-03192019-013928	10/21/2019	FT-FY20-102019-013928-A	<1	FT-FY20-102019-013928-B	<1
WS-013929	3/19/2019	3/19/2020	1	Break Room	In staff lounge across from room 123	WF-03192019-013929	10/21/2019	FT-FY20-102019-013929-A	<1	FT-FY20-102019-013929-B	<1
WS-013930	3/19/2019	3/19/2020	2	Cooler	In hallway adjacent to faculty restroom T-16	WF-03192019-013930	10/21/2019	FT-FY20-102019-013930-A	<1	FT-FY20-102019-013930-B	<1
WS-013931	3/19/2019	3/19/2020	2	Health Suite	In health suite exam room 212A	WF-03192019-013931	10/21/2019	FT-FY20-102019-013931-A	<1	FT-FY20-102019-013931-B	<1
WS-013932	3/19/2019	3/19/2020	2	Health Suite	In health suite toilet room 212B	WF-03192019-013932	10/21/2019	FT-FY20-102019-013932-A	<1	FT-FY20-102019-013932-B	<1
WS-013933	3/19/2019	3/19/2020	2	Cooler	In hallway adjacent to janitor closet 211	WF-03192019-013933	10/21/2019	FT-FY20-102019-013933-A	<1	FT-FY20-102019-013933-B	<1
WS-013934	3/19/2019	3/19/2020	2	Cooler	In hallway adjacent to storage room 205	WF-03192019-013934	10/21/2019	FT-FY20-102019-013934-A	<1	FT-FY20-102019-013934-B	<1
WS-013935	3/19/2019	3/19/2020	3	Break Room	In staff lounge across from room 325	WF-03192019-013935	10/21/2019	FT-FY20-102019-013935-A	<1	FT-FY20-102019-013935-B	<1
WS-013936	3/19/2019	3/19/2020	3	Cooler	In hallway adjacent to teacher restroom T-17	WF-03192019-013936	10/21/2019	FT-FY20-102019-013936-A	<1	FT-FY20-102019-013936-B	<1
WS-013937	3/19/2019	3/19/2020	3	Cooler	In hallway across from room 308	WF-03192019-013937	10/21/2019	FT-FY20-102019-013937-A	<1	FT-FY20-102019-013937-B	<1
WS-013938	3/19/2019	3/19/2020	3	Cooler	In hallway across from room 306	WF-03192019-013938	10/21/2019	FT-FY20-102019-013938-A	<1	FT-FY20-102019-013938-B	<1
WS-013939	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to faculty restroom T-5	WF-03192019-013939	10/21/2019	FT-FY20-102019-013939-A	<1	FT-FY20-102019-013939-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013910	7/17/2019	7/17/2020	Basement	Food Prep Sink	In kitchen	WF-07172019-013910	10/21/2019	FT-FY20-102019-013910-A	<1	FT-FY20-102019-013910-B	<1