



# Garrison ES Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002849	8/18/2017	8/18/2018	2	Combo Fountain	In classroom 249	WF-82017-002849	10/27/2017	FT-FY18-102017-002849-A	<1	FT-FY18-102017-002849-B	<1
WS- 002857	8/18/2017	8/18/2018	2	Combo Fountain	In classroom 247	WF-82017-002857	10/27/2017	FT-FY18-102017-002857-A	<1	FT-FY18-102017-002857-B	<1
WS- 002859	8/18/2017	8/18/2018	2	Combo Fountain	In classroom 244	WF-82017-002859	10/27/2017	FT-FY18-102017-002859-A	<1	FT-FY18-102017-002859-B	<1
WS- 002862	8/18/2017	8/18/2018	2	Cooler	In hallway adjacent to staff restroom	WF-82017-002862	10/27/2017	FT-FY18-102017-002862-A	<1	FT-FY18-102017-002862-B	<1
WS- 002864	8/18/2017	8/18/2018	2	Combo Fountain	In classroom 223	WF-82017-002864	10/27/2017	FT-FY18-102017-002864-A	<1	FT-FY18-102017-002864-B	<1
WS- 002872	8/18/2017	8/18/2018	2	Combo Fountain	In classroom 228	WF-82017-002872	10/27/2017	FT-FY18-102017-002872-A	<1	FT-FY18-102017-002872-B	<1
WS- 002876	8/18/2017	8/18/2018	2	Combo Fountain	In classroom 229	WF-82017-002876	10/27/2017	FT-FY18-102017-002876-A	<1	FT-FY18-102017-002876-B	<1
WS- 002879	10/17/2017	10/17/2018	1	Combo Faucet	In classroom 145	WF-102017-002879	10/27/2017	FT-FY18-102017-002879-A	<1	FT-FY18-102017-002879-B	<1
WS- 002887	8/18/2017	8/18/2018	1	Break Room	In parent resource center C105	WF-82017-002887	10/27/2017	FT-FY18-102017-002887-A	<1	FT-FY18-102017-002887-B	<1
WS- 002888	8/18/2017	8/18/2018	1	Cooler	In hallway adjacent to stairwell 1	WF-82017-002888	10/27/2017	FT-FY18-102017-002888-A	<1	FT-FY18-102017-002888-B	<1
WS- 002891	8/18/2017	8/18/2018	1	Combo Fountain	In classroom 125	WF-82017-002891	10/27/2017	FT-FY18-102017-002891-A	<1	FT-FY18-102017-002891-B	<1
WS- 002895	8/18/2017	8/18/2018	1	Combo Fountain	In classroom 127	WF-82017-002895	10/27/2017	FT-FY18-102017-002895-A	<1	FT-FY18-102017-002895-B	<1
WS- 002898	10/17/2017	10/17/2018	1	Combo Faucet	In classroom 132	WF-102017-002898	10/27/2017	FT-FY18-102017-002898-A	<1	FT-FY18-102017-002898-B	<1
WS- 002899	8/18/2017	8/18/2018	1	Combo Fountain	In classroom 132	WF-82017-002899	10/27/2017	FT-FY18-102017-002899-A	<1	FT-FY18-102017-002899-B	<1
WS- 002901	8/18/2017	8/18/2018	1	Combo Fountain	In classroom 129	WF-82017-002901	10/27/2017	FT-FY18-102017-002901-A	<1	FT-FY18-102017-002901-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS- 002732	1	Food Prep Sink	In kitchen	Right	10/27/2017	FT-FY18-102017-002732-A	<1	FT-FY18-102017-002732-B	<1	