



HD Cooke ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002354	5/26/2017	5/26/2018	1	Combo Fountain	In classroom 132	WF-52017-002354	11/2/2017	FT-FY18-102017-002354-A	<1	FT-FY18-102017-002354-B	<1
WS- 002357	10/16/2017	10/16/2018	1	Combo Faucet	In classroom 136	WF-102017-002357	11/2/2017	FT-FY18-102017-002357-A	2.4	FT-FY18-102017-002357-B	<1
WS- 002358	5/26/2017	5/26/2018	1	Combo Fountain	In classroom 133	WF-52017-002358	11/2/2017	FT-FY18-102017-002358-A	<1	FT-FY18-102017-002358-B	<1
WS- 002359	10/16/2017	10/16/2018	1	Combo Faucet	In classroom 133	WF-102017-002359	11/2/2017	FT-FY18-102017-002359-A	2	FT-FY18-102017-002359-B	<1
WS- 002361	10/16/2017	10/16/2018	1	Combo Faucet	In classroom 135	WF-102017-002361	11/2/2017	FT-FY18-102017-002361-A	<1	FT-FY18-102017-002361-B	<1
WS- 002367	5/26/2017	5/26/2018	1	Cooler	In hallway across from room 105	WF-52017-002367	11/2/2017	FT-FY18-102017-002367-A	<1	FT-FY18-102017-002367-B	<1
WS- 002374	5/26/2017	5/26/2018	2	Cooler	In hallway across from room 204	WF-52017-002374	11/2/2017	FT-FY18-102017-002374-A	<1	FT-FY18-102017-002374-B	<1
WS- 002378	5/26/2017	5/26/2018	2	Combo Fountain	In classroom 204	WF-52017-002378	11/2/2017	FT-FY18-102017-002378-A	<1	FT-FY18-102017-002378-B	<1
WS- 002384	5/26/2017	5/26/2018	2	Combo Fountain	In classroom 210	WF-52017-002384	11/2/2017	FT-FY18-102017-002384-A	<1	FT-FY18-102017-002384-B	<1
WS- 002394	5/26/2017	5/26/2018	2	Combo Fountain	In resource room 230	WF-52017-002394	11/2/2017	FT-FY18-102017-002394-A	<1	FT-FY18-102017-002394-B	<1
WS- 002395	10/16/2017	10/16/2018	2	Combo Faucet	In resource room 230	WF-102017-002395	11/2/2017	FT-FY18-102017-002395-A	<1	FT-FY18-102017-002395-B	<1
WS- 002396	5/26/2017	5/26/2018	2	Combo Fountain	In resource room 236	WF-52017-002396	11/2/2017	FT-FY18-102017-002396-A	<1	FT-FY18-102017-002396-B	<1
WS- 002397	10/16/2017	10/16/2018	2	Combo Faucet	In resource room 236	WF-102017-002397	11/2/2017	FT-FY18-102017-002397-A	1.9	FT-FY18-102017-002397-B	<1
WS- 002403	10/16/2017	10/16/2018	2	Combo Faucet	In classroom 232	WF-102017-002403	11/2/2017	FT-FY18-102017-002403-A	3.8	FT-FY18-102017-002403-B	<1
WS- 002404	5/26/2017	5/26/2018	2	Combo Fountain	In classroom 234	WF-52017-002404	11/2/2017	FT-FY18-102017-002404-A	<1	FT-FY18-102017-002404-B	<1
WS- 002405	10/16/2017	10/16/2018	2	Combo Faucet	In classroom 234	WF-102017-002405	11/2/2017	FT-FY18-102017-002405-A	<1	FT-FY18-102017-002405-B	<1
WS- 002406	5/26/2017	5/26/2018	3	Cooler	In hallway across from room 304	WF-52017-002406	11/2/2017	FT-FY18-102017-002406-A	<1	FT-FY18-102017-002406-B	<1
WS- 002407	5/26/2017	5/26/2018	3	Cooler	In hallway across from room 304	WF-52017-002407	11/2/2017	FT-FY18-102017-002407-A	<1	FT-FY18-102017-002407-B	<1
WS- 002408	5/26/2017	5/26/2018	3	Combo Fountain	In classroom 303	WF-52017-002408	11/2/2017	FT-FY18-102017-002408-A	<1	FT-FY18-102017-002408-B	<1
WS- 002410	10/16/2017	10/16/2018	3	Combo Faucet	In classroom 302	WF-102017-002410	11/2/2017	FT-FY18-102017-002410-A	3.3	FT-FY18-102017-002410-B	<1
WS- 002419	5/26/2017	5/26/2018	3	Combo Fountain	In classroom 311	WF-52017-002419	11/2/2017	FT-FY18-102017-002419-A	<1	FT-FY18-102017-002419-B	<1
WS- 002421	5/26/2017	5/26/2018	3	Combo Fountain	In classroom 312	WF-52017-002421	11/2/2017	FT-FY18-102017-002421-A	<1	FT-FY18-102017-002421-B	<1
WS- 002428	10/16/2017	10/16/2018	3	Combo Faucet	In resource room 342 adjacent to room 314	WF-102017-002428	11/2/2017	FT-FY18-102017-002428-A	1.3	FT-FY18-102017-002428-B	<1
Greater than 5 ppb - Devices Requiring Remediation											
WS- 002418	10/16/2017	10/16/2018	3	Combo Faucet	In classroom 310		11/2/2017	FT-FY18-102017-002418-A	11	FT-FY18-102017-002418-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS- 002365	1	Food Prep Sink	In kitchen fourth clockwise from entry door	11/2/2017	FT-FY18-102017-002365-A	<1	FT-FY18-102017-002365-B	<1			

First Re-Test (After Plumbing Check)

FY18 Filter Test

Less than 5 ppb - Device will be Returned to Service											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002418	10/16/2017	10/16/2018	3	Combo Faucet	In classroom 310	11/10/2017	FT-FY18-102017-002418-A	<1	FT-FY18-102017-002418-B	<1	