



Hearst ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004744	6/5/2017	6/5/2018	1	Health Suite	In health suite in exam room 2	WF-62017-004744	10/28/2017	FT-FY18-102017-004744-A	<1	FT-FY18-102017-004744-B	<1
WS-004746	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 122	WF-102017-004746	10/28/2017	FT-FY18-102017-004746-A	<1	FT-FY18-102017-004746-B	<1
WS-004750	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 114	WF-102017-004750	10/28/2017	FT-FY18-102017-004750-A	<1	FT-FY18-102017-004750-B	<1
WS-004763	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 165	WF-102017-004763	10/28/2017	FT-FY18-102017-004763-A	<1	FT-FY18-102017-004763-B	<1
WS-004764	6/5/2017	6/5/2018	1	Combo Fountain	In classroom 165	WF-62017-004764	10/28/2017	FT-FY18-102017-004764-A	<1	FT-FY18-102017-004764-B	<1
WS-004765	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 164	WF-102017-004765	10/28/2017	FT-FY18-102017-004765-A	<1	FT-FY18-102017-004765-B	<1
WS-004766	6/5/2017	6/5/2018	1	Combo Fountain	In classroom 164	WF-62017-004766	10/28/2017	FT-FY18-102017-004766-A	<1	FT-FY18-102017-004766-B	<1
WS-004767	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 161	WF-102017-004767	10/28/2017	FT-FY18-102017-004767-A	<1	FT-FY18-102017-004767-B	<1
WS-004769	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 160	WF-102017-004769	10/28/2017	FT-FY18-102017-004769-A	1.2	FT-FY18-102017-004769-B	<1
WS-004776	6/5/2017	6/5/2018	Basement	Ice Maker	In kitchen (ice maker)	WF-62017-004776	10/28/2017	FT-FY18-102017-004776-A	<1	FT-FY18-102017-004776-B	<1
WS-004777	6/5/2017	6/5/2018	Basement	Cooler	In gym	WF-62017-004777	10/28/2017	FT-FY18-102017-004777-A	<1	FT-FY18-102017-004777-B	<1
WS-004779	6/5/2017	6/5/2018	2	Break Room	In teacher work room 221	WF-62017-004779	10/28/2017	FT-FY18-102017-004779-A	<1	FT-FY18-102017-004779-B	<1
WS-004781	10/19/2017	10/19/2018	2	Combo Faucet	In classroom 219	WF-102017-004781	10/28/2017	FT-FY18-102017-004781-A	<1	FT-FY18-102017-004781-B	<1
WS-004784	7/7/2017	7/7/2018	2	Combo Fountain	In classroom 210	WF-72017-004784	10/28/2017	FT-FY18-102017-004784-A	<1	FT-FY18-102017-004784-B	<1
WS-004789	10/19/2017	10/19/2018	2	Combo Faucet	In classroom 260	WF-102017-004789	10/28/2017	FT-FY18-102017-004789-A	<1	FT-FY18-102017-004789-B	<1
WS-004791	6/5/2017	6/5/2018	2	Cooler	In hallway adjacent to room 220	WF-62017-004791	10/28/2017	FT-FY18-102017-004791-A	<1	FT-FY18-102017-004791-B	<1
WS-004796	6/5/2017	6/5/2018	2	Combo Fountain	In classroom 264	WF-62017-004796	10/28/2017	FT-FY18-102017-004796-A	<1	FT-FY18-102017-004796-B	<1
WS-004799	6/5/2017	6/5/2018	2	Break Room	In teacher work room 285	WF-62017-004799	10/28/2017	FT-FY18-102017-004799-A	<1	FT-FY18-102017-004799-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004774	Basement	Food Prep Sink	In kitchen on island	10/28/2017	FT-FY18-102017-004774-A	<1	FT-FY18-102017-004774-B	<1	
WS-004775	Basement	Food Prep Sink	In kitchen on island	10/28/2017	FT-FY18-102017-004775-A	<1	FT-FY18-102017-004775-B	<1	